

Late Comments  
8:30 a.m., April 26, 2012  
Regional Water Quality Control Board  
David C. Joseph Hearing Room  
5550 Skylane Boulevard, Suite A  
Santa Rosa, California

ITEM: 10

SUBJECT: **Public Hearing** on Order No. R1-2012-0015, to consider adoption of Waste Discharge Requirements for **Town of Scotia Company, LLC, Wastewater Treatment Facility and Eel River Power Cogeneration Plant**, WDID No. 1B83104OHUM, NPDES No. CA0006017, Humboldt County

#### DISCUSSION

After review of Regional Water Board staff's response to comments, Eel River Power, LLC, requested an additional change to the bottom and fly ash handling requirements for steam electric power plant. The following language reflects the requested modification and is recommended by staff for incorporation into proposed Order No. R1-2012-0015:

**b. Power Plant Solids Disposal and Handling Requirements.**

- i. By July 1, 2013, Bottom and Fly Ash generated at the Power Plant facility shall be stored in a title 27 compliant area or in a manner approved by the Executive Officer, until it can be either disposed of at a solid waste facility for which waste discharge requirements have been prescribed by a Regional Water Board, or disposed of or reused in a manner approved by the Regional Water Board.
- ~~ii. No later than December 4, 2013, Eel River Power, LLC shall submit a complete application to the Regional Water Board for either beneficial reuse or permitted disposal of both fly ash and bottom ash associated with the Power Plant.~~

Preliminary Staff  
Recommendation:

Adopt Order No. R1-2012-0015 with the proposed changes.