

Regional Water Quality Control Board
North Coast Region

Executive Officer's Summary Report
Thursday, June 19, 2014
Regional Water Board Office
Santa Rosa, California

- ITEM: 3
- SUBJECT: Public Hearing on Order No. R1-2014-0029 to consider adoption of proposed Waste Discharge Requirements for the **Town of Fort Jones, Wastewater Treatment Facility**, WDID No. 1A811570SIS (Roy O'Connor)
- BOARD ACTION: The Board will consider adoption of Waste Discharge Requirements Order No. R1-2014-0029.
- BACKGROUND: The Permittee owns and operates a municipal wastewater collection system and treatment facility which serves 342 connections, of which 3 are restaurants.
- The Permittee is currently regulated under Waste Discharge Requirements Order No. 98-1. The wastewater treatment facility (WWTF) is designed to treat and dispose of up to 60,000 gallons per day (GPD) of wastewater, and includes a collection system, Imhoff tank, and six percolation/evaporation ponds for effluent disposal.
- A groundwater monitoring assessment plan is required by this Order to develop a monitoring network to establish the local groundwater gradient and determine the appropriate locations to monitor discharges from the percolation/evaporation ponds. Attachment B of this Order requires ongoing monitoring to ensure that concentrations of pollutants will not adversely impact beneficial uses.
- A copy of the draft Order and information on how to access the draft posted on the Regional Water Board website was mailed to the Permittee, interested agencies, and persons. This item was open for public comment from April 1, 2014 through May 1, 2014. No comments were received from the Permittee, interested agencies, or the public.
- ISSUES: No permit concerns were expressed by the Permittee. Order No. R1-2014-0029 proposes effluent limitations and monthly sampling.
- RECOMMENDATION: Adopt Order No. R1-2014-0029, as proposed.
- SUPPORTING DOCUMENTS:
1. Proposed Order No. R1-2014-0029
 2. Public Notice