

North Coast Regional Water Quality Control Board

**ORDER NO. R1-2012-0097
NPDES NO. CA0022721
WDID NO. 1B83136OHUM**

**WASTE DISCHARGE REQUIREMENTS
FOR THE
CITY OF FERNDALE
WASTEWATER TREATMENT PLANT
HUMBOLDT COUNTY**

The following Permittee is subject to waste discharge requirements as set forth in this Order:

Table 1. Permittee Information

Permittee	City of Ferndale
Name of Facility	City of Ferndale Wastewater Treatment Facility
Facility Address	701 Port Kenyon Road
	Ferndale, CA 95536
	Humboldt County
Type of Facility	Publicly-Owned Treatment Works (POTW)
Facility Design Flow	0.55 mgd (average daily dry weather design flow ¹)
	0.95 mgd (peak daily wet weather design flow ²)

- ¹ Average daily dry weather design flow is defined as the average of daily volume of effluent calculated during the lowest consecutive 30-day period each calendar year.
- ² Peak daily wet weather design flow is defined as the maximum volume of effluent that may be treated, based on the capacity of the advanced wastewater treatment filters.

Table 2. Discharge Locations

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Disinfected tertiary treated municipal wastewater	40° 35' 40" N	124° 15' 44" W	Francis Creek/Salt River
002	Disinfected secondary treated municipal wastewater	Reclamation / Irrigation Use on Neighboring Agricultural Land		

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	December 6, 2012
This Order shall become effective on:	February 1, 2013
This Order shall expire on:	January 31, 2018
The Permittee shall file a Report of Waste Discharge as an application for renewal of waste discharge requirements in accordance with title 23, California Code of Regulations, no later than:	August 4, 2017
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a major discharge.	

IT IS HEREBY ORDERED, that Order No. R1-2009-0036 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Permittee shall comply with the requirements in this Order.

I, Matthias St. John, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, North Coast Region, on December 6, 2012.

Matthias St. John, Executive Officer

Table of Contents

I. FACILITY INFORMATION4
 II. FINDINGS.....4
 III. DISCHARGE PROHIBITIONS.....5
 IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS.....6
 A. Effluent Limitations.....6
 B. Land Discharge Specifications.....8
 C. Reclamation Specifications – Discharge Point 0028
 D. Other Requirements.....9
 V. RECEIVING WATER LIMITATIONS..... 10
 A. Surface Water Limitations 10
 B. Groundwater Limitations..... 12
 VI. PROVISIONS..... 13
 A. Standard Provisions 13
 B. Monitoring and Reporting Program (MRP) Requirements 13
 C. Special Provisions 13
 VII. COMPLIANCE DETERMINATION 24
 A. General 24
 B. Multiple Sample Data..... 24
 C. Average Monthly Effluent Limitation (AMEL) 25
 D. Average Weekly Effluent Limitation (AWEL)..... 25
 E. Maximum Daily Effluent Limitation (MDEL)..... 25
 F. Instantaneous Minimum Effluent Limitation 25
 G. Instantaneous Maximum Effluent Limitation 26

List of Tables

Table 1. Permittee Information1
 Table 2. Discharge Locations2
 Table 3. Administrative Information2
 Table 4. Effluent Limitations – Discharge Point 0016
 Table 5. Reclamation Discharge Specifications – Discharge Point 002.....9

List of Attachments

Attachment A – Definitions A-1
 Attachment B – Map Of City Of Ukiah Wastewater Treatment Plant..... B-1
 Attachment C – Facility Flow Schematic C-1
 Attachment D – Standard Provisions D-1
 Attachment E – Monitoring and Reporting Program (MRP) E-1
 Attachment F – Fact Sheet F-1

I. FACILITY INFORMATION

Information summarizing the City of Ferndale Wastewater Treatment Facility (hereinafter Facility or WWTF) is contained in Table 1 of this Order.

The Permittee owns wastewater collection, treatment, and disposal facilities that serve a population of approximately 1,500 residential and commercial users in the City of Ferndale. The treatment system is capable of the tertiary treatment of wastewater and includes a wet-weather flow equalization basin, headworks with an influent lift station, three surge pumps (one used for redundancy), a bar screen; a selector tank, four extended aeration basins, two rectangular clarifiers, two aerobic sludge digesters, disc filtration, an ultraviolet disinfection system, and a holding basin for temporary storage of treated effluent.

Additional background and facility information is provided in sections I and II of the Fact Sheet (Attachment F). Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the WWTF.

II. FINDINGS

The California Regional Water Quality Control Board, North Coast Region (hereinafter Regional Water Board), finds:

- A. Legal Authorities.** This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the Water Code (commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this Facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).
- B. Basis and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the Permittee's application for permit renewal, monitoring data collected and submitted during the term of the Permittee's previous Order, and other available information. The Fact Sheet (Attachment F) contains information and rationale for the requirements in this Order, is hereby incorporated into this Order and constitutes the Findings for this Order. Attachments A through E are also incorporated into this Order.
- C. Monitoring and Reporting.** Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP) establishing

monitoring and reporting requirements to implement federal and State requirements for the Facility is provided in Attachment E.

- D. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections of this Order and the MRP applicable to land application, reclamation and groundwater are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- E. Notification of Interested Parties.** The Regional Water Board has notified the Permittee and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of the notification are provided in the Fact Sheet.
- F. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

III. DISCHARGE PROHIBITIONS

- A.** The discharge of any waste not disclosed by the Permittee or not within the reasonable contemplation of the Regional Water Board is prohibited.
- B.** Creation of pollution, contamination, or nuisance, as defined by section 13050 of the California Water code is prohibited.
- C.** The discharge of sludge or digester supernatant is prohibited, except as authorized under VI. C. 5. c of this Order (Solids Disposal and Handling Requirements).
- D.** The discharge or reclamation use of untreated or partially treated waste (receiving a lower level of treatment than described in section II. A of the Fact Sheet) from anywhere within the collection, treatment, or disposal systems is prohibited, except as provided for in Prohibition III. E and in Attachment D, Standard Provision G (Bypass).
- E.** Any sanitary sewer overflow (SSO) that results in a discharge of untreated or partially treated wastewater to (a) waters of the State, (b) groundwater, or (c) land that creates pollution, contamination, or nuisance, as defined in Water Code section 13050 (m) is prohibited.

- F. The discharge of waste to land that is not owned by or under agreement to use by the Discharger is prohibited, except for use for fire suppression as provided in title 22, sections 60307 (a) and (b) of the Cal. Code of Regs.
- G. The discharge of waste at any point not described in Table 2 B or authorized by a permit issued by the State Water Board or another Regional Water Board is prohibited.
- H. The discharge of treated wastewater to the Eel River and its tributaries is prohibited during the period from May 15 through September 30 of each year.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations

1. Final Effluent Limitations – Discharge Point 001

- a. The Permittee shall maintain compliance with the following effluent limitations at Discharge Point 001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP.

Table 4. Effluent Limitations – Discharge Point 001

Effluent Limitations – Discharge Point 001						
Parameter	Units	Average Monthly ¹	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	---	---	---
	lbs/day ^{2,3}	79	119	---	---	---
Total Suspended Solids	mg/L	10	15	---	---	---
	lbs/day ^{2,3}	79	119	---	---	---
Settleable Solids	ml/L	0.1	---	0.2		
Total Coliform Organisms	MPN/100 ml	23 ⁴	---	230	---	---

¹ See Attachment A for definitions

² The mass discharge (lbs/day) is obtained from the following calculation for any calendar week or month:

$$\frac{8.34}{N} \sum_i^N Q_i C_i$$

in which N is the number of samples analyzed in any calendar week or month. Q_i and C_i are the flow rate (mgd) and the constituent concentration (mg/L), respectively, which are associated with each of the N grab samples, which may be taken in any calendar week or month. If a composite sample is taken, C_i is the concentration measured in the composite sample; and Q_i is the average flow rate occurring during the period over which samples are composited.

³ Mass-based effluent limitations are based on the wet weather peak design flow of 0.95 mgd.

⁴ The median of all samples collected in a 30-day calendar period.

Table 4. Effluent Limitations - Discharge Point 001

Effluent Limitations - Discharge Point 001						
Parameter	Units	Average Monthly ¹	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
pH	standard units	---	---	---	6.5	8.5
Ammonia Nitrogen	mg/L	1.0	---	---	---	---
Nitrate Nitrogen	mg/L	10	---	---	---	---
Total Nitrogen	mg/L	10	---	---	---	---
2,3,7,8 TCDD	µg/L	0.000000013	---	0.000000026	---	---

- b. Percent Removal.** The average monthly percent removal of BOD₅ and TSS shall not be less than 85 percent. Percent removal shall be determined from the 30-day average value of influent wastewater concentration in comparison to the 30-day average value of effluent concentration for the same constituent over the same time period as measured at Monitoring Locations M-INF and EFF-001, respectively.
- c. Discharge Rate.** During the period from October 1 through May 14, discharges of treated wastewater shall not exceed one-hundred percent (1:1) of the upstream receiving water flow.
- d. Flow.** The mean daily dry weather flow of waste through the treatment plant shall not exceed 0.55 mgd, measured over a calendar month. The average wet weather flow of waste through the treatment plant shall not exceed 0.95 mgd, measured daily and averaged over a calendar month.
- e. Acute Toxicity.** There shall be no acute toxicity in treated wastewater discharged to the Eel River and its tributaries. The Permittee will be considered compliant with this limitation when the survival of aquatic organisms in a 96-hour bioassay of undiluted effluent complies with the following.
 1. Minimum for any one bioassay: 70 percent survival;
 2. Median for any three or more consecutive bioassays: at least 90 percent survival.

Compliance with the acute toxicity effluent limitation shall be determined in accordance with section V of the MRP (Attachment E) of this Order.

B. Land Discharge Specifications

This section of the Order is not applicable as this Order does not permit treated wastewater to be land applied for the purpose of disposal. The Order does include Reclamation Specifications, below, which are applicable to reclamation/irrigation uses of treated wastewater.

C. Reclamation Specifications – Discharge Point 002

- 1. Reclamation / Recycling Requirements:** The Permittee shall comply with applicable state and local requirements regarding the production and use of reclaimed wastewater, including requirements of California Water Code (Water Code) sections 13500 – 13577 (Water Reclamation) and Department of Health Services (DHS) regulations at title 22, sections 60301 – 60357 of the Cal. Code of Regs (Water Recycling Criteria).
 - a.** The use of recycled water shall not create a condition of pollution or nuisance as defined in Water Code section 13050(m).
 - b.** Recycled water and airborne spray shall not be allowed to escape from the authorized recycled water use area(s).
 - c.** Direct or windblown spray, mist, or runoff from irrigation areas shall not enter dwellings, designated outdoor eating areas, or food handling facilities.
 - d.** Disinfected secondary treated recycled water shall not be irrigated within 100 feet of any domestic water supply well or domestic water supply surface intake, unless the technical requirements specified in title 22, Cal. Code of Regs., section 60310(a) have been met and approved by DHS.
 - e.** All areas where recycled water is used that are accessible to the public shall be posted with signs that are visible to the public, in a size no less than 4 inches high by 8 inches wide, and that include the following wording: 'RECYCLED WATER – DO NOT DRINK'. Each sign shall display an international symbol similar to that shown in title 22, Cal. Code of Regs, Figure 60310-A. These warning signs shall be posted at least every 500 feet with a minimum of a sign at each corner and access road.
- 2.** The Permittee shall maintain compliance with the following effluent limitations at Discharge Point 002, with compliance measured at Monitoring Location EFF-002 as described in the attached MRP.

Table 5. Reclamation Discharge Specifications – Discharge Point 002

Discharge Specifications - 002				
Parameter	Units	Average Monthly	Average Weekly	Maximum Daily
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	30	---	---
Total Suspended Solids	mg/L	30	---	---
Settleable Solids	mL/L-hr	0.1	---	0.2
Total Coliform Organisms	MPN/100 mL	23 ⁵	---	230

D. Other Requirements

1. Disinfection Process Requirements for Ultraviolet (UV) Disinfection System.

Upon completion and testing of the UV disinfection system, the Permittee shall operate the UV disinfection system in accordance with the following operating protocol in order to demonstrate compliance with Effluent Limitations contained in this Order.

- a. Disinfection of tertiary treated wastewater shall be accomplished using a disinfection process that, when combined with the filtration process, has been demonstrated to inactivate and/or remove 99.999 percent of the plaque-forming units of F-specific bacteriophage MS2, or polio virus in the wastewater. A virus that is at least as resistant to disinfection as polio virus may be used for purposes of the demonstration. A demonstration of system effectiveness shall be performed on-site at the Permittee’s WWTF at both maximum and minimum plant flows.
- b. The Permittee shall provide continuous, reliable monitoring of flow, UV transmittance, UV intensity, UV dose, UV power, and turbidity.
- c. The Permittee shall operate the UV disinfection system to provide a minimum UV dose of 100 millijoules per square centimeter (mJ/cm²) at all times, unless otherwise approved by the Executive Officer.
- d. The UV transmittance (at 254 nanometers) in the wastewater shall not fall below 55 percent of maximum at any time, unless otherwise approved by the Executive Officer.
- e. The quartz sleeves and cleaning system components shall be visually inspected per the manufacturer’s operation manual for physical wear (scoring, solarization, seal leaks, etc.) and to check the efficacy of the cleaning system.

- f. The quartz sleeves shall be cleaned at fixed intervals to ensure the minimum required UV dose delivery is consistently achieved. Cleaning intervals shall be established based on the presence of coliform organisms.
 - g. Lamps shall be replaced per the manufacturer's recommendation, or sooner, if there are indications the lamps are failing to provide adequate disinfection. Lamp age and lamp replacement records must be maintained onsite and made available for inspection by Regional Water Board staff upon request.
 - h. The UV disinfection system shall be operated in accordance with an operations and maintenance plan approved by the Regional Water Board Executive Officer.
2. **Storage Ponds.** Ponds used for wet weather influent equalization and/or storage of treated wastewater shall be constructed in a manner that protects groundwater. The Permittee shall submit design proposals for new wastewater storage ponds to the Regional Water Board for review prior to construction and demonstrate that the pond design incorporates features to protect groundwater from exceeding groundwater quality objectives.

V. RECEIVING WATER LIMITATIONS

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are required to be addressed as part of this Order. However, receiving water conditions not in conformance with the limitation are not necessarily a violation of this Order. Compliance with receiving water limitations shall be measured at monitoring locations described in the MRP (Attachment E). The Regional Water Board may require an investigation to determine cause and culpability prior to asserting a violation has occurred. Discharges from the Facility shall not cause the following in the receiving waters:

A. Surface Water Limitations

- 1. The discharge shall not cause the dissolved oxygen concentration of the receiving waters to be depressed below 7.0 mg/L. Additionally, the discharge shall not cause the dissolved oxygen content of the receiving water to fall below 10.0 mg/L more than 50 percent of the time, or below 7.5 mg/L more than 10 percent of the time. In the event that the receiving waters are determined to have dissolved oxygen concentration of less than 7.0 mg/L, the discharge shall not depress the dissolved oxygen concentration below the existing level.

2. The discharge shall not cause the specific conductance (micromhos⁵) concentration of the receiving waters to increase above 225 micromhos 50 percent of the time, or above 375 micromhos more than 10 percent of the time.
3. The discharge shall not cause the total dissolved solids concentration of the receiving waters to increase above 140 mg/l more than 50 percent of the time, or above 275 mg/l more than 10 percent of the time.
4. The discharge shall not cause the pH of the receiving waters to be depressed below 6.5 nor raised above 8.5. Within this range, the discharge shall not cause the pH of the receiving waters to be changed at any time more than 0.5 units from normal ambient pH levels. If the pH of the receiving water is less than 6.5, the discharge shall not cause a further depression of the pH of the receiving water. If the pH of the receiving water is greater than 8.5, the discharge shall not cause a further increase in the pH of the receiving water.
5. The discharge shall not cause turbidity of receiving waters to be increased more than 20 percent above naturally occurring background levels.
6. The discharge shall not cause receiving waters to contain floating materials, including solids, liquids, foams, and scum, in concentrations that cause nuisance or adversely affect beneficial uses.
7. The discharge shall not cause receiving waters to contain taste or odor producing substances in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, that cause nuisance, or` that adversely affect beneficial uses.
8. The discharge shall not cause coloration of receiving waters that causes nuisance or adversely affects beneficial uses.
9. The discharge shall not cause bottom deposits in receiving waters to the extent that such deposits cause nuisance or adversely affect beneficial uses.
10. The discharge shall not cause or contribute concentrations of biostimulants to the receiving water that promote objectionable aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
11. The discharge shall not cause receiving waters to contain toxic substances in concentrations that are toxic to, or that produce detrimental physiological

⁵ Measured at 77° F.

responses in humans, plants, animals, or aquatic life. Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, bioassays of appropriate duration, or other appropriate methods, as specified by the Regional Water Board.

12. The discharge shall not cause receiving water temperature to increase by more than 77° F above natural receiving water temperature at any time.
13. The discharge shall not cause an individual pesticide or combination of pesticides to be present in concentrations that adversely affect beneficial uses. The discharge must not cause bioaccumulation of pesticide, fungicide, wood treatment chemical, or other toxic pollutant concentrations in bottom sediments or aquatic life to levels which are harmful to human health.
14. The discharge shall not cause the receiving waters to contain concentrations of pesticides in excess of the limiting concentrations set forth in Table 3-2 of the Basin Plan. The discharge shall not cause the receiving waters to contain concentrations of pesticides in excess of the limiting concentrations established as Maximum Contaminant Levels by the Department of Health Services in title 22, Cal. Code of Regs, section 64444.
15. The discharge shall not cause receiving waters to contain oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water, that cause nuisance, or that otherwise affect beneficial uses.
16. The discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Regional Water Board or the State Water Board, as required by the federal Clean Water Act and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the Clean Water Act, or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.
17. The discharge shall not cause concentrations of chemical constituents to occur in excess of limits specified in Table 3-2 of the Basin Plan or in excess of more stringent Maximum Contaminant Levels (MCLs) established for these pollutants in title 22, Cal. Code of Regs. Division 4, Chapter 15, Articles 4 and 5.5.

B. Groundwater Limitations

The collection, storage, and use of wastewater or recycled water shall not cause or contribute to a statistically significant degradation of groundwater quality, cause

exceedance of applicable water quality objectives or create adverse impacts to beneficial uses of groundwater.

VI. PROVISIONS

A. Standard Provisions

- 1. Federal Standard Provisions.** The Permittee shall comply with all Standard Provisions included in Attachment D of this Order.
- 2. Regional Water Board Standard Provisions.** The Permittee shall comply with the following Regional Water Board standard provisions. In the event there is any conflict, duplication, or overlap between provisions specified by this Order, the more stringent provision shall apply.
 - a.** Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Permittee to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Permittee to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
 - b.** In the event the Permittee does not comply or will be unable to comply for any reason, with any prohibition, interim or final effluent limitation, land discharge specification, receiving water limitation, or provision of this Order that may result in a significant threat to human health or the environment, such as inundation of treatment components, breach of pond containment, sanitary sewer overflow, irrigation runoff, etc., that results in a discharge to a drainage channel or a surface water, the Permittee shall notify Regional Water Board staff within 24 hours and report orally and in writing to the Regional Water Board staff all unauthorized spills of waste. Spill notification and reporting shall be conducted in accordance with section X.E of the Monitoring and Reporting Program.

B. Monitoring and Reporting Program (MRP) Requirements

The Permittee shall comply with the MRP included as Attachment E to this Order, and future revisions thereto.

C. Special Provisions

1. Reopener Provisions

- a. Standard Revisions.** If applicable water quality standards are promulgated or approved pursuant to Section 303 of the CWA, or amendments thereto, the Regional Water Board may reopen this Order and make modifications in accordance with such revised standards.

- b. Reasonable Potential.** This Order may be reopened for modification to include an effluent limitation, if monitoring establishes that the discharge causes, or has the reasonable potential to cause or contribute to, an excursion above a water quality criterion or objective applicable to the receiving water.
- c. Whole Effluent Toxicity.** As a result of a Toxicity Reduction Evaluation (TRE), this Order may be reopened to include a chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a numeric chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a numeric chronic toxicity effluent limitation based on that objective.
- d. 303(d)-Listed Pollutants.** If an applicable total maximum daily load (TMDL) (see Fact Sheet section III.C) program is adopted, this Order may be reopened and effluent limitations for the pollutant(s) that are the subject of the TMDL will be modified or imposed to conform this Order to the TMDL requirements.
- e. Reclamation Requirements.** As part of its ROWD/permit application, the Permittee identified plans to construct a reclamation system for agricultural and urban reclamation. Sufficient information was not available to include reclamation requirements at the time the Regional Water Board adopted this Order. Upon submittal of the needed information by the Permittee, this Order may be reopened to incorporate reclamation requirements.
- f. Salt and Nutrient Management Plans.** The Recycled Water Policy adopted by the State Water Board on February 3, 2009 and effective May 14, 2009 recognizes the fact that some groundwater basins in the state contain salts and nutrients that exceed or threaten to exceed water quality objectives in the applicable Basin Plans, and that not all Basin Plans include adequate implementation procedures for achieving or ensuring compliance with the water quality objectives for salt or nutrients. The Recycled Water Policy finds that the appropriate way to address salt and nutrient issues is through the development of regional or subregional salt and nutrient management plans rather than through imposing requirements solely on individual recycled water projects. The Regional Water Board is developing a plan to address salt and nutrient management. This Order may be reopened to incorporate provisions consistent with any salt and nutrient management plan(s) adopted by the Regional Water Board.
- g. Nutrients.** This Order contains effluent limitations for ammonia and nitrate. If new water quality objectives for nutrients are established, or if monitoring data indicate the need for more stringent effluent limitations for these or other nutrient parameters, this Order may be reopened and modified to include new or modified effluent limitations, as necessary.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

a. Toxicity Reduction Requirements

- i. **Whole Effluent Toxicity.** In addition to a numeric limitation for whole effluent acute toxicity, the MRP of this Order requires routine monitoring for whole effluent chronic toxicity to determine compliance with the Basin Plan's narrative water quality objective for toxicity. As established by the MRP, if either of the effluent limitations for acute toxicity is exceeded (a single sample with less than 70% survival or a three sample median of less than 90% survival) or if the chronic toxicity monitoring trigger of either a single sample maximum of 1.6 chronic toxicity units (TUc) or a monthly median of 1.0 TUc (where TUc = 100/NOEC) is exceeded, the Permittee shall conduct accelerated monitoring as specified in section V. of the MRP.

Results of accelerated toxicity monitoring will indicate a need to conduct a toxicity reduction evaluation (TRE), if toxicity persists; or it will indicate that a return to routine toxicity monitoring is justified because persistent toxicity has not been identified by accelerated monitoring. TREs shall be conducted in accordance with the TRE workplan prepared by the Permittee pursuant to Section VI.C.2.a.ii of this Order, below.

- ii. **Toxicity Reduction Evaluation Workplan.** The Permittee submitted a TRE workplan to the Regional Water Board on May 7, 2007. This plan shall be reviewed at least once every 5 years and updated as necessary in order to remain current and applicable to the discharge and discharge facilities. The Permittee shall notify the Regional Water Board of this review and submit any revision of the TRE workplan with each Report of Waste Discharge.

The TRE workplan shall describe the steps the Permittee intends to follow if toxicity is detected, and should include at least the following items:

- (a). A description of the investigation and evaluation techniques that would be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
- (b). A description of the facility's methods of maximizing in-house treatment efficiency, good housekeeping practices, and a list of all chemicals used in the operation of this Facility.
- (c). If a toxicity identification evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor).

iii. Toxicity Reduction Evaluations (TRE) Implementation. The TRE shall be conducted in accordance with the following:

- (a). The TRE shall be initiated within 30 days of the date of completion of the accelerated monitoring testing, required by Sections V.A.7 and V.B.9 of the MRP, observed to exceed either the acute or chronic toxicity parameter.
- (b). The TRE shall be conducted in accordance with the Permittee's TRE workplan.
- (c). The TRE shall be in accordance with current technical guidance and reference material including, at a minimum, the USEPA manual EPA/833B 99/002.
- (d). The TRE may end at any stage if, through monitoring results, it is determined that there is no longer consistent toxicity. The Permittee shall notify the Regional Water Board of this determination.
- (e). The Permittee may initiate a TIE as part of the TRE process to identify the cause(s) of toxicity. TIEs shall be conducted in accordance with current technical guidance and reference material, including, at a minimum, the Permittee shall use the USEPA acute and chronic manuals, EPA/600/6-91/005F (Phase I), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III).
- (f). As toxic substances are identified or characterized, the Permittee shall continue the TRE by determining the source(s) and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with chronic toxicity parameters.
- (g). Many recommended TRE elements accompany required efforts of source control, pollution prevention, and storm water control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements of recommendations of such programs may be acceptable to comply with requirements of the TRE.
- (h). The Regional Water Board recognizes that chronic toxicity may be episodic and identification of a reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based in part on the Permittee's

actions and efforts to identify and control or reduce sources of consistent toxicity.

3. Best Management Practices and Pollution Prevention

a. Pollutant Minimization Program (PMP)

The Permittee shall, as required by the Executive Officer, develop and conduct a PMP as further described below when there is evidence (e.g., sample results reported as detected, but not quantified (DNQ) when the effluent limitation is less than the method detection limit (MDL), sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a priority pollutant is present in the effluent above an effluent limitation and either:

- i.** A sample result is reported as DNQ and the effluent limitation is less than the RL; or
 - ii.** A sample result is reported as ND and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in MRP section X.B.4.
- b.** The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:
- i.** An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
 - ii.** Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system;
 - iii.** Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
 - iv.** Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
 - v.** An annual status report that shall be submitted as part of the Annual Facility Report due March 1st to the Regional Water Board and shall include:
 - (a)** All PMP monitoring results for the previous year;
 - (b)** A list of potential sources of the reportable priority pollutant(s);

- (c) A summary of all actions undertaken pursuant to the control strategy;
and
- (d) A description of actions to be taken in the following year.

4. Construction, Operation and Maintenance Specifications

- a.** The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the Permittee to achieve compliance with this Order. Proper operation and maintenance includes adequate laboratory quality control and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by the Permittee only when necessary to achieve compliance with the conditions of this Order.
- b.** The Permittee shall maintain an updated Operation and Maintenance (O&M) Manual for the Facility. The Permittee shall update the O&M Manual, as necessary, to conform to changes in operation and maintenance of the Facility. The O&M Manual shall be readily available to operating personnel onsite and for review by state or federal inspectors. The O&M Manual shall include the following.
 - i.** Description of the Facility's organizational structure showing the number of employees, duties and qualifications and plant attendance schedules (daily, weekends and holidays, part-time, etc.). The description should include documentation that the personnel are knowledgeable and qualified to operate the treatment facility so as to achieve the required level of treatment at all times.
 - ii.** Detailed description of safe and effective operation and maintenance of treatment processes, process control instrumentation and equipment.
 - iii.** Description of laboratory and quality assurance procedures.
 - iv.** Process and equipment inspection and maintenance schedules.
 - v.** Description of safeguards to assure that, should there be reduction, loss, or failure of electric power, the Permittee will be able to comply with requirements of this Order.
 - vi.** Description of preventive (fail-safe) and contingency (response and cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. These plans shall identify the possible sources (such as loading and storage areas, power outage, waste treatment unit failure, process equipment failure, tank and piping failure) of accidental discharges, untreated or partially treated waste bypass, and polluted drainage.

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Wastewater Collection Systems

i. Statewide General WDRs for Sanitary Sewer Systems

The Permittee shall maintain coverage under, and shall be subject to the requirements of Order Nos. 2006-0003-DWQ and WQ-2008-0002-EXEC and any future revisions thereto for operation of its wastewater collection system. The Statewide General WDRs for Sanitary Sewer Systems are further described in section VII.B.5.a of the Fact Sheet.

In addition to the coverage obtained under Order No. 2006-0003, the Permittee's collection system is part of the treatment system that is subject to this Order. As such, pursuant to federal regulations at section 122.44, title 40 of the Code of Federal Regulations (40 CFR), the Permittee must properly operate and maintain its collection system (40 CFR 122.41(e)), report any non-compliance (40 CFR 122.41(l)(6) and (7)), and mitigate any discharge from the collection system in violation of this Order (40 CFR 122.41(d)).

ii. Spills and Sanitary Sewer Overflows

- (a) The Permittee shall take all feasible steps to stop spills and sanitary sewer overflows (SSOs) as soon as possible. All reasonable steps should be taken to collect spilled material and protect the public from contact with wastes or waste-contaminated soil or surfaces.
- (b) The Permittee shall report orally⁶ and in writing to the Regional Water Board staff all SSOs and unauthorized spills of waste. Spill notification and reporting shall be conducted in accordance with section X.E of the Monitoring and Reporting Program.

b. Source Control and Pretreatment Provisions

The Permittee shall perform source control functions and provide a summary of source control activities conducted in the Annual Facility Report (due March 1st to the Regional Water Board). Source control functions and requirements shall include the following:

- i.** Implement the necessary legal authorities to monitor and enforce source control standards, restrict discharges of toxic materials to the collection system and inspect facilities connected to the system.

⁶ Oral reporting means direct contact with a Regional Water Board staff person. The oral report may be given in person or by telephone. After business hours, oral contact must be made by calling the California Emergency Management Agency at (800) 852-7550 or the Regional Water Board spill officer at (707) 576-2220.

ii. If waste haulers are allowed to discharge to the Facility, establish a waste hauler permit system, to be reviewed by the Executive Officer, to regulate waste haulers discharging to the collection system or Facility.

iii. Industrial Waste Survey

- (a). The Permittee shall conduct an industrial waste survey (IWS) of all the industrial users (IUs) in the service area of the Facility to determine whether any IUs are subject to pretreatment standards specified in 40 CFR Part 403. The Permittee shall also perform a priority pollutant scan⁷ of the influent to the Facility. At a minimum, the IWS must identify the following for each industrial user and zero-discharging categorical industrial user: whether it qualifies as a significant user; the average and peak flow rates; the SIC code; any pretreatment being implemented by each industrial user; and whether or not the Permittee has issued a permit to any of the identified industrial users. The IWS and priority pollutant monitoring is required during the 12-month period that begins on July 1, 2013.
- (b). The results of the IWS and priority pollutant monitoring shall be submitted to the Regional Water Board in a written report no later than October 1, 2014. The written report shall include a certification report indicating whether the Facility receives pollutants from any IU that would require the Permittee to establish a pretreatment program in accordance with 40 CFR Part 403.
- (c). If, at any time, the Permittee becomes aware of an IU in the service area of the Facility that would require development of a pretreatment program pursuant to 40 CFR Part 403, then:
- (1) The Permittee shall notify the Regional Water Board within 30 days after there are discharges that trigger the pretreatment requirements.
 - (2) The Permittee shall submit a revised Report of Waste Discharge and the pretreatment program for the Regional Water Board's review and approval as soon as possible but not more than 1 year after the

⁷ The priority pollutant scan shall include CTR and title 22 pollutants. CTR pollutants are those pollutants identified in the California Toxics Rule at 40 CFR 131.38, and title 22 pollutants are those pollutants for which the California Department of Public Health has established Maximum Contaminant Levels (MCLs) at title 22, division 4, chapter 15, article 5.5, sections 64431 (Inorganic Chemicals) and 64444 (Organic Chemicals) of the California Code of Regulations. Duplicate analyses are not required for pollutants that are identified as CTR and title 22 pollutants.

Permittee's notification to the Regional Water Board of the need for pretreatment requirements. The Permittee shall require all Categorical Industrial Users (CIUs) in the service area of the Facility to comply with the federal categorical pretreatment standards.

(3) The Permittee shall notify the CIU(s) of its discharge effluent limits. The limits must be as stringent as the pretreatment standards contained in the applicable federal category (40 CFR Part 400-699). The Permittee may develop more stringent, technology-based local limits if it can show cause.

(4) The Permittee shall notify the Regional Water Board if any CIU in the service area of the Facility violates its discharge effluent limits.

- i. Perform public outreach to educate industrial, commercial, and residential users about the importance of preventing discharges of industrial and toxic wastes to the wastewater treatment plant.
- ii. Perform ongoing inspections and monitoring, as necessary, to ensure adequate source control.
- iii. The Regional Water Board retains the right to take legal action against an industrial user and/or the Permittee where a user fails to meet the approved applicable federal, state, or local pretreatment.
- iv. The Regional Water Board may amend this Order, at any time, to require the Permittee to develop and implement an industrial pretreatment program pursuant to the requirements of 40 CFR Part 403 if the Regional Water Board finds that the Facility receives pollutants from an IU that is subject to pretreatment standards, or if other circumstances so warrant.

c. Sludge Disposal and Handling Requirements

- i. Sludge, as used in this Order, means the solid, semisolid, and liquid residues removed during primary, secondary, or advanced wastewater treatment processes. Solid waste refers to grit and screenings generated during preliminary treatment. Biosolids refers to sludge that has been treated, tested, and demonstrated to be capable of being beneficially and legally used pursuant to federal and state regulations as a soil amendment for agriculture, silviculture, horticulture, and land reclamation activities.
- ii. All collected sludges and other solid waste removed from liquid wastes shall be removed from screens, sumps, ponds, and tanks as needed to ensure optimal plant operation and disposed of in accordance with applicable federal and State regulations.

- iii.** The use and disposal of biosolids shall comply with all of the land application and disposal requirements in 40 CFR 503, which are enforceable by the USEPA, not the Regional Water Board. If during the life of this Order, the State accepts primacy for implementation of 40 CFR 503, the Regional Water Board may also initiate enforcement where appropriate.
- iv.** Sludge or biosolids that are disposed of in a municipal solid waste landfill or used as daily landfill cover shall meet the applicable requirements of 40 CFR 258. In the annual self-monitoring report, the Permittee shall report the amount of sludge placed in a landfill and the landfill(s) which received the sludge or biosolids.
- v.** The beneficial use of biosolids by application to land as soil amendment is not covered or authorized by this Order. Biosolids that are applied to land as soil amendment by the Permittee within the North Coast Region shall comply with State Water Board Water Quality Order No. 2004-12-DWQ (General Waste Discharge Requirements for the Discharge of Biosolids to Land as a Soil Amendment in Agricultural, Silvicultural, Horticultural, and Land Reclamation Activities) or other permits issued by the Regional Water Board.
- vi.** The Permittee shall take all reasonable steps to prevent and minimize any sludge use or disposal in violation of this Order that may adversely affect human health or the environment.
- vii.** Solids and sludge treatment, storage, and disposal or reuse shall not create a nuisance, such as objectionable odors or flies, and shall not result in groundwater contamination.
- viii.** Solids and sludge treatment and storage sites shall have facilities adequate to divert surface water runoff from adjacent areas, to protect the boundaries of the site from erosion, and to prevent drainage from the treatment and storage site. Adequate protection is defined as protection from at least a 100-year storm.
- ix.** The discharge of sewage sludge and solids shall not cause waste material to be in a position where it is, or can be, conveyed from the treatment and storage sites and deposited in the waters of the State.

d. Discharge of Biosolids

For the discharge of biosolids from the Facility, the Permittee shall comply with the following requirements:

- i.** Statewide General WDRs for Discharge of Biosolids to Land

If applicable, the Permittee shall obtain authorization to discharge under and meet the requirements of the State Water Board Water Quality Order No.

2004-0012-DWQ General Waste Discharge Requirements for the Discharge of Biosolids to Land or Use as a Soil Amendment in Agricultural, Silvicultural, Horticultural, and Land Reclamation Activities. For existing discharges of biosolids to land, the Permittee shall submit a Notice of Intent to Comply within 180 days of the effective date of this Order. For future discharges of biosolids to land, the Permittee shall submit a Notice of Intent to Comply in accordance with the enrollment requirements of Order No. 2004-0012-DWQ; or

- ii. Alternatively, the Permittee may dispose of biosolids at another appropriately permitted facility.
- iii. New sludge treatment and storage facilities must comply with the Water Code and title 27 of the CCR requirements for the protection of water quality.

e. Operator Certification

Supervisors and operators of municipal wastewater treatment facilities (WWTFs) shall possess a certificate of appropriate grade in accordance with title 23, CCR, section 3680. The State Water Board may accept experience in lieu of qualification training. In lieu of a properly certified WWTF operator, the State Water Board may approve use of a water treatment facility operator of appropriate grade certified by the California Department of Public Health (CDPH) where water reclamation is involved.

f. Adequate Capacity

If the Facility or effluent disposal areas will reach capacity within 4 years, the Permittee shall notify the Regional Water Board. A copy of such notification shall be sent to appropriate local elected officials, local permitting agencies, and the press. Factors to be evaluated in assessing reserve capacity shall include, at a minimum, (1) comparison of the wet weather design flow with the highest daily flow, and (2) comparison of the average dry weather design flow with the lowest 30-day flow. The Permittee shall demonstrate that adequate steps are being taken to address the capacity problem. The Permittee shall submit a technical report to the Regional Water Board showing how flow volumes will be prevented from exceeding capacity, or how capacity will be increased, within 120 days after providing notification to the Regional Water Board, or within 120 days after receipt of Regional Water Board notification, that the Facility will reach capacity within four years. The time for filing the required technical report may be extended by the Regional Water Board. An extension of 30 days may be granted by the Executive Officer, and longer extensions may be granted by the Regional Water Board itself. [CCR title 23, section 2232]

6. Other Special Provisions

- a. **Storm Water Best Management Practices (BMPs).** BMPs to control storm water at the Facility shall be developed and upgraded, as necessary. In each annual report submitted to the Regional Water Board, the Permittee shall describe the effectiveness of these storm water BMPs as well as activities to maintain and upgrade these BMPs during the previous year.

7. Compliance Schedules

This section is not applicable to the Permittee.

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. General

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data

When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

C. Average Monthly Effluent Limitation (AMEL)

If the average (or when applicable, the median determined by subsection B above for multiple sample data) of daily discharges over a calendar month exceeds the AMEL for a given parameter, this will represent a single violation, though the Discharger will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the Discharger will be considered out of compliance for that calendar month. The Discharger will only be considered out of compliance for days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month.

D. Average Weekly Effluent Limitation (AWEL)

If the average (or when applicable, the median determined by subsection B above for multiple sample data) of daily discharges over a calendar week exceeds the AWEL for a given parameter, this will represent a single violation, though the Discharger will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of non-compliance. If only a single sample is taken during the calendar week and the analytical result for that sample exceeds the AWEL, the Discharger will be considered out of compliance for that calendar week. The Discharger will only be considered out of compliance for days when the discharge occurs. For any one calendar week during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar week.

E. Maximum Daily Effluent Limitation (MDEL)

If a daily discharge (or when applicable, the median determined by subsection B above for multiple sample data of a daily discharge) exceeds the MDEL for a given parameter, the Discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day.

F. Instantaneous Minimum Effluent Limitation

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, the Discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

G. Instantaneous Maximum Effluent Limitation

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, the Discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ): also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean = $\mu = \Sigma x / n$ where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative Pollutants: substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic Pollutants: substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV): a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass; or (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ): sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit: the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effective Concentration (EC): a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC25 is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.

Effluent Concentration Allowance (ECA): a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays: indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration: the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries: waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inhibition Concentration (IC): the IC25 is typically calculated as a percentage of effluent. It is the level at which the organisms exhibit 25 percent reduction in biological measurement such as reproduction or growth. It is calculated statistically and used in chronic toxicity testing.

Inland Surface Waters: all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL): the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median: the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL): the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML): the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone: a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND): those sample results less than the laboratory's MDL.

Ocean Waters: the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent Pollutants: substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP): waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to

reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention: any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Publicly Owned Treatment Works (POTW): a treatment works as defined in section 212 of the Clean Water Act (CWA), which is owned by a State or municipality as defined by section 502(4) of the CWA. [Section 502(4) of the CWA defines a municipality as a city, town, borough, county, parish, district, association, or other public body created by or pursuant to State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes). This definition includes any devices and systems used in the storage, treatment, recycling, and reclamation of municipal sewage or industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality as defined in section 502(4) of the Clean Water Act, which has jurisdiction over the Indirect Discharges to and the discharges from such a treatment works.

Reporting Level (RL): the ML (and its associated analytical method) used for reporting and compliance determination. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System: the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water: any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ): a measure of variability that is calculated as follows:

$$\sigma = \left(\frac{\sum[(x - \mu)^2]}{(n - 1)} \right)^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE): a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B - CITY OF FERNDALE MAP OF WASTEWATER TREATMENT FACILITY



ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Permittee must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR § 122.41(a).)
2. The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR § 122.41(c).)

C. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR. § 122.41(d).)

D. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Permittee only when necessary to achieve compliance with the conditions of this Order. (40 CFR § 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR § 122.5(c).)

F. Inspection and Entry

The Permittee shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR § 122.41(i); Water Code, § 13383):

1. Enter upon the Permittee 's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 CFR § 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR § 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR § 122.41(m)(1)(ii).)

- 2. Bypass not exceeding limitations.** The Permittee may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR § 122.41(m)(2).)
- 3. Prohibition of bypass.** Bypass is prohibited, and the Regional Water Board may take enforcement action against a Permittee for bypass, unless (40 CFR § 122.41(m)(4)(i)):

 - a.** Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR § 122.41(m)(4)(i)(A));
 - b.** There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR § 122.41(m)(4)(i)(B)); and
 - c.** The Permittee submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.6 below. (40 CFR § 122.41(m)(4)(i)(C).)
- 4. Burden of Proof.** In any enforcement proceeding, the Permittee seeking to establish the bypass defense has the burden of proof.
- 5. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR § 122.41(m)(4)(ii).)**
- 6. Notice**

 - a. Anticipated bypass.** If the Permittee knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR § 122.41(m)(3)(i).)
 - b. Unanticipated bypass.** The Permittee shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR § 122.41(n)(1).)

- 1.** Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR § 122.41(n)(2).)
- 2.** Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR § 122.41(n)(3)):
 - a.** An upset occurred and that the Permittee can identify the cause(s) of the upset (40 CFR § 122.41(n)(3)(i));
 - b.** The permitted facility was, at the time, being properly operated (40 CFR § 122.41(n)(3)(ii));
 - c.** The Permittee submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR § 122.41(n)(3)(iii)); and
 - d.** The Permittee complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR § 122.41(n)(3)(iv).)
- 3.** Burden of proof. In any enforcement proceeding, the Permittee seeking to establish the occurrence of an upset has the burden of proof. (40 CFR § 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR § 122.41(f).)

B. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this Order after the expiration date of this Order, the Permittee must apply for and obtain a new permit. (40 CFR § 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Permittee and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 CFR § 122.41(l)(3); § 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR § 122.41(j)(1).)
- B.** Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 CFR § 122.41(j)(4); § 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order related to the Permittee 's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 CFR § 122.41(j)(2).)
- B. Records of monitoring information shall include:**
 - 1.** The date, exact place, and time of sampling or measurements (40 CFR § 122.41(j)(3)(i));
 - 2.** The individual(s) who performed the sampling or measurements (40 CFR § 122.41(j)(3)(ii));
 - 3.** The date(s) analyses were performed (40 CFR § 122.41(j)(3)(iii));

4. The individual(s) who performed the analyses (40 CFR § 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR § 122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR § 122.41(j)(3)(vi).)

C. Claims of confidentiality for the following information will be denied (40 CFR § 122.7(b)):

1. The name and address of any permit applicant or Permittee (40 CFR § 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 CFR § 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Permittee shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Permittee shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR § 122.41(h); Water Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR § 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR § 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR § 122.22(c).)
 5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR § 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR § 122.41(l)(4)(i).)

3. If the Permittee monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 CFR § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Permittee shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR § 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR § 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(B).)
 - c. Violation of a maximum daily discharge limitation for any of the pollutants listed in this Order to be reported within 24 hours [40 CFR § 122.41(l)(6)(ii)(C)]
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR § 122.41(l)(6)(iii).)

F. Planned Changes

The Permittee shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as defined in section 122.29(b) (40 CFR § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 CFR § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR § 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Permittee shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 CFR § 122.41(l)(2).)

H. Other Noncompliance

The Permittee shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR § 122.41(l)(7).)

I. Other Information

When the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Permittee shall promptly submit such facts or information. (40 CFR § 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR § 122.42(b)):

- 1.** Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR § 122.42(b)(1)); and
- 2.** Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR § 122.42(b)(2).)
- 3.** Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR § 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM NO. R1-2012-0097

Table of Contents

I. GENERAL MONITORING PROVISIONS.....E-2

II. MONITORING LOCATIONS.....E-3

III. INFLUENT MONITORING REQUIREMENTS.....E-3

 A. Monitoring Location M-INF.....E-3

IV. EFFLUENT MONITORING REQUIREMENTSE-4

 A. Monitoring Location EFF-001E-4

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTSE-5

 A. Acute Toxicity Testing.....E-5

 B. Chronic Toxicity Testing.....E-7

 C. Chronic Toxicity Reporting.....E-9

VI. LAND DISCHARGE MONITORING REQUIREMENTSE-10

VII. RECLAMATION MONITORING REQUIREMENTSE-10

 A. Monitoring Location EFF-002E-10

VIII. RECEIVING WATER MONITORING REQUIREMENTS.....E-11

 A. Monitoring Location R-001E-11

 B. Monitoring Location R-002E-12

 C. Monitoring Location R-003E-12

IX. OTHER MONITORING REQUIREMENTS.....E-13

 A. Rainfall.....E-13

 B. Monitoring Location M-UV - UV Disinfection System MonitoringE-13

X. REPORTING REQUIREMENTSE-13

 A. General Monitoring and Reporting Requirements.....E-13

 B. Self-Monitoring Reports (SMRs)E-14

 C. Discharge Monitoring Reports (DMRs)E-16

 D. Other Reports.....E-17

 E. Spills and Overflows Notification.....E-19

List of Tables

Table E-1. Test Methods and MLs for Priority Pollutants.....E-2

Table E-2. Monitoring Station Locations.....E-3

Table E-3. Influent Monitoring - Monitoring Location M-INFE-4

Table E-4. Effluent Monitoring - Monitoring Location EFF-001.....E-4

Table E-5. Effluent Monitoring - Monitoring Location EFF-002.....E-10

Table E-6. Receiving Water Monitoring Requirements – R-001E-11

Table E-7. Receiving Water Monitoring Requirements – R-002E-12

Table E-8. Receiving Water Monitoring Requirements – R-003E-12

Table E-9. Monitoring Periods and Reporting Schedule.....E-14

Attachment E – Monitoring and Reporting Program (MRP)

The Code of Federal Regulations (CFR) at 40 CFR 122.48 requires that all National Pollutant Discharge Elimination System (NPDES) permits specify monitoring and reporting requirements. California Water Code (Water Code) sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This Monitoring and Reporting Program (MRP) establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A.** Wastewater Monitoring Provision. Composite samples may be taken by a proportional sampling device approved by the Executive Officer or by grab samples composited in proportion to flow. In compositing grab samples, the sampling interval shall not exceed one hour.
- B.** If the Permittee monitors any pollutant more frequently than required by this Order, using test procedures approved by 40 CFR Part 136 or as specified in this Order, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the monthly and annual discharge monitoring reports.
- C.** Laboratories analyzing monitoring samples shall be certified by the California Department of Public Health (CDPH) in accordance with the provisions of Water Code section 13176, and must include quality assurance / quality control data with their analytical reports.
- D.** Compliance and reasonable potential monitoring analyses shall be conducted using commercially available and reasonably achievable detection limits that are lower than the applicable effluent limitation. If no Minimum Level (ML) value is below the effluent limitations, the lowest ML shall be selected as the Reporting Level (RL). Table E-1 lists the test methods the Permittee may use for compliance and reasonable potential monitoring to analyze priority pollutants with specific monitoring requirements and effluent limitations. The required ML for all priority pollutants can be found in appendix 4 of the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*.

Table E-1. Test Methods and MLs for Priority Pollutants

CTR#	Constituent	Types of Analytical Methods MLs (µg/L)	
		Cold Vapor Atomic Absorption (CVAA)	Gas Chromatography (GC)
8	Mercury	0.2	---
16	2,3,7,8-TCDD	The Permittee shall use USEPA Method 1613 and achieve MLs equal to ½ the MLs specified in Table 2 of USEPA Method 1613 ¹	

Table E-1. Test Methods and MLs for Priority Pollutants

CTR#	Constituent	Types of Analytical Methods MLs (µg/L)	
		Cold Vapor Atomic Absorption (CVAA)	Gas Chromatography (GC)
103	Alpha-BHC	---	0.02
118	Heptachlor Epoxide	---	0.01

II. MONITORING LOCATIONS

The Permittee shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-2. Monitoring Station Locations

Discharge Point	Monitoring Location	Monitoring Location Description
Influent	M-INF	Untreated influent wastewater at the plant's headworks
001	EFF-001	Treated effluent downstream of disinfection processes and before contact with receiving water
002	EFF-002	Treated effluent downstream of the disinfection processes and before effluent application to reclamation use area(s)
Receiving Water	R-001	Francis Creek/Salt River surface water upstream of Discharge Point 001, beyond influence of the discharge
Receiving Water	R-002	Francis Creek/Salt River surface water at the point of discharge or other location approved by the Executive Officer
Receiving Water	R-003	Salt River surface water ½ mile downstream of Discharge Point 001, or other location approved by the Executive Officer

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location M-INF

1. The Permittee shall monitor influent to the wastewater treatment plant at Monitoring Location M-INF as follows:

Table E-3. Influent Monitoring - Monitoring Location M-INF

Parameter	Units	Sample Type	Sampling Frequency	Required Analytical Method ¹
Flow (Mean)	mgd	Continuous	Daily	Meter
Biochemical Oxygen Demand 5-day @ 20°C ²	mg/L	8-hr Composite	Weekly	Standard Method 5210B
Total Suspended Solids ²	mg/L	8-hr Composite	Weekly	Standard Method 2540D

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

When discharging at Discharge Point 001, the Permittee shall monitor treated wastewater at Monitoring Location EFF-001 as follows.

Table E-4. Effluent Monitoring - Monitoring Location EFF-001

Parameter	Units	Sample Type	Sampling Frequency	Required Analytical Test Method ¹
Flow ³	mgd	Continuous	Daily	Meter
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	8-hr Composite	Weekly	Standard Method 5210B
Total Suspended Solids	mg/L	8-hr Composite	Weekly	Standard Method 2540D
Settleable Solids	mL/L-hr.	8-hr Composite	Weekly	Standard Method 2540F
pH ⁴	s.u.	Grab	Weekly	title 40, section 136
Temperature ⁴	°F	Grab	Monthly	title 40, section 136
Total Coliform Organisms	MPN/100 mL	Grab	Weekly	Standard Method 9221
Ammonia Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Nitrate Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Total Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Total Phosphorous	mg/L P	Grab	Monthly	title 40, section 136
Total Dissolved Solids	mg/L	Grab	Monthly	Standard Method 2540C
Acute Toxicity	TUa	24-hr Composite	2X/year ⁵	MRP section V
Chronic Toxicity	TUc	24-hr Composite	2X/year ⁶	MRP section V

¹ In accordance with the current edition of *Standard Methods for the Examination of Water and Wastewater* (American Public Health Administration) or current test procedures specified in title 40, section 136
² Monitoring of BOD₅ and TSS in influent shall occur near simultaneously with effluent monitoring for the same parameters
³ On a monthly basis, the Discharger shall report average and maximum daily flows
⁴ pH and temperature monitoring must coincide with monthly monitoring for ammonia
⁵ Monitoring shall occur during the first month of surface water discharge and during the second consecutive month thereafter (ie. If monitoring occurs in November, consecutive monitoring shall be performed in January)

Table E-4. Effluent Monitoring - Monitoring Location EFF-001

Parameter	Units	Sample Type	Sampling Frequency	Required Analytical Test Method ¹
Mercury	µg/L	Grab	Monthly	Cold Vapor Atomic Absorption
2,3,7,8-TCDD	µg/L	Grab	2X/year	EPA Method 1613
Alpha-BHC	µg/L	Grab	Monthly	Gas Chromatography
Heptachlor Epoxide	µg/L	Grab	Monthly	Gas Chromatography
CTR Pollutants	µg/L	Grab	2X/Permit Term	Standard Methods ³

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity Testing

The Permittee shall conduct whole effluent toxicity (WET) testing to determine compliance with the acute toxicity effluent limitations established in the Order. The Permittee shall meet the following acute toxicity testing requirements:

- 1. Test Frequency.** The Permittee shall conduct acute WET testing in accordance with the schedule established by this MRP, as summarized in Table E-4, above, when discharging to surface water.
- 2. Sample Type.** For 96-hour static renewal or 96-hour static non-renewal testing, the samples shall be a 24-hour composite samples and shall be representative of the volume and quality of the discharge. Effluent samples shall be collected at Monitoring Location EFF-001.
- 3. Test Species.** Test species for acute testing shall be an invertebrate, the water flea, *Ceriodaphnia dubia*, and a vertebrate, the rainbow trout, *Oncorhynchus mykiss*, for at least the first two suites of tests conducted within 12 months after the effective date of the Order. After this screening period, monitoring shall be conducted using the most sensitive species. At least one time every five years, the Permittee shall re-screen with the two species described above and continue routine monitoring with the most sensitive species.
- 4. Test Methods.** The presence of acute toxicity shall be estimated as specified in Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to

⁶ Monitoring shall occur during the second month of surface water discharge and during the second consecutive month thereafter (i.e. If monitoring occurs in December, consecutive monitoring shall be performed in February)

Freshwater and Marine Organisms (USEPA Report No. EPA-821-R-02-012, 5th edition or subsequent editions), or other methods approved by the Executive Officer.

- 5. Test procedures related to pH control.** Sample filtration, aeration, temperature control and sample dechlorination shall be performed in accordance with the USEPA method and fully explained and justified in each acute toxicity report submitted to the Regional Water Board. Control of the pH in acute toxicity tests is allowed, provided the test pH is maintained at the measured effluent pH, and the control of pH is done in a manner that has the least influence on the test water chemistry and on the toxicity of other pH sensitive materials such as some heavy metals, sulfide and cyanide.
- 6. Test Dilutions.** The acute toxicity test shall be conducted using 100 percent effluent collected at Monitoring Location EFF-001, when discharging to surface water.
- 7. Test Failure.** If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Permittee shall re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.
- 8. Accelerated Monitoring.** If the result of any acute toxicity test fails to meet the single test minimum limitation established in sections IV. A. 1. e and IV.B.1.e of the Order (70 percent survival), and the testing meets all test acceptability criteria, the Permittee shall take two more samples, one within 14 days, and one within 21 days of receiving the initial sample result. If any of the additional samples do not comply with the three sample median minimum limitation (90 percent survival), the Permittee shall initiate a Toxicity Reduction Evaluation (TRE) in accordance with section VI. C. 2. a. of the Order. If the two additional samples are in compliance with the acute toxicity requirement, and the testing meets all test acceptability criteria, then a TRE will not be required. If the discharge has ceased before the additional samples could be collected, the Permittee shall contact the Executive Officer within 21 days with a plan to demonstrate compliance with the acute toxicity effluent limitation.
- 9. Notification.** The Permittee shall notify the Regional Water Board in writing 14 days after the receipt of test results exceeding an effluent limitation or trigger. The notification will describe actions the Permittee has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any actions required by this Order, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.
- 10. Reporting.** Test results for acute toxicity tests shall be reported according to section 12 (Report Preparation) of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms or in an equivalent format that

clearly demonstrates that the Permittee is in compliance with effluent limitations, and other permit requirements.

11. Ammonia Toxicity. The acute toxicity test shall be conducted without modifications to eliminate ammonia toxicity.

B. Chronic Toxicity Testing

The Permittee shall conduct chronic whole effluent toxicity (WET) testing to demonstrate compliance with the Basin Plan's narrative water quality objective for toxicity. The Permittee shall meet the following chronic toxicity testing requirements:

- 1. Test Frequency.** The Permittee shall conduct chronic WET testing in accordance with the schedule established by this MRP, as summarized in Table E-3, above, when discharging to surface water.
- 2. Sample Type.** For 96-hour static renewal or 96-hour static non-renewal testing, the samples shall be 24-hour composite samples and shall be representative of the volume and quality of the discharge. The effluent sample shall be collected at Monitoring Location EFF-001.
- 3. Test Species.** Test species for chronic testing shall be a vertebrate, the fathead minnow, *Pimephales promelas* (larval survival and growth test); an invertebrate, the water flea, *Ceriodaphnia dubia* (survival and reproduction test); and a plant, the green alga, *Selenastrum capricornutum* (growth test).
- 4. Test Methods.** The presence of chronic toxicity shall be estimated as specified in USEPA's Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms (USEPA Report No. EPA-821-R-02-013, 4th or subsequent editions).
- 5. Test procedures related to pH control,** sample filtration, aeration, temperature control and sample dechlorination shall be performed in accordance with the USEPA method and fully explained and justified in each chronic toxicity report submitted to the Regional Water Board. Control of the pH in chronic toxicity tests is allowed, provided the test pH is maintained at the measured pH of the downstream receiving water, and the control of pH is done in a manner that has the least influence on the test water chemistry and on the toxicity of other pH sensitive materials such as some heavy metals, sulfide and cyanide.
- 6. Test Dilutions.** The chronic toxicity test shall be conducted using a series of at least five dilutions and a control. The series shall consist of the following dilution series: 12.5, 25, 50, 75, and 100 percent effluent. Control and dilution water should be

receiving water at an appropriate location upstream of the discharge point. Laboratory water may be substituted for receiving water, as described in the manual, upon approval by the Regional Water Board Executive Officer. Specifically, for the *Selenastrum capricornutum* test, synthetic laboratory water with a hardness similar to the receiving water shall be used as the control and dilution water. If the dilution water used is different from the culture water, a second control using culture water shall be used.

- 7. Reference Toxicant.** If organisms are not cultured in-house, concurrent testing with a reference toxicant shall be conducted. Where organisms are cultured in-house, monthly reference toxicant testing is sufficient. Reference toxicant tests also shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
- 8. Test Failure.** If either the reference toxicant test or the chronic toxicity test does not meet all test acceptability criteria, as specified in the test method, the Permittee shall re-sample and re-test as soon as possible, not to exceed 14 days following notification of test failure.
- 9. Notification.** The Permittee shall notify the Regional Water Board in writing within 14 days after the receipt of test results that indicate an exceedance of the monitoring trigger for chronic toxicity during regular or accelerated monitoring.
- 10. Accelerated Monitoring Requirements.** If the result of any chronic toxicity test exceeds a chronic toxicity trigger of 1.0 TUC, and the testing meets all test acceptability criteria, the Permittee shall initiate accelerated monitoring. Accelerated monitoring shall consist of four additional effluent samples, one test conducted approximately every week, over a four-week period. Testing shall commence within 14 days of receipt of the sample results of the exceedance of the chronic toxicity trigger. If the discharge will cease before the additional samples can be collected, the Permittee shall contact the Executive Officer within 21 days with a plan to demonstrate compliance with the chronic toxicity effluent limitation. The following protocol shall be used for accelerated monitoring and TRE implementation.
 - a.** If the results of four consecutive accelerated monitoring tests do not exceed the effluent limitation, the Permittee may cease accelerated monitoring and resume regular chronic toxicity monitoring. If there is adequate evidence of a pattern of effluent toxicity, however, the Regional Water Board Executive Officer may require that the Permittee initiate a TRE.
 - b.** If the source(s) of the toxicity is easily identified (i.e. temporary plant upset), the Permittee shall make necessary corrections to the facility and shall continue accelerated monitoring until four consecutive accelerated tests do not exceed the

effluent limitation. Upon confirmation that the effluent toxicity has been removed, the Permittee may cease accelerated monitoring and resume regular chronic toxicity monitoring.

- c. If the result of any accelerated toxicity test exceeds an effluent limitation or trigger, the Permittee shall cease accelerated monitoring and initiate a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of the test results exceeding the effluent limitation during accelerated monitoring, the Permittee shall submit a TRE Action Plan to the Regional Water Board including, at minimum:
 - (1.) Specific actions the Permittee took to investigate and identify the cause(s) of toxicity, including a TRE WET monitoring schedule;
 - (2.) Specific actions the Permittee took to mitigate the impact of the discharge and prevent the recurrence of toxicity;
 - (3.) Recommendations for further actions to mitigate continued toxicity, if needed; and
 - (4.) A schedule for implementation of recommended actions.

11. Ammonia Toxicity. The chronic toxicity test shall be conducted without modifications to eliminate ammonia toxicity.

C. Chronic Toxicity Reporting

1. **Routine Reporting.** Test results for chronic tests shall be reported according to the acute and chronic manuals and the Monitoring and Reporting Program and shall be attached to the corresponding monthly self-monitoring report. Test results shall include, at a minimum, for each test:
 - a. sample date(s)
 - b. test initiation date
 - c. test species
 - d. end point values for each dilution (e.g., number of young, growth rate, percent survival)
 - e. NOEC value(s) in percent effluent
 - f. IC15, IC25, IC40, and IC50 values (or EC15, EC25...etc.) in percent effluent
 - g. TUC values (100/NOEC)
 - h. Mean percent mortality (\pm s.d.) after 96 hours in 100 percent effluent (if applicable)
 - i. NOEC and LOEC values for reference toxicant test(s)
 - j. IC50 or EC50 value(s) for reference toxicant test(s)
 - k. Available water quality measurements for each test (e.g., pH, DO, temperature, conductivity, hardness, salinity, ammonia)
 - l. Statistical methods used to calculate endpoints.

m. The statistical output page, which includes the calculation of percent minimum significant difference (PMSD)

2. **Quality Assurance Reporting.** Because the permit requires sublethal hypothesis testing endpoints from Methods 1000.0, 1002.0, and 1003.0 in the test methods manual titled *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA-821-R-02-013, 2002), with-in test variability must be reviewed for acceptability, and variability criteria (upper and lower PMSD bounds) must be applied, as directed under section 10.2.8 – *Test Variability of the test methods manual*. Under section 10.2.8, the calculated PMSD for both reference toxicant test and effluent toxicity test results must be compared with the upper and lower PMSD bounds variability criteria specified in Table 6 – *Variability Criteria (Upper and Lower PMSD Bounds) for Sublethal Hypothesis Testing Endpoints Submitted Under NPDES Permits*, following the review criteria in paragraphs 10.2.8.2.1 through 10.2.8.2.5 of the test methods manual. Based on this review, only accepted effluent toxicity test results shall be reported.

3. **Compliance Summary.** Monthly self-monitoring reports submitted by the Permittee shall contain an updated chronology of chronic toxicity test results expressed in TUC, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency (routine, accelerated, or TRE). The final report shall clearly demonstrate that the Permittee is in compliance with effluent limitations and other permit requirements.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

This section of the standardized permit is not applicable to the City of Ferndale.

VII. RECLAMATION MONITORING REQUIREMENTS

A. Monitoring Location EFF-002

1. The Permittee shall monitor treated wastewater to be reclaimed and used for irrigation at Monitoring Location EFF-002 as follows:

Table E-5. Effluent Monitoring - Monitoring Location EFF-002

Parameter	Units	Sample Type	Sampling Frequency	Required Analytical Test Method
Flow ³	mgd	Continuous	Daily	Meter
BOD ₅	mg/L	8-hr Composite	Monthly	Standard Method 5210B
TSS	mg/L	8-hr Composite	Monthly	Standard Method 2540D
Settleable Solids	mL/L-hr.	8-hr Composite	Weekly	Standard Method 2540F

Table E-5. Effluent Monitoring - Monitoring Location EFF-002

Parameter	Units	Sample Type	Sampling Frequency	Required Analytical Test Method
Total Coliform Organisms	MPN/100 mLs	Grab	Weekly	Standard Method 9221
Ammonia Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Nitrate Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Total Phosphorous	mg/L P	Grab	Monthly	title 40, section 136
Total Dissolved Solids	mg/L	Grab	Monthly	Standard Method 2540C
Visual Observations	---	---	Daily	Visual

VIII. RECEIVING WATER MONITORING REQUIREMENTS

A. Monitoring Location R-001

1. The Permittee shall monitor upstream conditions in the receiving waters at Monitoring Location R-001 during the periods of surface water discharge, as follows:

Table E-6. Receiving Water Monitoring Requirements – R-001

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Method
Flow	cfs or mgd		Daily	Gauge or Meter ⁷
Dissolved Oxygen	mg/L	Grab	Monthly	title 40, section 136
pH ⁸	s.u.	Grab	Monthly	Standard Methods
Temperature ⁸	° F	Grab	Monthly	Standard Methods
Turbidity	NTU	Grab	Monthly	Standard Method 2130B
Specific Conductance	micromhos/cm ⁹	Grab	Monthly	title 40, section 136
Ammonia Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Nitrate Nitrogen	mg/L N	Grab	Monthly	title 40, section 136
Total Phosphorous	mg/L P	Grab	Monthly	title 40, section 136
Visual Observations	---	---	Monthly	Visual
CTR Pollutants ¹⁰	µg/L	Grab	2X/Permit Term	Standard Methods

⁷ The Discharger shall propose a method of measurement for the receiving water flow for approval by the Executive Officer.

⁸ pH and temperature monitoring must coincide with monthly monitoring for ammonia

⁹ Measured in micromhos/cm at 25 °C

¹⁰ Those pollutants identified by the California Toxics Rule at title 40, section 131.38. Monitoring shall occur simultaneously with effluent monitoring for CTR pollutants required by Section IV. A. 1 of the MRP. Analytical methods must achieve the lowest minimum level (ML) specified in Appendix 4 of the SIP; and in accordance with

B. Monitoring Location R-002

The Permittee shall monitor downstream conditions in the receiving waters at Monitoring Location R-002 during the periods of surface water discharge, as follows:

Table E-7. Receiving Water Monitoring Requirements – R-002

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Method
Dissolved Oxygen	mg/L	Grab	Monthly	title 40, section 136
pH	s.u.	Grab	Monthly	Standard Methods
Temperature	°F	Grab	Monthly	Standard Methods
Hardness ¹¹	mg/L CaCO ₃	Grab	Monthly	Standard Methods
Turbidity	NTU	Grab	Monthly	Standard Method 2130B
Specific Conductance	micromhos/cm ⁹	Grab	Monthly	title 40, section 136
Visual Observations	---	---	Monthly	Visual

C. Monitoring Location R-003

The Permittee shall monitor downstream conditions in the receiving waters at Monitoring Location R-003 during the periods of surface water discharge, as follows.

Table E-8. Receiving Water Monitoring Requirements – R-003

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Method
Dissolved Oxygen	mg/L	Grab	Monthly	title 40, section 136
pH	s.u.	Grab	Monthly	Standard Methods
Temperature	°F	Grab	Monthly	Standard Methods
Specific Conductance	micromhos/cm ⁹	Grab	Monthly	title 40, section 136
Visual Observations	---	---	Monthly	Visual

Section 2.4.1 of the SIP, the Discharger shall report the Reporting Level (RL) and the Method Detection Limit (MDL) with each sample result.

¹¹ Receiving water hardness monitoring must coincide with effluent monitoring for metals

IX. OTHER MONITORING REQUIREMENTS

A. Rainfall

The Permittee shall monitor and report monthly rainfall to an accuracy of 0.1 inches for comparison to surface water flow and recycled water application rates.

B. Monitoring Location M-UV - UV Disinfection System Monitoring

The Permittee shall monitor the UV Disinfection system, as follows:

1. **Monitoring.** The UV transmittance of the effluent from the UV disinfection system shall be monitored continuously and recorded. The operation UV dose shall be calculated from UV transmittance and exposure time, using lamp age and sleeve fouling factors.
2. **Compliance.** The UV transmittance shall not fall below 55 percent of maximum at any time, unless otherwise approved by California Department of Public Health (CDPH). The operational UV dose shall not fall below 100 millijoules per square centimeter (mJ/cm^2) at any time, unless otherwise approved by CDPH.
3. **Reporting.** The Permittee shall report daily average and lowest daily transmittance and operational UV dose on its monthly monitoring reports. If the UV transmittance falls below 55 percent or UV dose falls below $100 \text{ mJ}/\text{cm}^2$, the event shall be reported to the Regional Water Board and the CDPH by telephone with 24 hours. Any inadequately treated and disinfected wastewater shall be diverted to a storage basin or an upstream process for adequate treatment.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. **Standard Provisions.** The Permittee shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. **Schedules of Compliance.** If applicable, the Permittee shall submit all reports and documentation required by compliance schedules that are established by this Order. Such reports and documentation shall be submitted to the Regional Water Board on or before each compliance date established by this Order. If noncompliance is reported, the Permittee shall describe the reasons for noncompliance and a specific date when compliance will be achieved. The Permittee shall notify the Regional Water Board

when it returns to compliance with applicable compliance dates established by schedules of compliance.

B. Self-Monitoring Reports (SMRs)

1. The Permittee shall submit electronic Self-Monitoring Reports (eSMRs) using the State Water Board’s California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal. The Permittee shall maintain sufficient staffing and resources to ensure it submits eSMRs that are complete and timely. This includes provision of training and supervision of individuals (e.g., Permittee personnel or consultant) on how to prepare and submit eSMRs.
2. The Permittee shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Permittee shall submit monthly SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Permittee monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. All monitoring results reported shall be supported by the inclusion of the complete analytical report from the laboratory that conducted the analyses.
4. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-9. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins	Monitoring Period	SMR Due Date
Continuous	February 1, 2013	All	1 st day of second calendar month following sampling
Daily	February 1, 2013	Midnight through 11:59 PM or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	1 st day of second calendar month following sampling
Weekly	February 1, 2013	Sunday through Saturday	1 st day of second calendar month following sampling
Monthly	February 1, 2013	1 st day of calendar month through last day of same	1 st day of second calendar month following sampling

Table E-9. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins	Monitoring Period	SMR Due Date
2X / Year	February 1, 2013	October 1 through May 15	1 st day of second calendar month following sampling
Annually	February 1, 2013	January 1 through December 31	1 st day of February of each year.
2X / Order Term	February 1, 2013	October 1 through May 15	May 1, 2014 and May 1, 2016

1. Reporting Protocols. The Permittee shall report with each sample result the applicable ML, the RL and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136.
2. The Permittee shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
 - a. Sample results greater than or equal to the reported ML shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 - b. Sample results less than the RL, but greater than or equal to the laboratory’s MDL, shall be reported as “Detected, but Not Quantified,” or DNQ. The estimated chemical concentration of the sample shall also be reported.

 For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words “Estimated Concentration” (may be shortened to “Est. Conc.”). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+ a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.
 - c. Sample results less than the laboratory’s MDL shall be reported as “Not Detected,” or ND.
 - d. Permittees are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
3. The Permittee shall submit SMRs in accordance with the following requirements:
 - a. The Permittee shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance

with interim and/or final effluent limitations. The reported data shall include calculation of all effluent limitations that require averaging, taking of a median, or other computation. The Permittee is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Permittee shall electronically submit the data in a tabular format as an attachment. During periods of land discharge, the reports shall certify "land discharge".

- b.** The Permittee shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify:
 - (1)** Facility name and address;
 - (2)** WDID number;
 - (3)** Applicable period of monitoring and reporting;
 - (4)** Violations of the WDRs (identified violations must include a description of the requirement that was violated and a description of the violation);
 - (5)** Corrective actions taken or planned; and
 - (6)** The proposed time schedule for corrective actions.
- c.** SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the CIWQS Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). In the event that paper submittal of SMRs is required, the Discharge shall submit the SMR to the address listed below:

Regional Water Quality Control Board
North Coast Region
5550 Skylane Blvd., Suite A
Santa Rosa, CA 95403

C. Discharge Monitoring Reports (DMRs)

DMRs are required for facilities designated as major dischargers.

- 1.** As described in Section X.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Permittee to electronically submit self-monitoring reports that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, major dischargers shall submit DMRs in accordance with the requirements described below. The Facility is currently designated as a minor discharger.

2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o Discharge Monitoring Report Processing Center Post Office Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15th Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated or modified cannot be accepted.

D. Other Reports

1. The Permittee shall report the results of any special studies, acute and chronic toxicity testing, TRE/TIE, PMP, and Pollution Prevention Plan required by Special Provisions of this Order.
2. **Groundwater Monitoring Reports.** Groundwater monitoring data, if required, shall be maintained in a spreadsheet format that allows for analysis of the on-going data. The electronic spreadsheets shall be submitted with the semi-annual groundwater monitoring reports.
3. **Annual Report.** The Permittee shall submit an annual report to the Regional Water Board for each calendar year. The report shall be submitted by March 1st of the following year. The report shall, at a minimum, include the following:
 - a. Both tabular and, where appropriate, graphical summaries of the monitoring data and disposal records from the previous year. If the Permittee monitors any pollutant more frequently than required by this Order, using test procedures approved under 40 CFR, section 136 or as specified in this Order, the results of this monitoring shall be included in the calculation and report of the data submitted SMR.
 - b. A comprehensive discussion of the Facility’s compliance (or lack thereof) with all effluent limitations and other WDRs, and the corrective actions taken or planned, which may be needed to bring the discharge into full compliance with the Order.
 - c. The names, certificate grades, and general responsibilities of all persons employed at the Facility;

- d. The names and telephone numbers of persons to contact regarding the wastewater treatment facility for emergency and routine situations;
 - e. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration;
 - f. A statement certifying whether the current operation and management manual and spill contingency plan, reflect the wastewater treatment facility as currently constructed and operated, and the dates when these documents were last reviewed and last revised for adequacy.
 - g. **Source Control Activity Reporting.** The Permittee shall submit, as part of its annual report to the Regional Water Board, a description of the Permittee's source control activities, as required by Provision VI.C.5.b. of this Order.
 - i. A copy of the source control standards.
 - ii. A description of the waste hauler permit system.
 - iii. A summary of the compliance and enforcement activities during the past year. The summary shall include the names and addresses of any industrial or commercial users under surveillance by the Permittee, an explanation of whether they were inspected, sampled, or both, the frequency of these activities at each user, and the conclusions or results from the inspection or sampling of each user.
 - iv. A summary of any industrial waste survey results.
 - v. A summary of public participation activities to involve and inform the public.
- 4. Biosolids Handling and Disposal Activity Reporting.** The Permittee shall submit, as part of its annual report due March 1st each year to the Regional Water Board, a description of the Permittee's solids handling, disposal and reuse activities over the previous twelve months. At a minimum, the report shall contain:
- a. Annual sludge production, in dry tons and percent solids;
 - b. A schematic diagram showing sludge handling facilities (e.g., digesters, thickeners, drying beds, etc.), if any and a solids flow diagram.
 - c. Methods of final disposal of sludge:
 - i. For any portion of sludge discharged to a sanitary landfill, the Permittee shall provide the volume of sludge transported to the land fill, the names and locations of the facilities receiving sludge, the Regional Water Board's WDRs order number for the regulated landfill, and the landfill classification.

- a. As soon as possible, but not later than **two (2) hours** after becoming aware of the discharge, the Permittee shall notify the California Emergency Management Agency (CalEMA)¹², the local health officer or directors of environmental health with jurisdiction over affected water bodies or land areas, and the Regional Water Board.

Information to be provided verbally to the Regional Water Board includes:

- i. Name and contact information of caller;
 - ii. Date, time and location of spill occurrence;
 - iii. Estimates of spill volume, rate of flow, and spill duration;
 - iv. Surface water bodies impacted, if any;
 - v. Cause of spill;
 - vi. Cleanup actions taken or repairs made; and
 - vii. Responding agencies.
- b. As soon as possible, but not later than **twenty-four (24) hours** after becoming aware of a discharge, the Permittee shall submit to the Regional Water Board a certification that CalEMA and the local health officer or directors of environmental health with jurisdiction over affected water bodies or land areas have been notified of the discharge. For the purpose of this requirement, "certification" means a CalEMA certification number and, for the local health department, name of local health staff, department name, phone number and date and time contacted.
 - c. Within **five (5) business days**, the Permittee shall submit a written report to the Regional Water Board office. The report must include all available details related to the cause of the spill and corrective action taken or planned to be taken, as well as copies of reports submitted to other agencies.
 - i. Information provided in the verbal notification;
 - ii. Other agencies notified by telephone;
 - iii. Detailed description of cleanup actions and repairs taken; and
 - iv. Description of actions that will be taken to minimize or prevent future spills.
 - d. In the cover letter of the monthly monitoring report, the Permittee shall include a brief written summary of the event and any additional details related to the cause or resolution of the event, including, but not limited to results of any water quality monitoring conducted.

¹² The contact number for spill reporting for the CalEMA is (800) 852-7550. The contact number of the Regional Water Board during normal business hours is (707) 576-2220. After normal business hours, spill reporting to CalEMA will satisfy the 2 hour notification requirement for the Regional Water Board.

2. All spills, unauthorized discharges, and sanitary sewer overflows (SSOs) less than 1,000 gallons that do not reach a drainage channel or a surface water:
 - a. As soon as possible, but not later than **twenty-four (24) hours** after becoming aware of the discharge, the Permittee shall notify the Regional Water Board and provide the applicable information in requirement 1.a of this section.
 - b. In the cover letter of the monthly monitoring report, the Permittee shall include a written description of the spill event.

ATTACHMENT F – FACT SHEET

Table of Contents

I.	PERMIT INFORMATION.....	F-3
II.	FACILITY DESCRIPTION	F-4
III.	APPLICABLE PLANS, POLICIES, AND REGULATIONS.....	F-10
	A. California Environmental Quality Act (CEQA).....	F-10
	B. State and Federal Regulations, Policies, and Plans.....	F-10
	C. Impaired Water Bodies on CWA 303(d) List.....	F-14
	D. Other Plans, Policies and Regulations.....	F-15
IV.	RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS.....	F-16
	A. Discharge Prohibitions.....	F-16
	B. Technology-Based Effluent Limitations	F-19
	C. Water Quality-Based Effluent Limitations (WQBELs).....	F-22
	D. Final Effluent Limitations	F-33
	E. Interim Effluent Limitations	F-38
	F. Land Discharge Specifications.....	F-38
	G. Reclamation Specifications.....	F-38
V.	RATIONALE FOR RECEIVING WATER LIMITATIONS.....	F-38
	A. Surface Water	F-38
	B. Groundwater	F-39
VI.	RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS.....	F-39
	A. Influent Monitoring.....	F-39
	B. Effluent Monitoring.....	F-39
	C. Whole Effluent Toxicity Testing Requirements	F-40
	D. Receiving Water Monitoring.....	F-43
	E. Other Monitoring Requirements.....	F-44
VII.	RATIONALE FOR PROVISIONS.....	F-44
	A. Standard Provisions	F-44
	B. Regional Water Board Standard Provisions	F-45
	C. Special Provisions	F-45
VIII.	PUBLIC PARTICIPATION	F-51
	A. Notification of Interested Parties.....	F-51
	B. Written Comments	F-52
	C. Public Hearing	F-52
	D. Waste Discharge Requirements Petitions	F-52
	E. Information and Copying	F-53
	F. Register of Interested Persons.....	F-53
	G. Additional Information	F-53

List of Tables

Table F-1.	Facility Information	F-3
Table F-2.	Historic Effluent Limitations and Monitoring Data – Discharge Point 001.....	F-7
Table F-3.	Historic Effluent Limitations and Monitoring Data – Discharge Point 002.....	F-8
Table F-4.	Basin Plan Beneficial Uses	F-11
Table F-5.	Technology-Based Effluent Limitations - Discharge Point 001.....	F-22
Table F-6.	Summary of Amended RPA Results	F-31
Table F-7.	Determination Final WQBELs Based on Human Health Criteria	F-33
Table F-8.	Effluent Limitations New WWTF – Discharge Point 001	F-36
Table F-9.	Required Effluent Monitoring Retained From Previous Permit.....	F-40
Table F-10.	Required Receiving Water Monitoring.....	F-43

ATTACHMENT F – FACT SHEET

As described in section II.B of the Order, the Regional Water Board incorporates this Fact Sheet as findings of the Regional Water Board supporting the issuance of this Order. This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Permittee. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Permittee.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the Ferndale Wastewater Treatment Facility.

Table F-1. Facility Information

WDID	1B831360HUM
Permittee	City of Ferndale
Name of Facility	City of Ferndale Wastewater Treatment Facility
Facility Address	701 Port Kenyon Road
	Ferndale, CA 95536
	Humboldt County
Facility Contact, Title and Phone	Jay Parrish, City Manager, (707) 786-4224
Persons Authorized to Sign and Submit Reports¹	Jay Parrish, City Manager Doug Culbert, Chief Operator Steve Coppini, Operator
Mailing Address	834 Main Street, P.O. Box 1095, Ferndale, CA 95536
Billing Address	834 Main Street, P.O. Box 1095, Ferndale, CA 95536
Type of Facility	Publicly Owned Treatment Works
Major or Minor Facility	Minor
Threat to Water Quality	2
Complexity	A
Pretreatment Program	No
Reclamation Requirements	Yes - Producer
New Facility	0.55 mgd average dry weather flow (ADWF)
Permitted Design Flow	0.95 mgd peak wet weather flow (PWWF)
Watershed	Lower Eel River
Receiving Water	Francis Creek/Salt River
Receiving Water Type	Freshwater

¹ Additional persons may be authorized to sign and submit reports, upon receipt of written authorization from the City Manager or Chief Operator.

- A. The City of Ferndale (hereinafter the Permittee) is the owner and operator of wastewater collection, treatment, reclamation, and disposal systems – a publicly owned treatment works (POTW). For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Permittee herein.
- B. The City of Ferndale discharges tertiary treated wastewater to Francis Creek/the Salt River, waters of the United States, and is currently regulated by Order No. R1-2009-0036, which was adopted on July 23, 2009. The POTW also provides secondary treated wastewater for reclamation/irrigation use on neighboring agricultural land. The terms and conditions of the current Order remain in effect until new Waste Discharge Requirements and National Pollutant Discharge Elimination System (NPDES) permit requirements are adopted pursuant to this Order.
- C. The Permittee submitted a Report of Waste Discharge, dated January 15, 2009, and applied for an NPDES permit renewal proposing construction of a new wastewater treatment facility (WWTF) to discharge at existing Discharge Point 001 an ADWF up to 0.55 mgd and a PWWF up to 0.95 mgd of treated wastewater. The application was deemed complete on February 12, 2009. The Permittee submitted a water effects ratio study (WER) for copper on August 7, 2012 as well as a supplemental summary of effluent data collected for select priority pollutants since the new treatment facility went online in December 2011. The WER and supplemental data were accompanied by a request for evaluation of effluent limitations and permit revision.

II. FACILITY DESCRIPTION

The Permittee owns and operates a municipal wastewater treatment facility (WWTF) and associated wastewater collection, reclamation, and disposal facilities that serve a population of approximately 1,500 residential and commercial users. From October 1 through May 14, treated wastewater is discharged to Francis Creek at its confluence with the Salt River and from May 15 through September 30, treated wastewater is applied to neighboring agricultural land.

A. Description of Wastewater Collection, Treatment or Controls

The City of Ferndale’s wastewater treatment facility, located north of the City near the confluence of Francis Creek and the Salt River, treats municipal wastewater from the City’s 1,500 residents, outlying areas, and several commercial facilities. Tertiary treated wastewater may be discharged to Francis Creek at its confluence with the Salt River from October 1 through May 14, and at least secondary treated wastewater is delivered for irrigation/reclamation use on neighboring agricultural land owned by Elias and Marilyn Sousa from May 15 through September 30 of each year and at other

appropriate times based upon weather and soil conditions. The Salt River is tributary to the Lower Eel River within the Ferndale Hydrologic Subarea of the Lower Eel River Hydrologic Area.

The Permittee previously reported a high rate of inflow and infiltration (I&I) – an average rate of approximately 0.5 mgd during the rainy season with a peak daily rate of approximately 3.6 mgd (Spencer Engineering and Construction Management, 2006). Subsequently the Permittee identified collection system improvements and adopted a municipal ordinance to reduce I/I through testing of sewer laterals and their rehabilitation, where appropriate.

The Permittee has identified and implemented significant collection system improvements. The Permittee has rehabilitated manholes and replaced or repaired several faulty portions of collection lines within its collection system. Permittee self-monitoring reports submitted during the 2008/2009 wet season show reduced rates of inflow and infiltration. The current average wet weather flows are approximately 0.6 mgd with peak flows less than 2.5 mgd. Average dry weather flows are reported around 0.15 mgd. The average annual flow at the historic WWTF between January 2007 and March 2009 was 0.43 mgd.

The Permittee completed construction of a new WWTF in late 2011. The new WWTF system will provides tertiary treatment of wastewater. Raw wastewater flows from the municipal collection system by gravity to the headworks. Within the headworks, a comminutor and bar screen provide primary treatment. Wastewater from the headworks up to 0.95 mgd is then pumped to a selector tank flowing by gravity to one of two rectangular extended aeration basins for biological treatment. From the aeration basins wastewater flows by gravity to the adjacent rectangular clarifiers. Return activated sludge (RAS) is selectively injected into the selector tank and aeration basins as appropriate to achieve maximum nitrogen removal efficiencies. Aerobically digested sludge is then pumped to a belt press for dewatering. The dewatered sludge is removed offsite for recycling or disposal at a permitted facility. Clarified wastewater undergoes disc filtration prior to ultraviolet disinfection. A holding basin is used at the end of the treatment train for temporary storage of treated effluent during periods of land application. Variable drive pumps located within the basin to provide continuous flows when discharging to surface water.

Influent exceeding 0.95 mgd is automatically diverted from the headworks to a synthetically lined wet-weather flow equalization basin, located in the historic oxidation pond. Flows from the wet-weather equalization basin automatically flow back to the headworks to proceed with full treatment through the WWTF once influent flows subside below 0.95 mgd.

B. Discharge Points and Receiving Waters

During the discharge season, the treatment plant discharges to Francis Creek at Discharge Point 001 (40° 35' 40" N latitude and 124° 15' 44" W longitude), approximately 600 feet upstream of its confluence with the Salt River, within the Ferndale Subarea of the Lower Eel River Hydrologic Area. The Basin Plan limits discharges to the Eel River and its tributaries to one percent of the receiving water flow (1:100) unless an exception to the requirement is granted by the Regional Water Board. (See section IV.C. of this Fact Sheet.) Exceptions are given for cause on a case-by-case basis, taking into consideration:

1. The reliability of the wastewater treatment facility;
2. Whether the discharge of waste is limited to rates and constituent levels that protect the beneficial uses of the receiving waters;
3. Whether reasonable alternatives for reclamation have been addressed to limit the amount of the wastewater to be discharged;
4. Whether the exception complies with state and federal antidegradation policies; and
5. Whether there is any discharge of waste to surface waters during the period of May 15 through September 30.

In order to consistently achieve effluent of sufficient quality to protect beneficial uses and become eligible for an exception to the Basin Plan discharge rate requirements, the Permittee has proposed construction of the new WWTF described above.

Hydraulic conditions of the Francis Creek / Salt River watershed have been degrading over time resulting in a higher sediment load and reduced flows. Watershed-wide plans for restoration of Francis Creek and the Salt River are underway that may affect and possibly improve the hydraulic configuration of the WWTF effluent receiving water area. Discharge Point 001 will remain unchanged at this time, with the ultimate receiving water remaining at the confluence of the Salt River.

C. Summary of Existing Requirements and Self-Monitoring Data

1. Effluent limitations contained in Order No. R1-2009-0036 for discharges from Discharge Point 001 (Monitoring Location EFF-001) and representative monitoring data from the new WWTF during the term of Order No. R1-2009-0036 are as follows:

Table F-2. Historic Effluent Limitations and Monitoring Data - Discharge Point 001

Parameter	Effluent Limitations				Monitoring Data (From December 2011 - To May 2012)	
	Units	Average Monthly ²	Average Weekly ²	Maximum Daily ²	Highest Result	No. of Violations
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	---	9	0
Total Suspended Solids	mg/L	10	15	---	6	0
Settleable Solids	ml/L	0.1	---	0.2	< 0.01	0
Total Coliform Organisms	MPN/100 ml	23 ³	---	---	110	1
Total Coliform Organisms	MPN/100 ml	---	---	230	1600	2
pH	standard units	Not less than 6.5 nor greater than 8.5			Range 6.9 to 7.9	
Ammonia	mg/L	1.0	---	---	0.59	0
Nitrate	mg/L	10	---	---	1.9	0
Total Nitrogen	mg/L	10	---	---	3.8	0
Lead ⁴	µg/L	1.2	---	2.4	< 0.5	0
Copper ⁴	µg/L	4.0	---	8.0	3.1	0
Mercury	µg/L	0.05	---	0.10	< 1.0	0
Nickel ⁴	µg/L	26	---	52	8.1	0
Zinc ⁴	µg/L	36	---	72	14	0
2,3,7,8 TCDD	µg/L	1.3 E-08	---	2.6 E-08	---	---

² See Attachment A Definitions

³ The median of all samples collected in a 30-day calendar period.

⁴ Final effluent limitations for this metal are dependent on the hardness of the receiving water and have been determined at each time that effluent was monitored in accordance with Table E-9 contained in Appendix E of the previous Order.

Table F-2. Historic Effluent Limitations and Monitoring Data - Discharge Point 001

Parameter	Effluent Limitations				Monitoring Data (From December 2011 - To May 2012)	
	Units	Average Monthly ²	Average Weekly ²	Maximum Daily ²	Highest Result	No. of Violations
Chlorodibromomethane	µg/L	0.401	---	0.804	< 1.0 < 0.5	0
Dichlorobromomethane	µg/L	0.56	---	1.1	< 1.0 < 0.5	0
Bis(2-Ethylhexyl) Phthalate	µg/L	1.8	---	3.6	< 4.0	0
alpha-BHC	µg/L	0.0039	---	0.0078	< 0.1	0
Heptachlor Epoxide	µg/L	0.0001	---	0.0002	< 0.1	0
Flow	mgd	0.95	---	---	0.764	0

2. Effluent limitations contained in Order No. R1-2006-0049 for discharges from Discharge Point 002 (Monitoring Location EFF-002) and representative monitoring data from the term of Order No. R1-2006-0049 are as follows:

Table F-3. Historic Effluent Limitations and Monitoring Data - Discharge Point 002

Parameter	Effluent Limitations			Monitoring Data (From December 2011 - To May 2012)	
	Units	Average Monthly ²	Maximum Daily ²	Highest Result	No. of Violations
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	30	---	3	0
Total Suspended Solids	mg/L	30	---	< 1	0
Settleable Solids	ml/L	0.1	0.2	< 0.01	0
Total Coliform Organisms	MPN/100 ml	23 ³	230	7.8	0
Flow	mgd	0.55	---	0.21	0

D. Compliance Summary

1. Violations Summary

During the term of the previous Order, and since operation of the new WWTF, the Permittee experienced three violations of coliform effluent limitations. Violations occurred during discharge to Francis Creek. These violations occurred in relation to periods of adjustment to the new equipment.

2. Enforcement Action Summary

Enforcement actions have yet to be taken against the Permittee, related to the three above mentioned violations of waste discharge and NPDES requirements. Previous enforcement actions are summarized below.

- a. Administrative Civil Liability (ACL) Complaint No. R1-2011-0068.** This ACL Complaint was issued by the Regional Water Board Executive Officer to address violations occurring across the effective periods of both Order R1-2009-0036 which became effective September 1, 2009 as well as the previous Order. Penalties imposed for violations of Order R1-2009-0036 included a total of four exceedances of total coliform effluent limitations, three for exceeding daily limitations and one for exceeding the monthly median.
- b. Cease and Desist Order (CDO) Rescission No. R1-2012-0018.** Pursuant to provisions of the Basin Plan, and discharge prohibitions set forth in historic permits, Ferndale was previously restricted from discharging effluent to the Eel River and its tributaries from October 1 to May 14 each year to flows no greater than one percent of the receiving water flow. Due to the low flows in Francis Creek and the Salt River, effluent flows from the WWTF routinely exceed one percent of the receiving water flow. The Permittee had been under order to cease and desist discharging in violation of waste discharge requirements and the Basin Plan since May 15, 2003. During the previous application for permit renewal, the Permittee applied for an exception to the discharge restriction. The exception was predicated upon the discharge of high quality effluent from the new WWTF and was adopted by the Board in Order R1-2009-0036. Upon completion and sustained successful operation of the new WWTF, on March 15, 2012, the Board adopted CDO Rescission No. R1-2012-0018 rescinding the order to cease and desist.

E. Planned Changes

The entire WWTF has been recently upgraded. No other planned changes have been identified at this time.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section. This section provides supplemental information, where appropriate, for the plans, policies, and regulations relevant to the discharge.

A. California Environmental Quality Act (CEQA)

Under California Water Code (Water Code) section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA (commencing with section 21100) of division 13 of the Public Resources Code. Accordingly, this exemption from CEQA applies to the Regional Water Board's action to adopt those portions of the Order that regulate NPDES discharges.

This action also involves the re-issuance of waste discharge requirements for an existing facility that discharges treated recycled wastewater to land through the use of irrigation. The Regional Water Board's action in approving those parts of the Order that regulate WDR-related discharges is also exempt from CEQA as an existing facility for which no expansion of design flow is being permitted at the time of the lead agency's determination pursuant to title 14, California Code of Regulations (CCR), section 15301.

B. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The Regional Water Quality Control Board (Regional Water Board) adopted a *Water Quality Control Plan for the North Coast Region* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. The Basin Plan, at page 2-18.00, establishes beneficial uses for groundwater as municipal and domestic supply, industrial service supply, industrial process supply, agricultural supply, and freshwater supply. Thus, beneficial uses applicable within the Ferndale Hydrologic Subarea of the Eel River Hydrologic Unit and area groundwater are as follows:

Table F-4. Basin Plan Beneficial Uses

Beneficial Use (s)	Receiving Water Name Discharge Points	
	Francis Creek / Salt River 001	Groundwater 002
Municipal and Domestic Water Supply (MUN)	E	E
Agricultural Supply (AGR)	E	E
Industrial Service Supply (IND)	E	E
Industrial Process Supply (PRO)	P	P
Groundwater Recharge (GWR)	E	
Freshwater Replenishment (FRESH)	E	
Navigation (NAV)	E	
Hydropower Generation (POW)	P	
Water Contact Recreation (REC-1)	E	
Non-contact Water Recreation (REC-2)	E	
Commercial and Sport fishing (COMM)	E	
Cold Freshwater Habitat (COLD)	E	
Wildlife Habitat (WILD)	E	
Preservation of Rare, Threatened or Endangered Species (RARE)	E	
Marine Habitat (MAR)	P	
Migration of Aquatic Organisms (MIGR)	E	
Spawning, Reproduction, and/or Early Development (SPWN)	E	
Shellfish Harvesting (SHELL)	E	
Estuarine habitat (EST)	E	
Aquaculture (AQUA)	P	P
Native American Culture (CUL)	E	E
Subsistence Fishing (FISH)	E	

In addition to the beneficial uses set out in the Basin Plan, there are several implementation plans that include actions intended to meet water quality objectives and protect beneficial uses of the North Coast Basin. For the Eel River and its tributaries, no point source waste discharges are allowed during the period of May 15 through September 30 and for all other periods the receiving stream's flow must be at least 100 times greater than the waste flow.

The Basin Plan also contains a narrative water quality objective for toxicity that states:

All waters shall be maintained free of toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life. Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, bioassay of appropriate duration or other appropriate methods as specified by the Regional Water Board.

The survival of aquatic life in surface waters subjected to a waste discharge, or other controllable water quality factors, shall not be less than that for the same water body in areas unaffected by the waste discharge, or when necessary for other control water that is consistent with the requirements for 'experimental water' as described in Standard Methods for the Examination of Water and Wastewater 18th Edition (or most recent addition). At a minimum, compliance with this objective as stated in the previous sentence shall be evaluated with a 96-hour bioassay.

In addition, effluent limits based upon acute bioassays of effluent will be prescribed. Where appropriate, additional numerical receiving water objectives for specific toxicants will be established as sufficient data becomes available, and source control of toxic substances will be required.

Requirements of this Order implement the Basin Plan.

- 2. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain federal water quality criteria for priority pollutants.
- 3. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.

Section 1.2 of the SIP allows the Regional Water Board to adjust the criteria/objective for metals with discharger-specific Water Effect Ratios (WER) established in accordance with U.S. EPA guidance – Interim Guidance on Determination and Use of Water Effect Ratios for Metals (EPA-823-B-94-001) or Streamlined Water-Effect Ratio Procedure for Discharges of Copper (EPA-822-R-01-005) (Streamlined Procedure). The Streamlined Procedure determines site-

specific values for a WER, a criteria adjustment factor accounting for the effect of site-specific water characteristics on pollutant bioavailability and toxicity to aquatic life.

- 4. Compliance Schedules and Interim Requirements.** The provision in section 2.1 of the SIP that allowed for the use of compliance schedules and interim limitations in an NPDES permit for CTR constituents ended on May 18, 2010. Based on a discharger's request and demonstration that it is infeasible to comply with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in a cease and desist order or time schedule order adopted by the Regional Water Board.

The State Water Board adopted Resolution No. 2008-0025 on April 15, 2008, titled Policy for Compliance Schedules in National Pollutant Discharge Elimination System Permits, which includes compliance schedule policies for pollutants that are not addressed by the SIP. This Policy became effective on August 27, 2008.

This Order does not include a compliance schedule.

- 5. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 CFR § 131.21, 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- 6. Antidegradation Policy.** 40 CFR 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of 40 CFR 131.12 and State Water Board Resolution No. 68-16. As discussed in detail in this Fact Sheet, the permitted discharge is consistent with the antidegradation provision of 40 CFR 131.12 and State Water Board Resolution No. 68-16.

- 7. Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at 40 CFR 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
- 8. Endangered Species Act.** This Order does not authorize an act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State. The Permittee is responsible for meeting all requirements of the applicable Endangered Species Act.

C. Impaired Water Bodies on CWA 303(d) List

Section 303(d) of the federal CWA requires states to identify waterbodies that do not meet water quality standards and are not supporting their beneficial uses after implementation of technology-based effluent limitations on point sources. Each state must submit an updated list, the 303(d) List of Impaired Waterbodies, to USEPA by April of each even numbered year. In addition to identifying the waterbodies that are not supporting beneficial uses, the 303(d) list also identifies the pollutant or stressor causing impairment and establishes a schedule for developing a control plan to address the impairment. The USEPA requires the Regional Water Board to develop total maximum daily loads (TMDLs) for each 303(d) listed pollutant and water body contaminant. TMDLs establish the maximum quantity of a given pollutant that can be added to a water body from all sources without exceeding the applicable water quality standard for that pollutant and determine wasteload allocations (the portion of a TMDL allocated to existing and future point sources) for point sources and load allocations (the portion of a TMDL attributed to existing and future nonpoint sources) for nonpoint sources.

In June 2007, the USEPA provided final approval of the 303(d) list of impaired water bodies prepared by the State. The list identifies the Eel River Delta within the Lower Eel Hydrologic Area as impaired by sedimentation/siltation and temperature. On December 18, 2007, USEPA approved a TMDL addressing sediment and temperature in the Lower Eel River and its tributaries. Regarding temperature, the TMDL concludes that most sources of heat in the Lower Eel River watershed are from diffuse, nonpoint sources and result from such factors as removal of stream shade, longer stream flow travel time, changes in timing and volume of natural stream flow due to water diversions and impoundments, and increased sediment

loads that cause widening of streams. As the critical time period for temperature is in the summer, the TMDL was established for that critical time period, which is also the time period when point source discharges from area wastewater treatment facilities are prohibited. The TMDL concludes that, because of the summer discharge prohibition, area wastewater treatment facilities, such as Ferndale's wastewater treatment plant, do not contribute to temperature loadings to the Lower Eel River Watershed, and therefore, the TMDL establishes a "zero" wasteload allocation for all current and future wastewater treatment facilities that discharge to the Lower Eel River Watershed. The Regional Water Board interprets this wasteload allocation to mean that, as long as the City of Ferndale adheres to the summer discharge prohibition, it will be in compliance with the approved TMDL for temperature.

Regarding sediment, the TMDL establishes a maximum loading of 125 percent of the natural sediment loading for the watershed and further defines that loading rate as 2.5 tons of sediment per square mile of watershed per day on a long term basis. Although nonpoint sources were found to be primarily responsible for excessive sediment loadings to the Lower Eel River, the TMDL establishes wasteload allocations for area wastewater treatment facilities at levels corresponding to existing permit limitations for suspended and settleable solids. To satisfy the requirements of the TMDL, this Order therefore retains the monthly average limitations for settleable solids from Order No. R1-2008-0038 of 0.1 mLs/L-hr., and suspended solids at 30 mg/L.

D. Other Plans, Policies and Regulations

- 1. Stormwater.** The Order requires the Permittee to seek authorization to discharge under and meet the requirements of the State Water Board's Water Quality Order 97-03-DWQ, NPDES General Permit No. CAS000001, *Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities Excluding Construction Activities*, if applicable. Pursuant to title 40, section 403, coverage under the general permit is not required for wastewater treatment facilities that treat domestic sewage, with a design flow of less than 1.0 mgd. Ferndale's current design flow is 0.95 mgd. However, section VI C6a of the Order does require the WWTF to implement upgrade and report best management practices to control Stormwater at the facility.
- 2. Sanitary Sewer Systems.** On May 2, 2006, the State Water Board adopted State Water Board Order No. 2006-0003-DWQ, *Statewide General WDRs for Sanitary Sewer Systems*. The general permit is applicable to all "federal and state agencies, municipalities, counties, districts, and other public entities that own or operate sanitary sewer systems greater than one mile in length that collect and/or convey untreated or partially treated wastewater to a publicly owned treatment facility in

the State of California.” The purpose of the general permit is to promote the proper and efficient management, operation, and maintenance of sanitary sewer systems and to minimize the occurrences and impacts of sanitary sewer overflows. The Order requires the Permittee to seek coverage under Order No. 2006-0003-DWQ, if applicable, and restates some provisions of the general permit.

3. **Discharge of Biosolids to Land.** On July 22, 2004, the State Water Board adopted State Water Board Order No. 2004-0012-DWQ, *General Waste Discharge Requirements for the Discharge of Biosolids to Land for Use as a Soil Amendment in Agricultural, Silvicultural, Horticultural, and Land Reclamation Activities*. The general waste discharge requirements establish standards for agronomic applications and the use of biosolids as a soil amendment or fertilizer in agriculture, forestry, and surface mining reclamation, and include provisions to mitigate significant environmental impacts. That Order requires the Permittee to obtain coverage under Order No. 2004-0012-DWQ, by December 30, 2007, for the discharge of biosolids from the wastewater treatment plant. The Order requires the Permittee to seek coverage under Order No. 2004-0012-DWQ, if applicable, and restates some provisions of the general permit.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: Section 122.44(a) requires that permits include applicable technology-based limitations and standards; and section 122.44(d) requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where the discharge has the reasonable potential to cause or contribute to an excursion above a narrative criterion, but numeric water quality objectives have not been established, WQBELs may be established using one or more of three methods described at title 40, section 122.44 (d) (vi). First, WQBELs may be established using a calculated water quality criterion, such as a proposed State criterion or an explicit State policy or regulation interpreting its narrative criterion. Second, WQBELs may be established on a case-by-case basis using USEPA criteria guidance published under CWA section 304(a). Third, WQBELs may be established using an indicator parameter for the pollutant of concern.

A. Discharge Prohibitions

1. **Prohibition III A.** The discharge of any waste not disclosed by the Permittee or not within the reasonable contemplation of the Regional Water Board is prohibited.

This prohibition is based on the Basin Plan, the previous Order (Order No. R1-2009-0036), and State Water Board Order WQO 2002-0012 regarding the petition of WDRs Order No. 01-072 for the East Bay Municipal Utility District and Bay Area Clean Water Agencies. In State Water Board Order WQO 2002-0012, the State Water Board found that this prohibition is acceptable in Orders, but should be interpreted to apply only to constituents that are either not disclosed by the Permittee or are not reasonably anticipated to be present in the discharge, but have not been disclosed by the Permittee. It specifically does not apply to constituents in the discharge that do not have “reasonable potential” to exceed water quality objectives.

The State Water Board has stated that the only pollutants not covered by this prohibition are those which were “disclosed ...and...can be reasonably contemplated.” (In re the Petition of East Bay Municipal Utilities District et al., (State Water Board 2002) Order No. WQ 2002-0012, p. 24) In that Order the State Water Board cited a case which held the Permittee is liable for discharge of pollutants not “within the reasonable contemplation of the permitting authority”..., (Piney Run Preservation Assn. v. County Commissioners of Carroll County, Maryland (4th Cir. 2001) 368 F .3d 255, 268.) Thus, State Water Board authority provides that, to be permissible, the constituent discharged (1) must have been disclosed by the Permittee and (2) can be reasonably contemplated by the Regional Water Board.

Whether or not the Permittee reasonably contemplates the discharge of a constituent is not relevant. What matters is whether the Permittee disclosed the constituent to the Regional Water Board or whether the presence of the pollutant in the discharge can otherwise be reasonably contemplated by the Regional Water Board at the time of Order adoption.

- 2. Prohibition III.B.** Creation of pollution, contamination, or nuisance, as defined by section 13050 of the Water Code, is prohibited.

This prohibition is based on section 13050 of the Water Code. It has been retained from Order No. R1-2009-0036.

- 3. Prohibition III.C.** The discharge of sludge or digester supernatant is prohibited, except as authorized under section VI.C.5.c. (Solids Disposal and Handling requirements).

This prohibition is based on restrictions on the disposal of sewage sludge found in federal regulations (title 40, section 503 (Biosolids), section 527, and section 258) and title 27 Cal. Code of Regs. It has been retained from Order No. R1-2008-0038.

- 4. Prohibition III.D.** The discharge of untreated or partially treated waste from anywhere within the collection, treatment, or disposal facility is prohibited, except as provided for in Prohibition III. E and Attachment D, Standard Provision I.G (Bypass).

This Prohibition has been retained from Order No. R1-2006-0036 and is based on the Basin Plan to protect beneficial uses of the receiving water from unpermitted discharges, and the intent of Water Code sections 13260 through 13264 relating to the discharge of waste to waters of the State without filing for and being issued an Order. This prohibition applies to spills not related to sanitary sewer overflows (SSOs) and other unauthorized discharges of wastewater within the collection, treatment, and disposal facilities. The discharge of untreated or partially treated wastewater from the collection, treatment, or disposal facility represents an unauthorized bypass pursuant to title 40, section 122.41(m) or an unauthorized discharge which poses a threat to human health and/or aquatic life, and therefore, is explicitly prohibited by this Order.

- 5. Prohibition III.E.** Any sanitary sewer overflow (SSO) that results in a discharge of untreated or partially treated wastewater to (a) waters of the United States, (b) groundwater, or (c) land that creates a pollution, contamination, or nuisance as defined in Water Code section 13050(m) is prohibited.

This prohibition applies to spills related to SSOs and is based on State standards, including section 13050 of the Water Code and the Basin Plan. This prohibition is consistent with the States' antidegradation policy as specified in State Water Board Resolution No. 68-16 (Statement of Policy with Respect to Maintaining High Quality of Waters in California) in that the prohibition imposes conditions to prevent impacts to water quality, does not allow the degradation of water quality, will not unreasonably affect beneficial uses of water, and will not result in water quality less than that prescribed in State Water Board or Regional Water Board plans and policies.

This prohibition is stricter than the prohibitions stated in State Water Board Order 2006-0003-DWQ, *Statewide General Waste Discharge Requirements for Sanitary Sewer Systems*. Order 2006-0003-DWQ prohibits SSOs that result in the discharge of untreated or partially treated wastewater to waters of the United States and SSOs that create a nuisance. Prohibition III.E. of this Order further prohibits any SSO that results in the discharge of untreated or partially treated wastewater to groundwater due to the prevalence of high groundwater in this Region and this Region's reliance on groundwater as a drinking water source.

- 6. Prohibition III.F.** The discharge of waste to land that is not owned by or subject to an agreement for use by the Permittee is prohibited.

This prohibition is retained from Order No. R1-2009-0036. Land used for the application of wastewater must be owned by the Permittee or be under control of the Permittee by contract so that the Permittee maintains a means for ultimate disposal of treated wastewater.

- 7. Prohibition III.G.** The discharge of waste at any point except Discharge Point 001 or to neighboring agricultural lands, or as authorized by another State Water Board or Regional Water Board Order, is prohibited.

This prohibition is a general prohibition that allows the Permittee to discharge waste only in accordance with WDRs. It is based on sections 301 and 402 of the federal CWA and section 13263 of the Water Code.

- 8. Prohibition III.H.** The discharge of treated wastewater from the wastewater treatment facility to the Eel River or its tributaries is prohibited during the period May 15 through September 30 of each year.

This prohibition is required by the Basin Plan. The Basin Plan prohibits discharges to the Eel River and its tributaries during the period May 15 through September 30 (Chapter 4, Waste Discharge prohibitions for the North Coastal Basin)

B. Technology-Based Effluent Limitations

1. Scope and Authority

Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations, require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based for Secondary Treatment Standards at Part 133.

Regulations promulgated in section 125.3(a)(1) require technology-based effluent limitations for municipal Permittees to be placed in NPDES permits based on Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such

treatment works must, at a minimum, meet effluent limitations based on secondary treatment as defined by the USEPA Administrator.

In addition, section 122.45 (f) requires the establishment of mass-based effluent limitations for all pollutants limited in Orders, except, 1) for pH, temperature, radiation, or other pollutants which cannot appropriately be expressed by mass, or (2) when applicable standards and limitations are expressed in terms of other units of measure, or (3) where the permit limitation is established on a case-by-case basis under section 125.3, and the limitations expressed in terms of mass are infeasible because the mass of the pollutant discharged cannot be related to a measure of operation, and permit conditions ensure that dilution will not be used as a substitute for treatment. Pollutants limited in terms of mass additionally may be limited in terms of other units of measurement, and the permit shall require that Permittee to comply with both limitations. Mass based limitations are based on the facility design flow.

Technology-based effluent limitations may be set on a case-by-case basis under section 402(a)(1) of the CWA to the extent that EPA-promulgated effluent limitations are inapplicable based upon the available information and unique factors related to the applicant. A combination of EPA- promulgated effluent limitations and effluent limits developed under a case-by-case basis scenario may be applied to carry out provisions of the CWA.

Alternative requirements, described as “Best Practicable Control Technology” (BPT) requirements may be established by a permitting authority on a case-by-case basis considering the appropriate factors listed at title 40, section 125.3 (d)(1). Factors to be considered for BPT requirements include:

- a. The total cost of application of technology in relation to the effluent reduction benefits to be achieved from such application;
- b. The age of equipment and facilities involved;
- c. The process employed;
- d. The engineering aspects of the application of various types of control techniques; process changes;
- e. Process changes; and
- f. Non-water quality environmental impact (including energy requirements)

2. Applicable Technology-Based Effluent Limitations

The City of Ferndale’s treated effluent is discharges into Francis Creek near its confluence with the Salt River during the winter discharge period of October 1 to May 14. Historically, the Salt River was wide and deep enough to be used as a shipping channel. Over time, the Salt River has experienced significant

reductions in channel capacity from sediment deposition and prolific growth of in-stream vegetation. As a result, the volume of effluent discharged from the Ferndale WWTF consistently exceeds one percent of the receiving water flow in violation of permit and Basin Plan requirements. The City of Ferndale has been under a Cease and Desist Order to comply with Basin Plan discharge rate requirements since May 2003. The Permittee has constructed a new WWTF utilizing a combination of extended aeration and disc filtration to comply with the criteria for an exception from the rate limitations set forth in Prohibition 3 of the Basin Plan, which are discussed in detail in this Fact Sheet.

In accordance with section 125.3(c) a combination of EPA-promulgated and case-by-case technology based effluent limitations has been established for the new WWTF. In setting case-by-case limitations pursuant to section 125.3 and based on BPT, the Regional Water Board considered the factors set forth in section 125.3(d). This information was provided by the Permittee as part of the application for NPDES permit renewal, which included a request for an exception to the Water Quality Control Plan for the North Coast Region Discharge Rate Limitation (Exception Request). The Exception Request, which demonstrated the capabilities of the new WWTF, explained that the new WWTF is capable of consistently treating wastewater to tertiary level quality through the operation of extended aeration tanks, clarifiers, and disc filters. Tertiary level treatment is defined under these circumstances as the ability to achieve 10 mg/l as a monthly average for BOD and TSS respectively.

An average weekly effluent limitation for BOD and TSS has also been established in the Order as required by title 40, section 122.45(d)(2), which states that effluent limitations for POTWs must be expressed as average weekly and average monthly limitations unless impracticable. In accordance with title 40, section 133.101, the average weekly limitation was calculated by multiplying the average monthly limitation of 10 mg/L by 1.5 to obtain a result of 15 mg/L.

This Order establishes the following technology based effluent limitations, applicable to Discharge Point 001.

Table F-5. Technology-Based Effluent Limitations - Discharge Point 001

Parameter	Units	New WWTF Effluent Limitations	
		Average Monthly	Average Weekly
BOD ₅	mg/L	10	15
	lbs/day	79	119
TSS	mg/L	10	15
	lbs/day	79	119
Percent Removal ⁵	%	85	---
pH	s.u.	6.0 – 9.0 ⁶	

a. Biochemical Oxygen Demand and Suspended Solids

Concentration-based limitations for BOD₅ and TSS reflect tertiary treatment. The mass emission limitations are based on the facility’s new average wet weather design capacity of 0.95 mgd.

The 30-day average percent removal requirement established by this Order for the new extended aeration WWTF is 85 percent as required by the technology-based effluent limitations derived from the minimum technology-based federal requirements for equivalent to secondary treatment set forth in section 133.105.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and NPDES regulations at title 40, section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards, including numeric and narrative objectives within a standard.

Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. During development of Order No. R1-2009-0036, a reasonable potential analysis (RPA) demonstrated reasonable potential for discharges from the Ferndale wastewater

⁵ Percent removal is determined for both BOD and TSS through comparison of the monthly average concentrations measured at M-INF and EFF-001

⁶ The final effluent limitation for pH is established between 6.5 and 8.5 based upon the more stringent water quality based criteria.

treatment facility to cause or contribute to exceedances of applicable water quality criteria for copper; lead; mercury; nickel; zinc; 2,3,7,8-TCDD; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide.

During development of this Order, new information from the upgraded WWTF was used to develop an amended RPA specifically incorporating new effluent data for copper, lead, mercury, nickel, zinc, chlorodibromomethane, dichlorobromomethane, bis(2-ethylhexyl)phthalate, alpha-BHC and heptachlor epoxide. Where new information was not available, the information and findings from the previous RPA was determined to remain applicable.

Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established in accordance with the requirements of title 40, section 122.44(d)(1) (vi), using: 1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; 2) an indicator parameter for the pollutant of concern; or 3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information.

The process for determining "reasonable potential" and calculating WQBELs, when necessary, is intended to protect the designated beneficial uses of receiving waters as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in the Basin Plan and in other applicable State and federal rules, plans, and policies, including applicable water quality criteria from the CTR and the NTR.

Section 4, of the Basin Plan limits discharges to the Eel River and its tributaries to releases not exceeding one percent (100:1) of the receiving stream's flow during the allowable discharge season. As described in this Fact Sheet, the City of Ferndale was formerly under Cease and Desist Order to comply with Basin Plan discharge rate requirements.

The Basin Plan indicates that the Regional Water Board will consider for cause exceptions to the waste discharge rate limitations and requires that exceptions be defined in NPDES permits for each discharger, on a case by case basis. The Permittee applied for and has been granted an exception to the waste discharge rate limitation. The Permittee has demonstrated consistency with Basin Plan exception requirements for a discharge rate at one hundred percent of the receiving water flow (1:1) as follows:

- a.** *The wastewater treatment facility shall be reliable.*

The Permittee has constructed a new WWTF including replacement of the influent pump station, a new expanded headworks facility, retrofit of the existing oxidation pond into an 8.0 million gallon equalization basin, construction of new aeration tanks, clarifiers, disc filters, and ultraviolet disinfection. Ultraviolet disinfection has been shown to be more effective than chlorine in denaturing viruses and provides a higher level of pathogen removal than chlorine disinfection. Extended aeration and filtration and disinfection treatment technologies applied at the new WWTF have been shown to produce reliably high quality effluent of tertiary level quality.

- b.** *Reliability shall be demonstrated through analysis of the features of the facility including, but not limited to, system redundancy, proper operation and maintenance, and backup storage capacity to prevent the threat of pollution or nuisance.*

The new headworks facility includes a primary channel and a second channel for redundancy. Two main pumps within the headworks pump influent to the treatment works, with a third pump in place for redundancy. Wintertime flows exceeding the peak treatment capacity of 0.95 mgd will be pumped to an 8.0 million gallon equalization basin and retained for later treatment when influent flows subside. The equalization basin may also serve as emergency storage or temporary storage during WWTF upsets or routine maintenance activities respectively.

- c.** *The discharge of waste shall be limited to rates and constituent levels which protect the beneficial uses of the receiving waters.*

In conjunction with the application for the 2009 NPDES permit renewal, the Permittee submitted the Exception Request. The analysis provided by the Permittee in the Exception Request, and reviewed by the Regional Water Board Staff, demonstrated that the discharge from the WWTF will be limited to concentrations and rates protective of beneficial uses identified in this Fact sheet.

- d.** *Protection shall be demonstrated through analysis of all the beneficial uses of the receiving waters. For receiving waters which support domestic water supply (MUN) and water contact recreation (REC1), analysis shall include expected normal and extreme weather conditions within the discharge period, including estimates of instantaneous and long-term minimum, average, and maximum discharge flows and percent dilution in receiving waters. The analysis shall evaluate and address cumulative effects of all discharges, including point and nonpoint source contributions, both in existence and reasonably foreseeable. For receiving waters which support domestic water supply (MUN), the Regional*

Water Board shall consider the California Department of Health Services evaluation of compliance with the Surface Water Filtration and Disinfection Regulations contained in Section 64650 through 64666, Chapter 17, Title 22 of the California Code of Regulations. Demonstration of protection of beneficial uses shall include consultation with the California Department of Fish and Game regarding compliance with the California Endangered Species Act.

The Exception Request included an analysis that compared the potential cumulative effects of the discharge of the tertiary treated wastewater that could occur under extreme conditions on the existing receiving water quality, with the existing effluent quality, and models the projected conditions. Constituents that were identified and compared to water quality objectives in the Basin Plan for the protection of beneficial uses include: color, taste and odor, floating materials, biostimulatory substances, nitrogen, phosphorus, phytoplankton chlorophyll-a, sediment, turbidity, total suspended solids, settleable materials, oil and grease, dissolved oxygen, pH, bacteria, temperature, toxicity, pesticides, and chemical constituents.

- e. The exception shall be limited to that increment of wastewater which remains after reasonable alternatives for reclamation have been addressed.*

The Permittee reclaims all treated wastewater from May 15 through September 30 each year. Additional periods of reclamation occur as weather permits. Because of large amounts of rainfall and high groundwater table in the North Coast Region, there are limited opportunities for additional reclamation.

- f. The exception shall comply with State Water Board Resolution No. 68-16, "Statement of Policy with Respect to Maintaining High Quality Waters in California," and the federal regulations covering antidegradation (40 CFR §131.12).*

The General Findings of the Exception Request indicate:

“The new WWTF effluent quality, consistent and uniform discharge rates improve instream dissolved oxygen levels. In general, dissolved oxygen levels at the downstream sampling sites show predicted dissolved oxygen levels above the Basin Plan minimum dissolved oxygen limit of 7 mg/l. Ammonia levels at all three sites have been significantly improved due to the highly nitrified effluent from the new WWTF. Phytoplankton chlorophyll-a levels have also been reduced at all three sites. Following the end of the discharge period modeling results show that any effects or impacts from discharged effluent quickly dissipate for all constituents.”

The exception to the discharge limitation will not result in degradation of the receiving water because it will result in improvements over existing conditions in the receiving waters. The exception therefore complies with state and federal anti-degradation policies.”

- g. There shall be no discharge of waste during the period May 15 through September 30.*

The Order prohibits discharges to surface water between May 15 and September 30 each year, during which time the Permittee reclaims the treated effluent for agricultural re-use.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. Beneficial Uses.** Beneficial use designations for receiving waters for discharges from the Facility are presented in section III.B.1 of this Fact Sheet.
- b. Basin Plan Water Quality Objectives.** In addition to the specific water quality objectives indicated above, the Basin Plan contains narrative objectives for color, tastes and odors, floating material, suspended material, settleable material, oil and grease, biostimulatory substances, sediment, turbidity, pH, dissolved oxygen, bacteria, temperature, toxicity, pesticides, chemical constituents, and radioactivity that apply to inland surface waters, enclosed bays, and estuaries, and includes the Russian River and its tributaries. For waters designated for use as domestic or municipal supply (MUN), the Basin Plan establishes as applicable water quality criteria the Maximum Contaminant Levels (MCLs) established by CDPH for the protection of public water supplies at title 22 of the CCR section 64431 (Inorganic Chemicals) and section 64444 (Organic Chemicals).
- c. SIP, CTR and NTR.** Water quality criteria and objectives applicable to this receiving water are established by the California Toxics Rule (CTR), established by the USEPA at 40 CFR 131.38; and the National Toxics Rule (NTR), established by the USEPA at 40 CFR 131.36. Criteria for most of the 126 priority pollutants are contained within the CTR and the NTR.

3. Determining the Need for WQBELs

NPDES regulations at 40 CFR 122.44 (d) require effluent limitations to control all pollutants which are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard.

a. Non-Priority Pollutants

- i. pH.** This Order retains an effluent limitation for pH of 6.5 to 8.5 from the previous permit. This limitation is based on the water quality objective for

all surface waters of the North Coast Region established by the Basin Plan (Chapter 3). This effluent limitation will be in effect for both the current and new WWTF.

- ii. Total Coliform Bacteria.** Coliform bacteria are a pollutant of concern in all wastewaters of domestic origin, and therefore, the Order retains the effluent limitations for total coliform bacteria from the previous permit. These effluent limitations will ensure that water quality objectives for bacteria, as established by Chapter 3 of the Basin Plan, will be maintained. The specific limitations are based on requirements established by the Department of Health Services at title 22, Cal. Code of Regs, Division 4, Chapter 3 (Water Recycling Criteria, and are those levels of bacteria required for the reclamation use of treated wastewater for surface irrigation of (i) pasture used for animals producing milk for human consumption and (ii) any nonedible vegetation where access is controlled. This effluent limitation will remain in effect.
- iii. Settleable Solids.** Effluent limitations for settleable solids are retained from the previous Order and reflect levels of treatment attainable by secondary treatment facilities. This limitation is based on the water quality objective prohibiting bottom deposits for all surface waters of the North Coast Region established by the Basin Plan. This effluent limitation will remain in effect.
- iv. Nitrogen Compounds.** Untreated domestic wastewater contains ammonia nitrogen. Nitrification is a biological process that converts ammonia to nitrite and nitrate. Denitrification is a process that converts nitrate to nitrogen gas, which is then released to the atmosphere. Inadequate or incomplete nitrification may result in the discharge of ammonia to the receiving stream and inadequate or incomplete denitrification may result in the discharge of nitrate to the receiving stream. The WWTF is designed to use nitrification to remove ammonia from the waste stream and denitrification to remove nitrate from the waste stream, culminating in an overall reduction of total nitrogen.

 - (a). Total Nitrogen.** The Basin Plan contains a narrative water quality objective for biostimulatory substances that states “[w]aters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.” The Regional Water Board is increasingly concerned about the biostimulatory properties of discharges to surface waters in the North Coast Region. The Exception Request submitted by the Permittee evaluated the potential for biostimulatory effects specific to Francis Creek and the Salt River from nutrients, such as phosphorus and nitrogen containing compounds,

common to treated wastewaters. Stimulation of biological growth can diurnally deplete dissolved oxygen in receiving water below Basin Plan criteria. Results from site specific monitoring and modeling indicate that nitrogen is the potential limiting nutrient for biostimulatory activity in Francis Creek and the Salt River. Based upon the available information, a total nitrogen concentration in the effluent of 10 mg/L has been shown by modeling to limit biostimulation to an extent which maintains receiving water dissolved oxygen concentrations to concentrations ranging within Basin Plan criteria most of the time. The Order establishes an effluent limitation for the new WWTF for total nitrogen at 10 mg/L in order to support the Exception Request. Confirmation of modeling assumptions and associated effluent limitations will be evaluated based upon ongoing monitoring of actual conditions over time.

- (b). Nitrate.** Nitrate is known to cause adverse health effects in humans. For waters designated as domestic or municipal supply, the Basin Plan (Chapter 3) adopts the Maximum Contaminant Levels (MCLs), established by the Department of Public Health for the protection of public water supplies at Title 22 of the California Code of Regulations, sections 64431 (Inorganic Chemicals) and 64444 (Organic Chemicals), as applicable water quality criteria. The MCL for nitrate (10 mg/L N) is therefore applicable as a water quality criterion. In order to support the Exception Request this Order establishes effluent limitations for nitrate for the protection of human health as well as prevention of biostimulatory effects which could result in diurnal swings of dissolved oxygen concentrations in the receiving water below Basin Plan criteria as described above.
- (c). Ammonia.** Ammonia is known to cause toxicity to aquatic organisms in surface waters. The Basin Plan establishes a narrative water quality objective for toxicity, stating that “[a]ll waters shall be maintained free of toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life.” Due to concerns regarding ammonia toxicity, the Regional Water Board relies on USEPA’s recommended water quality criteria for ammonia in fresh water from the 1999 Update of Ambient Water Quality Criteria for Ammonia, EPA-822-R-99-014 (1999) to interpret the Basin Plan’s narrative objective for toxicity. USEPA has recommended acute and chronic water quality criteria for the protection of aquatic life, which are dependent on receiving water pH, and the presence/absence of salmonids (acute criteria), and pH, temperature, and the presence/absence of early life stages of fish (chronic criteria). Applying the USEPA acute and chronic ammonia

toxicity criteria for periods where salmonids are present the acute ammonia concentration in extreme temperature (18°C) and pH (8.5) conditions would be calculated at 2.14 mg/L and 0.87 mg/L respectively. Application of ammonia concentration at 1.0 mg/L to receiving water models used for the Exception Request indicated downstream ammonia concentrations up to 0.5 mg/L, below levels for ammonia toxicity. The model accounted for a discharge ratio of 1:1 in receiving water. This Order therefore retains an effluent limitation for ammonia to protect aquatic life.

b. Priority Pollutants

SIP section 1.3 requires the Regional Water Board to use all available, valid, relevant, and representative receiving water and effluent data and information to conduct a reasonable potential analysis (RPA). For the previous Order the Regional Water Board used effluent and receiving monitoring data generated during five monitoring events collected during discharges from the historic WWTF that occurred in February 2002, January 2003, December 2003, March 2004, and November 2007.

Section 1.2 of the SIP indicates that the Regional Water Board shall have discretion to consider if any data are inappropriate for use in implementing the Policy. Instances where such consideration is warranted include, but are not limited to evidence that a sample is not representative of effluent or ambient receiving water quality. In this case, Regional Water Board staff has determined that receiving water data from 2002 and 2003 was close to ten years old and erroneously high, particularly in January 2003; as a result the data is unlikely to adequately represent existing ambient receiving water quality. Therefore, when conducting the RPA, Regional Water Board staff applied receiving water data available from 2004 and 2007 as well as hardness data from 2011 and 2012.

Limited effluent data collected during seven monitoring events from the new WWTF between December 2011 and May 2012 have been applied by the Regional Water Board to generate an RPA using current effluent data for copper; lead; mercury; nickel; zinc; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide.

Some freshwater water quality criteria are hardness-dependent; i.e., as hardness decreases, the toxicity of certain metals increases, and the applicable water quality criteria become correspondingly more stringent. For the RPA, a hardness concentration of 110 mg/L CaCO₃ was used, reflecting the lowest receiving water hardness measured by the Permittee since initiating discharge from the new WWTF.

To conduct the amended RPA, Regional Water Board staff identified the maximum effluent concentration (MEC) and maximum background (B) concentration for each priority, toxic pollutant from effluent and receiving water data provided by the Permittee, and compared this information to the most stringent applicable water quality criterion (C) for each pollutant with applicable water quality criteria from the NTR, CTR, and the Basin Plan. Section 1.3 of the SIP establishes three triggers for a finding of reasonable potential.

Trigger 1. If the MEC is greater than C, there is reasonable potential, and an effluent limitation is required.

Trigger 2. If B is greater than C, and the pollutant is detected in effluent (MEC > ND), there is reasonable potential, and an effluent limitation is required.

Trigger 3. After a review of other available and relevant information, a permit writer may decide that a WQBEL is required. Such additional information may include, but is not limited to: the facility type, the discharge type, solids loading analyses, lack of dilution, history of compliance problems, potential toxic impact of the discharge, fish tissue residue data, water quality and beneficial uses of the receiving water, CWA 303 (d) listing for the pollutant, and the presence of endangered or threatened species or their critical habitat.

For priority pollutants where data indicates no detectable concentration, but the minimum detection level exceeds the required minimum levels identified in Appendix 4 if the SIP, monitoring rather than reasonable potential will be triggered.

c. Priority Pollutant Reasonable Potential Determination

The RPA, which includes the WER for copper as well as the current effluent data for copper; lead; mercury; nickel; zinc; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide, no longer demonstrates reasonable potential for discharges from the City of Ferndale wastewater treatment facility for priority pollutants with the exception of 2,3,7,8-TCDD. No current information is available for 2,3,7,8-TCDD, therefore reasonable potential remains as identified during the previous permit term. The RPA determined that there is either no reasonable potential or there was insufficient information to conclude affirmative reasonable potential for the remainder of the 126 priority pollutants.

Because the new WWTF has been online for only one discharge season, available priority pollutant data is limited. In order to ensure priority pollutant data is available to conduct future RPAs, Attachment E of this Order requires a

minimum of two sample events for all priority pollutants in both effluent and receiving water during the term of this Order. The following table summarizes the reasonable potential analysis for each priority pollutant that analyzed in the effluent collected in 2011 and 2012.

The MECs, most stringent WQO/WQCs (C), and background concentrations (B) used in the RPA are presented in the following table, along with the RPA results (yes or no) for each toxic pollutant analyzed.

Table F-6. Summary of Amended RPA Results

CTR #	Priority Pollutants	MEC or Minimum DL ^[a] [b]	C	B or Minimum DL ^[a] [b]	RPA Results ^[c]
6	Copper	3.1	32.4	6.8	No
7	Lead	<0.5	3.59	1.7	No
8	Mercury	<1.0	0.05	0.012	Effluent MDL > C, Interim Monitor
9	Nickel	8.1	56.54	17.3	No
13	Zinc	14	130	18.4	No
16	2,3,7,8-TCDD	1.1E-07	1.3E-08	9.8E-07	Yes (Trigger 1)
68	Bis(2-Ethylhexyl)Phthalate	<4.0	1.8	2	Effluent MDL > C, Interim Monitor
103	alpha-BHC	<0.1	0.0039	<0.005	Effluent MDL > C, Interim Monitor
118	Heptachlor Epoxide	<0.1	0.0001	<0.005	Effluent MDL > C, Interim Monitor

[a] The Maximum Effluent Concentration (MEC) or maximum background concentration is the actual detected concentration unless it is preceded by "<", in which case the value shown is the minimum detection level as the analytical result was reported as not detected (ND).

[b] The MEC or maximum background concentration is "Not Available" when there are no monitoring data for the constituent.

[c] RPA Results:

- = Yes, if MEC > WQO/WQC, or B > WQO/WQC and MEC is detected;
- = No, if MEC and B are < WQO/WQC or all effluent data are undetected;
- = Undetermined (Ud), if no criteria have been promulgated;
- = Interim Monitor, if Effluent MDL > C
- = Cannot determine, if there are insufficient data.

4. WQBEL Calculations

Final WQBELs for 2,3,7,8 TCDD have been determined using the methods described in Section 1.4 of the SIP.

Step 1: For each priority pollutant that demonstrate reasonable potential, identify the applicable water quality criterion/objectives for the pollutant(s), and adjust the

criterion or objective, if applicable. This step is described in sections IV.C.3.b and IV.C.3.c, above.

Step 2: To calculate the effluent limits, an effluent concentration allowance (ECA) is calculated for each pollutant found to have reasonable potential using the following equation, which takes into account dilution and background concentrations:

$$ECA = C + D (C - B), \text{ where}$$

C = the applicable water quality criterion (adjusted for receiving water hardness and expressed as the total recoverable metal, if necessary)

D = the dilution credit (here D = 0, as the discharge does not qualify for a dilution credit)

B = the background concentration

Because no credit for dilution is being allowed, D=0, and the ECA is equal to the applicable criterion (ECA = C).

Step 3: For each ECA based on an aquatic life criterion/ the long term average discharge condition (LTA) is determined by multiplying the ECA by a factor (multiplier), which adjusts the ECA to account for effluent variability. The multiplier depends on the coefficient of variation (CV) of the data set and whether it is an acute or chronic criterion/objective. Table 1 of the SIP provides pre-calculated values for the multipliers based on the values of the CV. When the data set contains less than 10 sample results, or when 80 percent or more of the data set is reported as non-detect (ND), the CV is set equal to 0.6. Derivation of the multipliers is presented in section 1.4 of the SIP.

From Table 1 of the SIP, the acute and chronic ECA multipliers for calculating LTAs at the 99th percentile occurrence probability for copper, and cyanide are shown in the table below. The LTAs are determined as follows.

Step 4: WQBELs, including an average monthly effluent limitation (AMEL) and a maximum daily effluent limitation (MDEL) are calculated using the most limiting (lowest) LTA. The LTA is multiplied by a factor that accounts for averaging periods and exceedance frequencies of the effluent limitations, and for the AMEL, the effluent monitoring frequency. Here the CV for each of the pollutants is set equal to 0.60, respectively, and the sampling frequency is set equal to 4 (n = 4). The 99th percentile occurrence probability was used to determine the MDEL multiplier and a 95th percentile occurrence probability was used to determine the AMEL multiplier.

Step 5: When the most stringent water quality criterion/objective is a human health criterion/objective (as 2,3,7,8-TCDD), the AMEL is set equal to the ECA. From Table 2 of the SIP, when CV = 0.6 and n = 4, the MDEL multiplier at the 99th

percentile occurrence probability equals 3.11, and the AMEL multiplier at the 95th percentile occurrence probability equals 1.55. The MDEL for protection of human health is calculated by multiplying the ECA by the ratio of the MDEL multiplier to the AMEL multiplier and the AMEL is equivalent to the ECA. Final WQBELs for 2,3,7,8-TCDD are determined as follows.

Table F-7. Determination Final WQBELs Based on Human Health Criteria

Pollutant	Units	ECA	MDEL/AMEL	MDEL	AMEL
2,3,7,8-TCDD	µg/L	1.3E-08	2.01	2.6E-08	1.3E-08

5. Whole Effluent Toxicity (WET)

Effluent limitations for whole effluent, acute and chronic toxicity, protect the receiving water from the aggregate effect of a mixture of pollutants that may be present in effluent. There are two types of WET tests – acute and chronic. An acute toxicity test is conducted over a short time period and measures mortality. A chronic test is conducted over a longer period of time and may measure mortality, reproduction, and/or growth. The Basin Plan establishes a narrative water quality objective for toxicity, requiring that all waters be maintained free of toxic substances in concentrations that are lethal to, or produce other detrimental responses in aquatic organisms. Detrimental responses may include, but are not limited to, decreased growth rate, decreased reproductive success of resident or indicator species, and/or significant alterations in population, community ecology, or receiving water biota. The existing Order includes an effluent limitation for acute toxicity in accordance with the Basin Plan, which requires that the average survival of test organisms in undiluted effluent for any three consecutive 96-hour bioassay tests be at least 90 percent, with no single test having less than 70 percent survival.

In addition to the Basin Plan requirements, section 4 of the SIP states that chronic toxicity limitations are required in Orders for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. This Order does not establish an effluent limitation for chronic toxicity; however, chronic WET monitoring is required and limitations will be established if monitoring results demonstrate that discharges from the wastewater treatment facility are causing or contributing to chronic toxicity in the receiving water.

D. Final Effluent Limitations

1. Satisfaction of Anti-Backsliding Requirements

Except as provided in title 40, section 122.44(l)(2), federal anti-backsliding regulations require effluent limitations, standards and conditions contained in

reissued permits to be as least as stringent as the effluent limitations, standards, or conditions contained in the previous permit.

Removal of effluent limitations for chlorine, copper; lead; mercury; nickel; zinc; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide results in conditions at least as stringent as the effluent limitations in the previous Order. The addition of the new WWTF is a material and substantial alteration that justifies that application of a less stringent effluent limit. (40 CFR 122.44(l)((2)(i)(A.) Analytical results from the new WWTF effluent for copper; lead; mercury; nickel; zinc; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide indicate no reasonable potential to exceed water quality criteria. Insufficient data exists to eliminate reasonable potential for 2,3,7,8-TCDD from the new WWTF. The new WWTF provides tertiary quality effluent, replacing the existing WWTF that formerly provided only equivalent to secondary quality effluent; the quality of the discharge has significantly improved, resulting in an overall improvement to existing conditions in the receiving water. This information was not available at the time the previous permit was issued. Furthermore, chlorine is no longer used at the WWTF and is therefore also no longer considered to pose reasonable potential to exceed water quality criteria.

The reasonable potential for copper to exceed water quality criteria has been modified based upon site-specific conditions at the Ferndale facility. The new information provided by the Permittee indicates that based upon the relative bioavailability of copper to aquatic organisms; there is no reasonable potential for toxicity to those organisms from the copper in the effluent. Therefore, the protection afforded under the modified permit results in a level of protection for beneficial uses equal to the previous conditions of Order No. R1-2009-0036. Additionally, this Order is consistent with section 303 (d)(4)(B) of the Clean Water Act, which allows for changes to effluent limitations or other permitting standards provided that the quality of receiving waters equals or exceeds levels necessary to protect the beneficial uses for such waters and the change is consistent with the antidegradation policy. Consistency with the anti-degradation policy is addressed below. All other effluent limitations, standards, and conditions contained in this Order are at least as stringent as the effluent limitations in the previous Order.

Further, where a permit contains a less stringent effluent limitation than in the previous permit, CWA section 402(o) requires compliance with CWA 303(d)(4). Where the water quality meets or exceeds the applicable water quality standard for that constituent, section 303(d)(4) allows the effluent limitation to be revised only if it is consistent with the anti-degradation policy. As explained below, this

permit satisfies the requirements of the federal and state antidegradation policies.

2. Satisfaction of Antidegradation Policy

This Order is consistent with applicable federal and State antidegradation policies, as it does not authorize the discharge of increased concentrations of pollutants or increased volumes of treated wastewater. In fact, overall water quality in the receiving water will improve.

Pursuant to the Antidegradation Policy, the lowering of water quality can be allowed only if beneficial uses are protected, and if there is a maximum benefit to the people of the state. Adjusting the copper criterion using scientifically derived Water Effect Ratio (WER) factors as well as removal of limitations for chlorine, copper; lead; mercury; nickel; zinc; chlorodibromomethane; dichlorobromomethane; bis(2-ethylhexyl)phthalate; alpha-BHC; and heptachlor epoxide are predicated upon the protection of beneficial uses and therefore inherently complies with the requirement to protect those uses. In addition, the Permittee has evaluated potential sources in an effort to reduce these priority pollutant concentrations in the effluent.

Discharges regulated in accordance with this Order are for a publically owned treatment works (POTWs). The increased costs of additional treatment that would otherwise be required to remove low levels of priority pollutants are not in the best interest of the public given that beneficial uses are already shown to be protected; therefore the allowance of an incremental increase in degradation is found to be in the best interest to the people of the state.

The activities allowed in accordance with these modifications to the waste discharge requirements apply to existing facilities. Discharges from the WWTF will be required to maintain protection of the beneficial uses of the receiving water and comply with applicable provisions of the Basin Plan.

3. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD and TSS. Restrictions on these pollutants are discussed in sections this Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements applicable to both the WWTF. In addition, this Order contains effluent limitations for pH, total coliform bacteria, settleable solids, total nitrogen, nitrate, ammonia, and 2,3,7,8-TCDD that are more stringent than the

minimum, federal technology-based requirements but are necessary to meet water quality standards. These requirements are also discussed this Fact Sheet.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. Most beneficial uses and water quality objectives contained in the Basin Plan were approved under State law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for purposes of the CWA” pursuant to section 131.21(c)(1). The remaining water quality objectives and beneficial uses implemented by this Order (specifically the addition of the beneficial use of Native American Culture (CUL) and the General Objective regarding antidegradation) were approved by USEPA on March 4, 2005, and are applicable water quality standards pursuant to section 131.21(c)(2). Collectively, this Order’s restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

Table F-8. Effluent Limitations New WWTF – Discharge Point 001

Parameter	Units	Effluent Limitations New WWTF – Discharge Point 001				
		Average Monthly ⁷	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Biochemical Oxygen Demand 5-day @ 20°C	mg/L	10	15	---	---	---
	lbs/day ^{8,9}	79	119	---	---	---
Total	mg/L	10	15	---	---	---

⁷ See Attachment A for definitions

⁸ The mass discharge (lbs/day) is obtained from the following calculation for any calendar week or month:

$$\frac{8.34}{N} \sum_i^N Q_i C_i$$

in which N is the number of samples analyzed in any calendar week or month. Q_i and C_i are the flow rate (mgd) and the constituent concentration (mg/L), respectively, which are associated with each of the N grab samples, which may be taken in any calendar week or month. If a composite sample is taken, C_i is the concentration measured in the composite sample; and Q_i is the average flow rate occurring during the period over which samples are composited.

⁹ Mass-based effluent limitations are based on the peak wet weather flow of 0.95 mgd.

Table F-8. Effluent Limitations New WWTF – Discharge Point 001

Parameter	Units	Effluent Limitations New WWTF – Discharge Point 001				
		Average Monthly ⁷	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Suspended Solids	lbs/day ^{3 4}	79	119	---	---	---
Settleable Solids	ml/L	0.1	---	0.2		
Total Coliform Organisms	MPN/100 ml	23 ¹⁰	---	230	---	---
pH	standard units	---	---	---	6.0	9.0
Ammonia Nitrogen	mg/L	1.0	---	---	---	---
Nitrate Nitrogen	mg/L	10	---	---	---	---
Total Nitrogen	mg/L	10	---	---	---	---
2,3,7,8 TCDD	µg/L	1.3E-08	---	2.6E-08	---	---

4. Summary of Final Effluent Limitations

- a. **Percent Removal.** The average monthly percent removal of BOD₅ and TSS shall not be less than 85 percent. Percent removal shall be determined from the 30-day average value of influent wastewater concentration in comparison to the 30-day average value of effluent concentration for the same constituent over the same time period as measured at Monitoring Locations M-INF and EFF-001, respectively.
- b. **Discharge Rate.** During the period from October 1 through May 14, discharges of treated wastewater shall not exceed one-hundred percent (1:1) of the receiving water flow.
- c. **Flow.** The mean daily dry weather flow of waste through the treatment plant shall not exceed 0.55 mgd, measured over a calendar month. The average wet weather flow of waste through the treatment plant shall not exceed 0.95 mgd, averaged over a calendar month.
- d. **Acute Toxicity.** There shall be no acute toxicity in treated wastewater discharged to the Eel River and its tributaries. The Permittee will be considered compliant with this limitation when the survival of aquatic organisms in a 96-hour bioassay of undiluted effluent complies with the following.

¹⁰ The median of all samples collected in a 30-day calendar period

- i. Minimum for any one bioassay: 70 percent survival
- ii. Median for any three or more consecutive bioassays: at least 90 percent survival.

Compliance with the acute toxicity effluent limitation shall be determined in accordance with section V of the Monitoring and Reporting Program (Attachment E) of this Order.

E. Interim Effluent Limitations

This section does not apply to the City of Ferndale Wastewater Treatment Facility.

F. Land Discharge Specifications

This section does not apply to the City of Ferndale Wastewater Treatment Facility.

G. Reclamation Specifications

The Reclamation Specifications found in section IV.C.1 through section IV.C.14 of this Order conform to regulations contained in title 22, Cal. Code of Regs., Division 4, Chapter 3.

Disinfected secondary treated effluent is considered suitable for irrigation. The draft permit includes the disinfection standard prescribed by the expired Order; a median total coliform count not to exceed a most probable number (MPN) of 23 per 100 mL of effluent with no single sample exceeding a MPN of 230 per 100 mL. Secondary treatment is considered adequate to achieve stabilization of organic matter as well as prevent anaerobic and putrescible conditions. This order includes effluent limitations for biochemical oxygen demand and total suspended solids consistent with secondary treatment.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

1. CWA section 303(a-c) requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Regional Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional [Water] Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains Receiving Surface Water Limitations based on

the Basin Plan numerical and narrative water quality objectives for biostimulatory substances, bacteria, chemical constituents, color, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, sediment, settleable material, suspended material, tastes and odors, temperature, toxicity, and turbidity.

B. Groundwater

1. The beneficial uses of the underlying ground water are municipal and domestic supply, industrial service supply, industrial process supply, agricultural supply, and freshwater replenishment to surface waters. Groundwater limitations are required to protect the beneficial uses of the underlying groundwater.
2. State Water Board Resolution No. 68-16, requires, in part, that whenever the existing quality of water is better than the quality established in policies as of the date on which such policies become effective, such existing high quality water will be maintained until it is demonstrated to the state that any changes will be consistent with maximum benefit to the people of the state, will not unreasonably affect beneficial uses of such water, and will not result in water quality less than prescribed in the policies. This Order does not allow degradation of groundwater.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

Influent monitoring requirements for BOD₅ and TSS are retained from the previous permit and are necessary to determine compliance with the Order's percent removal requirements for these parameters.

B. Effluent Monitoring

Effluent monitoring requirements contained in Table F-15 have been retained from the previous permit. These monitoring requirements are necessary to determine compliance with prohibitions and/or effluent limitations established by the Order. Effluent monitoring requirements for chronic toxicity have also been retained from the previous permit. These monitoring requirements enable the Regional Water Board to

assess compliance with the Basin Plan’s narrative water quality objective for toxicity that is applicable to all receiving waters of the Region.

Table F-9. Required Effluent Monitoring Retained From Previous Permit

Parameter	Parameter
Flow	Acute Toxicity
Biochemical Oxygen Demand	Chronic Toxicity
Total Suspended Solids	Mercury
Settleable Solids	2,3,7,8-TCDD
pH	Alpha-BHC
Temperature	Heptachlor Epoxide
Total Coliform Organisms	Total Phosphorous
Ammonia Nitrogen	Total Dissolved Solids
Nitrate Nitrogen	CTR Pollutants
Total Nitrogen	

C. Whole Effluent Toxicity Testing Requirements

1. Acute Toxicity

- a. **Rationale.** 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity (Effluent Limitation IV.A.1.d).
- b. **Test Frequency.** The MRP retains a quarterly monitoring frequency from the previous permit in accordance with USEPA’s recommendation for monthly WET testing for facilities listed as “major facilities” and quarterly testing for “minor facilities.” (*Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs*, USEPA, 1996). Acute toxicity monitoring is required twice during the discharge season to meet this requirement.
- c. **Sample Type.** This Order specifies a 96-hour static renewal or static non-renewal test as described in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (USEPA Report No. EPA-821-R-02-012, 5th edition or subsequent editions). Upon request, other methods may be approved by the Regional Water Board’s Executive Officer.
- d. **Test Species.** This Order requires the Permittee to conduct acute toxicity tests with the water flea, *Ceriodaphnia dubia*, and the rainbow trout, *Oncorhynchus mykiss*, for at least two suites of tests. For the first two suites of

acute toxicity tests, the Permittee will determine the most sensitive aquatic species and continue to monitor with the most sensitive species. At least once every five years, the Permittee will rescreen to reconfirm the most sensitive species for the acute toxicity test.

- e. Test Method.** The presence of acute toxicity shall be estimated as specified in effluent limitation IV.A.1.e of the Order and shall be consistent with *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (USEPA Report No. EPA-821-R-02-012, 5th edition or subsequent editions). Upon request, other methods may be approved by the Regional Water Board Executive Officer.
- f. Dilution Water.** Acute toxicity tests shall be conducted using undiluted effluent.
- g. Test Failure.** If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Permittee shall re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.
- h. Accelerated Monitoring.** The provision requires accelerated acute toxicity testing when routine acute toxicity test results exceed the single sample effluent limitation (70 percent survival). The purpose of accelerated monitoring is to determine, in an expedient manner, whether there is a pattern of toxicity before requiring the implementation of a TRE. Under this provision, the Permittee is required to conduct testing on at least two additional samples, one within 14 days, and one within 21 days of receiving the initial sample result. If any of the additional samples do not comply with the three sample median minimum limitation (90 percent survival) using that sample result and the two previous sample results, the Permittee shall initiate a TRE. If any test of a sample is ruled invalid, the Permittee will re-sample within 7 days following notification of test invalidation.
- i. Notification and Reporting.** The MRP includes notification requirements regarding test results that exceed the acute toxicity effluent limitation and require reporting of whole effluent toxicity test results in accordance with the acute toxicity manual Chapter 12 (Report Preparation) or in an equivalent format.

2. Chronic Toxicity

- a. **Rationale.** Chronic whole effluent toxicity (WET) testing is required two times per year, during the discharge season, in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.
- b. **Test Frequency.** The USEPA has no fixed guidance on the establishment of monitoring frequency, but recommends monthly WET testing for facilities listed as "major facilities" and quarterly testing for "minor facilities" during the first year of WET testing in order to develop sufficient data to conduct a reasonable potential analysis. USEPA further recommends that a reduction in sampling frequency is appropriate if no individual toxicity test exceeds the WET limit or trigger. For small municipalities, not designated as "major facilities," the USEPA recommends at least one suite of tests to be conducted during the lifetime of the permit and prior to reissuance in order to assess reasonable potential. (*Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Programs*, USEPA, 1996).

This Order specifies routine monitoring for chronic toxicity, two times per year during the discharge season.

- c. **Sample Location.** Representative effluent samples shall be collected at Monitoring Location EFF-001, when discharging to surface water.
- d. **Sample Type.** The Permittee shall collect an 24 hour composite samples of effluent discharged from Discharge Point EFF-001 for critical life stage toxicity testing as indicated in this Order.
- e. **Test Species.** This Order requires the Permittee to conduct short-term tests with the water flea, *Ceriodaphnia dubia* (survival and reproduction test), the fathead minnow, *Pimephales promelas* (larval survival and growth test), and the green alga, *Selenastrum capricornutum* (growth test). Initially, the Permittee is required to determine the most sensitive test species and monitor the discharge for chronic toxicity using that species for no more than five years, whereupon, the Permittee will repeat the screening procedure to confirm the most sensitive species. If reasonable potential to exceed the narrative water quality objective is found to exist, the Permit may be reopened to include a chronic toxicity limitation, as appropriate. The Basin Plan does not allow a mixing zone for this discharge; therefore, reasonable potential will be based on results of chronic toxicity tests from samples collected at the end of the pipe.

- f. **Test Method.** The presence of chronic toxicity shall be estimated as specified in and shall be consistent with *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA-821-R-02-013, October, 2002.
- g. **Dilution Water.** Control and dilution water should be receiving water at a location immediately upstream and outside the influence of the outfall for all test methods except the short-term chronic *Selenastrum capricornutum* test. For the *S. capricornutum* test method, synthetic laboratory water with a hardness similar to the receiving water shall be used as a control and diluent. Laboratory water may be substituted for receiving water, as described in the manual, upon approval by the Regional Water Board Executive Officer.
- h. **Accelerated Monitoring.** Guidance regarding accelerated monitoring and TRE initiation is provided in the *Technical Support Document for Water Quality-Based Toxics Control*, EPA/505/2-90-001, March 1991 (TSD). The TSD at page 118 states, "EPA recommends if toxicity is repeatedly or periodically present at levels above effluent limits more than 20 percent of the time, a TRE should be required." If there is adequate evidence of a pattern of effluent toxicity (i.e., toxicity present exceeding the monitoring trigger 20 percent of the time), the Regional Water Board's Executive Officer will require the Permittee to initiate a TRE. The TRE will include follow-up monitoring requirements to assure toxicity has been mitigated. Due to possible seasonality of the toxicity, the accelerated monitoring should be performed in a timely manner, preferably taking no more than 2 to 3 months to complete.
- i. **Monitoring Trigger.** A numeric chronic toxicity monitoring trigger of 1.0 TUc (where TUc = 100/NOEC) is established by the Order, because this Order does not allow any dilution for the chronic condition. Therefore, a TRE is triggered when the effluent exhibits a pattern of toxicity at 100 percent effluent.

D. Receiving Water Monitoring

- 1. Surface Water receiving water monitoring requirements contained in Table F-10 have been retained from the from the previous permit. These monitoring requirements are necessary to determine compliance with prohibitions, effluent limitations, and receiving water limitations established by the Order.

Table F-10. Required Receiving Water Monitoring

Parameter	Parameter
Flow	Ammonia Nitrogen

Table F-10. Required Receiving Water Monitoring

Parameter	Parameter
Dissolved Oxygen	Nitrate Nitrogen
pH	Total Phosphorous
Temperature	Visual Observations
Turbidity	CTR Pollutants
Specific Conductance	

2. Surface Water receiving water monitoring requirements are newly established by the Monitoring and Reporting Program (Attachment E of this Order) for an additional downstream location at R-003 for dissolved oxygen, pH, temperature, specific conductance, and visual observations. The monitoring requirements have been established to confirm assumptions of beneficial use protection presented in the Permittee’s Exception Request.
3. This Order does not establish groundwater monitoring requirements.

E. Other Monitoring Requirements

Operations monitoring for the ultraviolet disinfection system has been newly established by the Monitoring and Reporting Program (Attachment E of this Order). These monitoring requirements are established to document proper operations and maintenance of the disinfection system for the new WWTF. This monitoring is intended to ensure adherence to proper standards for ultraviolet light dosage are implemented, adequate disinfection occurs, and maintain required bacterial monitoring at a weekly frequency.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address enforcement authority

specified in sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

B. Regional Water Board Standard Provisions

In addition to the Federal Standard Provisions (Attachment D), the Permittee must comply with the Regional Water Board Standard Provisions provided in Standard Provisions VI.A.2.

1. Order Provision VI.A.2.a identifies the State's enforcement authority under the Water Code, which is more stringent than the enforcement authority specified in the federal regulations (e.g., title 40, sections 122.41(j)(5) and (k)(2)).
2. Order Provision VI.A.2.b requires the Permittee to notify Regional Water Board staff, orally and in writing, in the event that the Permittee does not comply or will be unable to comply with any Order requirement. The Provision requires the Permittee to make direct contact with a Regional Water Board staff person.
3. Order Provision VI.A.2.c requires the Permittee to petition with, and receive approval from, the State Water Board Division of Water Rights prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse. This requirement is mandated by Water Code section 1211.

C. Special Provisions

1. Reopener Provisions

- a. **Standards Revisions (Special Provisions VI.C.1.a).** Conditions that necessitate a major modification of a permit are described in title 40, section 122.62, which include the following:
 - (1) When standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision. Therefore, if revisions of applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such revised standards.
 - (2) When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.

- b. Reasonable Potential (Special Provisions VI.C.1.b).** This provision allows the Regional Water Board to modify, or revoke and reissue, this Order if present or future investigations demonstrate that the Permittee governed by this Permit is causing or contributing to excursions above any applicable priority pollutant criterion or objective or adversely impacting water quality and/or the beneficial uses of receiving waters.
- c. Whole Effluent Toxicity (Special Provisions VI.C.1.c).** This Order requires the Permittee to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity through a TRE. This Order may be reopened to include a numeric chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a numeric chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a numeric chronic toxicity limitation based on that objective.
- d. 303(d)-Listed Pollutants (Special Provisions VI.C.1.d).** This provision allows the Regional Water Board to reopen this Order to modify existing effluent limitations or add effluent limitations for pollutant(s) that are the subject of any future TMDL action.
- e. Special Studies (Special Provisions VI.C.1.e).** The Permittee may elect to study the feasibility of the use of water effect ratios and/or mixing zones to meet water quality objectives and effluent limitations for toxic pollutants. If these or other future water quality studies such as the required reclamation/recycled water evaluation provide new information and a basis for determining that a permit condition or conditions should be modified, the Regional Water Board may reopen this Order and make appropriate modifications to this Order.

2. Special Studies and Additional Monitoring Requirements

- a. Toxicity Reduction Evaluations (Special Provision VI.C.2.a).** The SIP requires the use of short-term chronic toxicity tests to determine compliance with the narrative toxicity objectives for aquatic life in the Basin Plan. Attachment E of this Order requires chronic toxicity monitoring for demonstration of compliance with the narrative toxicity objective.

In addition to WET monitoring, Special Provisions VI.C.2.a.(1) requires the Permittee to submit to the Regional Water Board an initial investigative TRE Work Plan for approval by the Executive Officer, to ensure the Permittee has a plan to immediately move forward with the initial tiers of a TRE, in the event effluent toxicity is encountered in the future. The TRE is initiated by

evidence of a pattern of toxicity demonstrated through the additional effluent monitoring provided as a result of an accelerated monitoring program.

- b. TRE Guidance.** The Permittee is required to prepare a TRE Work Plan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:
1. *Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants (EPA/833B-99/002)*, August 1999.
 2. *Generalized Methodology for Conducting Industrial TREs, (EPA/600/2-88/070)*, April 1989.
 3. *Methods for Aquatic Toxicity Identification evaluations: Phase I Toxicity Characterization Procedures*. Second Edition, EPA 600/6-91/005F, February 1991.
 4. *Toxicity Identification evaluation: Characterization of Chronically Toxic Effluents, Phase I*, EPA 600/6-91/005F, May 1992.
 5. *Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/080, September 1993.
 6. *Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/081, September 1993.
 7. *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, EPA-821-R-02-012, October 2002.
 8. *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA-821-R-02-013, October 2002.
 9. *Technical Support Document for Water Quality-based Toxics Control*, EPA/505/2-90-001, March 1991.
- c. Wastewater Reclamation Evaluation (Special Provision VI.C.2.b.)** This Order allows seasonal use of reclaimed wastewater. These discharges are required to comply with California Water Code sections 13500 – 13577 (Water Reclamation) and Department of Health Services regulations at title 22, Cal. Code of Regs., sections 60301 – 60357 (Water Recycling Criteria).. In order to ensure compliance with applicable regulations, some facilities may need to implement modifications. It is appropriate to provide a reasonable

time schedule for the proper evaluation of potential discharges, possible alternatives, and implementation for any necessary modifications.

3. Best Management Practices and Pollution Prevention

- a. Pollution Minimization Plan.** Provision VI.C.3 is included in this Order as required by section 2.4.5 of the SIP. The Regional Water Board included standard provisions in all NPDES permits requiring development of a Pollutant Minimization Program when there is evidence that a toxic pollutant is present in effluent at a concentration greater than an applicable effluent limitation.

4. Construction, Operation, and Maintenance Specifications

Title 40, section 122.41(e) requires proper operation and maintenance of permitted wastewater systems and related facilities to achieve compliance with permit conditions. An up-to-date operation and maintenance manual, as required by Provision VI.C.4.b of the Order, is an integral part of a well-operated and maintained facility.

5. Special Provisions for Municipal Facilities (POTWs Only)

The Regional Water Board includes special provisions in all NPDES Orders for municipal wastewater treatment facilities regarding wastewater collection systems, sanitary sewer overflows, source control, sludge handling and disposal, operator certification, and adequate capacity. These provisions assure efficient and satisfactory operation of municipal wastewater collection and treatment systems.

a. Wastewater Collection System (Provision VI.C.5.a)

i. Statewide General WDRs for Sanitary Sewer Systems

The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006. The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Permittee's collection

system is part of the system that is subject to this Order, certain standard provisions are applicable as specified in Provisions, section VI.C.5. For instance, the 24-hour reporting requirements in this Order are not included in the General Order. The Permittee must comply with both the General Order and this Order. The Permittee and public agencies that are discharging wastewater into the facility were required to obtain enrollment for regulation under the General Order by December 1, 2006.

All NPDES permits for POTWs currently include federally required standard conditions to mitigate discharges (title 40, section 122.41(d)), to report non-compliance (title 40, section 122.41(1)(6) and (7)), and to properly operate and maintain facilities (title 40, section 122.41(e)). This provision is consistent with these federal requirements.

ii. Sanitary Sewer Overflows.

Order No. 2006-0003-DWQ includes a Reporting Program that requires the Permittee, beginning May 2, 2007, to report SSOs to an online SSO database administered through the California Integrated Water Quality System (CIWQS) and telefax reporting when the online database is not available. The goal of these provisions is to ensure appropriate and timely responses by the Permittee to sanitary sewer overflows to protect public health and water quality.

The Order also includes reporting provisions to ensure adequate and timely notifications are made to the Regional Water Board and appropriate local, state, and federal authorities.

The Order establishes oral reporting limits for SSOs. SSOs less than 100 gallons are not required to be reported orally, while SSOs greater than or equal to 100 gallons must be reported orally to the Regional Water Board. Inevitably, minor amounts of untreated or partially treated wastewater may escape during carefully executed routine operation and maintenance activities. This Order establishes a reasonable minimum volume threshold for oral notifications. It has been the experience of Regional Water Board staff that SSOs to land that are less than 100 gallons are not likely to have a material effect on the environment or public health. Larger volumes in excess of 100 gallons may indicate lack of proper operation and maintenance and due care, and pose more of a threat to the environment or public health. All SSOs, regardless of volume, must be electronically reported pursuant to State Water Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems.

b. Source Control Provisions (Provision VI.C.5.b)

Because the average dry weather design flow of the Facility is less than 5.0 mgd, the Order does not require the Permittee to develop a pretreatment program that conforms to federal regulations. However, due to the identification of the reasonable potential for the priority pollutants lead, nickel, zinc, mercury, copper, 2,3,7,8-TCDD, chlorodibromomethane, dichlorobromomethane, bis(2-ethylhexyl)phthalate, alpha-BHC, and heptachlor epoxide, in the discharge, the proposed Order includes requirements for the Permittee to implement a source identification and reduction program. The Permittee's source identification and reduction program will need to address only those pollutants that continue to be detected by levels that trigger reasonable potential.

In addition, the Regional Water Board recognizes that some form of source control is prudent to ensure the efficient operation of the WWTF, the safety of City staff, and to ensure that pollutants do not pass through the treatment facility to impair beneficial uses of the receiving water. The proposed Order includes prohibitions for the discharge of pollutants that may interfere, pass through, or be incompatible with treatment operations, interfere with the use of disposal of sludge, or pose a health hazard to personnel.

c. Sludge Disposal and Handling (Provision VI.C.5.c)

The disposal or reuse of wastewater treatment screenings, sludges, or other solids removed from the liquid waste stream is regulated by title 40, sections 257, 258, 501, and 503, the State Water Board promulgated provisions of title 27, Cal. Code of Regs., Division 2, and with the Water Quality Control Plan for Ocean Waters of California (California Ocean Plan). The Permittee will be required to obtain coverage under State Water Board Water Quality Order No. 2004-0012-DWQ (*General Waste Discharge Requirements for the Discharge of Biosolids to Land as a Soil Amendment in Agricultural, Silvicultural, Horticultural, and Land Reclamation Activities*) or other applicable WDRs issued by the Regional Water Board.

d. Operator Certification (Provision VI.C.5.d)

This provision requires the WWTF to be operated by supervisors and operators who are certified as required by title 23, Cal. Code of Regs., section 3680.

e. Adequate Capacity (Provision VI.C.5.e)

The goal of this provision is to ensure appropriate and timely planning by the Permittee to ensure adequate capacity for the protection of public health and water quality.

f. Statewide General WDRs for Discharge of Biosolids to Land (Provision VI.C.5.f)

This provision requires the Permittee to comply with the State's regulations relating to the discharge of biosolids to the land. The discharge of biosolids through land application is not regulated under this Order.

The Permittee does not currently discharge biosolids to land, but should discharge be necessary, the Permittee will have to comply with this provision.

6. Other Special Provisions - Stormwater

Currently, the Discharge is exempted from Stormwater permitting requirements based on a WWTF flow of less than 1.0 mgd. However, this provision requires the Permittee, to implement best management practices relating to industrial stormwater activities at the facility. Currently, the Discharge is exempted from these requirements based on a WWTF flow of less than 1.0 mgd.

7. Compliance Schedules

This section does not apply to the City of Ferndale Wastewater Treatment Facility.

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, North Coast Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the City of Ferndale Wastewater Treatment Facility. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Permittee and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through posting on the Regional Water Board's Internet

site http://www.waterboards.ca.gov/northcoast/public_notices/public_hearings/npdes_permits_and_wdrs.shtml and through publication in the Times Standard on September 15, 2012.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments must be received at the Regional Water Board offices by 5:00 p.m. on October 12, 2012.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: December 6, 2012
Time: 8:30 AM
Location: Regional Water Board Office, Board Hearing Room
5550 Skylane Boulevard, Suite A
Santa Rosa, CA 95403

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/northcoast> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (ROWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling 707-576-2220.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Lisa Bernard at (707) 576-2677 or Lisa.Bernard@waterboards.ca.gov.