

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

ORDER NO. 80-36

NPDES PERMIT NO. CA0005738

AMENDMENT OF WASTE DISCHARGE REQUIREMENTS
(ORDER NO. 79-156) FOR:

COLGATE-PALMOLIVE COMPANY
BERKELEY, ALAMEDA COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region, (hereinafter Board) finds that:

1. Colgate-Palmolive Company, hereinafter the discharger, submitted letters dated March 21 and May 6, 1980, requesting a minor change in their effluent limitations as adopted by the Board November 20, 1979, in Order No. 79-156.
2. The proposed addition of "soap manufacturing by batch kettle" will change the character and volume of waste 001, primarily cooling water, by the addition of 0.03 million gallons per day (mgd) to the existing average flow of 0.73 mgd and 0.08 mgd to the existing maximum flow of 2.5 mgd. No significant changes to beneficial uses of San Francisco Bay and contiguous waters is expected from this minor change.
3. The Board has notified the discharger and interested agencies and persons of its intent to amend waste discharge requirements for the existing discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.
4. The amendment of waste discharge requirements for this discharge is exempt from the provisions of Chapter 3 (commencing with Section 21000) of Division 13 of the Public Resources Code in accordance with Water Code Section 13389.
5. The Board in a public meeting heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that the Regional Board amends Order No. 79-156 to read as follows:

Finding No. 2.a. is amended to read:

- "a. Waste 001 consists of an average of 0.76 million gallons per day (mgd) and a maximum of 2.6 mgd of waste resulting from soap manufacturing by batch kettle and glycerine concentration and distillation. The waste is discharged via a storm drain in Bolivar Drive to San Francisco Bay at the foot of Potter Street. Occasionally, for maintenance purposes, the City of Berkeley directs the flow into Aquatic Park Lagoon, a water of the United States."

Effluent Limitation for waste #001 is amended to read:

"A. Effluent Limitations

1. The discharge of an effluent containing constituents in excess of the following limits is prohibited:

<u>Discharge Serial #</u>	<u>Constituent</u>	<u>Units</u>	<u>30-Day Average</u>	<u>Maximum Daily</u>
001	*BOD ₅	lbs/day	57	171
		kg/day	26	78
	*COD	lbs/day	156	468
		kg/day	71	212
	*Total sus- pended solids	lbs/day	26	76
		kg/day	12	35
	*Oil & Grease	lbs/day	8	23
		kg/day	4	11
	Settleable Solids	ml/l-hr	0.1	0.5

*Limits on these parameters are incremental over intake."

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on August 5, 1980.

FRED H. DIERKER
Executive Officer