CALIFORNIA REGIONAL WATER
AUG 06 2012
QUALITY CONTROL BOARD

**ACCEPTANCE OF CONDITIONAL RESOLUTION AND WAIVER OF RIGHT TO HEARING**

By signing below and returning this Acceptance of Conditional Resolution and Waiver of Right to Hearing (Acceptance and Waiver) to the Regional Water Quality Control Board (Regional Water Board), the Atlantic Richfield Company (ARCO) hereby accepts the "Offer to Participate in Expedited Payment Program" and waives the right to a hearing before the Regional Water Board to dispute the allegations of violations described in the Notice of Violation which is attached hereto as Exhibit A and incorporated herein by reference.

ARCO agrees that the attached Exhibit A shall serve as a complaint pursuant to Article 2.5 of the California Water Code (CWC) and that no separate complaint is required for the Regional Water Board to assert jurisdiction over the alleged violations through its Assistant Executive Officer. ARCO agrees to pay the penalties authorized by CWC section 13385, which shall be deemed payment in full of any civil liability pursuant to the CWC sections 13385 and 13385.1 that otherwise might be assessed for the violations described in the attached Exhibit A.

ARCO understands that this Acceptance and Waiver does not address or resolve liability for any violation that is not specifically identified in the attached Exhibit A.

Upon execution by ARCO, the Acceptance and Waiver shall be returned to:

Expedited Payment Program
California Regional Water Quality Control Board
San Francisco Bay Region
NPDES Enforcement Section, Regulatory Measure ID No. 381860
Attention: Farhad Azimzadeh
1515 Clay Street, Suite 1400
Oakland, California 94612

ARCO understands that federal regulations set forth at title 40, Code of Federal Regulations, section 123.27(d)(2)(iii) require the Regional Water Board to publish notice of and provide at least 30 days for public comment on any proposed resolution of an enforcement action. Accordingly, this Acceptance and Waiver, prior to execution by the Executive Officer of the Regional Water Board, will be published as required by law for public comment.

If no comments are received within the notice period which causes the Executive Officer of the Regional Water Board to reconsider the Expedited Payment Amount, the Executive Officer will execute the Acceptance and Waiver. Resolution of these violations by the Regional Water Board will preclude State Water Board action for these same violations.

ARCO understands that if significant comments are received in opposition to the Expedited Payment Amount, the offer on behalf of the Regional Water Board to resolve the violations set forth in the attached Exhibit A may be withdrawn. In that circumstance, ARCO will be advised of the withdrawal and an administrative civil liability complaint may be issued and the matter may be set for a hearing before the Regional Water Board or the State Water Board. For such a liability hearing, ARCO understands that this Acceptance and Waiver executed by ARCO will be treated as a settlement communication and will not be used as evidence in that hearing.

ARCO understands that once the Acceptance and Waiver is executed by the Executive Officer of the Regional Water Board, payment of the amount in full no later than 30 days after the date of the Executive Officer's signature is a condition of this Acceptance and Waiver. ARCO must submit its payment in full by check made out to "California Regional Water Quality Control Board" and sent to the address indicated above, together with a copy of this Acceptance and Waiver after execution by the Executive Officer.

I hereby affirm that I am duly authorized to act on behalf of and to bind ARCO in the making and giving of this Acceptance and Waiver.

Atlantic Richfield Company

By: _____ Aug 2, 2012
(Signed Name) (Date)

John C. Skance
(Printed or typed name)

Strategy Manager - Remediation Management
(Title)

IT IS SO ORDERED (R2-2012-0056) PURSUANT TO CALIFORNIA WATER CODE SECTION 13385

Digitally signed by Bruce H. Wolfe
Date: 2012.09.11 17:43:20 -07'00'

By: _____

Bruce H. Wolfe
Executive Officer
Regional Water Quality Control Board

**Note to ARCO: Please return the signed waiver with Exhibit A, together.**

Regulatory Measure ID: 381860

**EXHIBIT A**
**Notice of Violation**

Atlantic Richfield Company
ARCO Service Station #5384
Located at 545 West Alma Avenue, San Jose, Santa Clara County, CA 95110

Mandatory Minimum Penalties without Regional Water Quality Control Board Hearing

The following table lists this facility's alleged permit exceedance of California Water Code (CWC) Sections 13385(h) and 13385(i) for which the Water Board has not assessed a mandatory minimum penalty. Final calculation of MMP amounts owed, and descriptions of the abbreviations that appear in the table are also listed in the table below.

| No | CIWQS Violation ID No. | Date of Occurrence | Effluent Limitation Description (Unit) | Effluent Limit | Reported Value | Percent a Group I or Group II Pollutant is over Effluent Limitation | Type of Exceedance | CWC Section 13385(h) and/or (i) Required MMP |
|---|---|---|---|---|---|---|---|---|
| 1 | 925072 | 11/27/2007 | TPHd (µg/L) | 50 | 63 | 26% | C1, S | $3,000 |
| | | | | | | | **Total** | **$3,000** |

**Legend for Table:**
CIWQS = California Integrated Water Quality System database used by the Water Boards to manage violation and enforcement activities.
Violation ID = Identification number assigned to a permit exceedance in CIWQS.
CWC = California Water Code.
C = Count – The number that follows represents the number of exceedances ARCO has had in the past 180 days, including this violation. A count greater than three (> C3) means that a penalty under CWC Section 13385(i) applies.
S = Serious, which means that a penalty under CWC Section 13385(h) applies when an effluent limitation is exceeded 40% or more for a Group I pollutant or 20% or more for a Group II pollutant.

Regulatory Measure ID: 381860
Place ID: 655531