

Attachment C

ATTACHMENT C: Spill Table (January 1, 2001 through September 30, 2008)

Sewerage Agency Of Southern Marin
 ACL Complaint No. R2-2008-0070
 Treatment Plant/Sewer Overflows

No.	Date	Location	Gallons Discharged	Gallons Recovered	Overflow Destination	Cause
1	12/27/04	Miller Ave. Mill Valley MH # AR6	6,000	0	Pickleweed Inlet	Extreme weather conditions/I&I and incomplete cleaning project (contractor's equipment failed)
2	12/27/04	Almonte Blvd & Wisteria Lane, Mill Valley MH# A11	1,200	0	Pickleweed Inlet	Extreme weather conditions/I&I and incomplete cleaning project (contractor's equipment failed)
3	12/27/04	Almonte Blvd north of Shoreline Highway MH #A24	600	0	Pickleweed Inlet	Extreme weather conditions/I&I and incomplete cleaning project (contractor's equipment failed)
4	12/30-31/2005	Equalization Pond	1,400,000	0	Pickleweed Inlet	Extreme weather conditions. A state of emergency was declared in Marin County due to wide spread flooding.
5	1/25/2008	Equalization Pond	2,450,000	0	Pickleweed Inlet	Large winter storm.
6	1/31/2008	Wastewater Treatment Plant	961,000	500	Some captured on paved surface	Storm/inadequate number of pumps functioning to handle flows/alarm error.
Total Gallons			4,818,800	500		