

## Response to Comments

United States Navy  
San Clemente Island Wastewater Treatment Plant  
Revised Tentative WRR/WDR

This Table describes all significant comments received from interested persons with regard to the above-mentioned tentative permit. Each comment has a corresponding response and action taken.

Commenter	#	Comment	Response	Action Taken
<b>Comments received from the United States Navy on April 13, 2015</b>				
United States Navy	1	Page 4, Section II.2 and Page 11, Section IX.9.D.ii. The Navy is currently approved for soil compaction. Please remove "grading" from Sections II.2. and IX.9.D.ii. as to not exclude soil compaction activities.	Staff agreed to the proposed changes.	Revisions were made to the permit.
United States Navy	2	Page 10, Section VIII.6. Please delete Section VIII.6 "Reclaimed water shall not contain trace constituents or other substances in concentrations exceeding the limits contained in the current edition of DDW's Drinking Water Standards." consistent with Section IV.3. "The approved and potential future uses of the recycled water from the SCI WWTP are not expected to cause significant infiltration of the recycled water to the groundwater basin. As a result, this Order does not include effluent limits for the protection of groundwater for municipal use or monitoring associated with municipal use."	Staff agreed to the proposed changes.  As noted by the discharger, the uses of recycled water on the island are not expected to result in significant groundwater infiltration. In addition, no groundwater has been detected on the island.	Revisions were made to the permit.
United States Navy	3	Page 13, Section XI.3. Revise this section, consistent with Title 22 CCR Section 60301.230, by inserting "median total coliform concentration of" so full section reads: Section XI.3 "In addition to meeting the disinfection requirements	This section has been revised to be consistent with Title 22 CCR Section 60301.230.	Revisions were made to the permit.

Committer	#	Comment	Response	Action Taken
		for secondary-23 recycled water (section XI.1), the median total coliform concentration of disinfected tertiary-treated recycled water shall also not exceed an MPN of 2.2 per 100 mL utilizing the bacteriological results of the last seven days for which analyses have been completed.”		