



**California Regional Water Quality Control Board  
Central Valley Region  
Katherine Hart, Chair**



**Matthew Rodriguez**  
Secretary for  
Environmental Protection

11020 Sun Center Drive, #200, Rancho Cordova, California 95670-6114  
(916) 464-3291 • FAX (916) 464-4645  
<http://www.waterboards.ca.gov/centralvalley>

**Edmund G. Brown Jr.**  
Governor

2 September 2011

Will Dickinson, Deputy Director  
Placer County Facility Services Department  
11476 C Avenue  
Auburn, CA 95603

CERTIFIED MAIL NO.  
7010 1670 0002 0652 5204

**MINOR MODIFICATIONS TO PLACER COUNTY DEPARTMENT OF FACILITY SERVICES,  
SEWER MAINTENANCE DISTRICT NO. 3, WASTE DISCHARGE REQUIREMENTS ORDER  
R5-2007-0070 (NPDES NO. CA0079367); PLACER COUNTY**

Central Valley Regional Water Quality Control Board (Central Valley Water Board) staff has noted several typographical errors in Waste Discharge Requirements (WDR) Order R5-2007-0070 for the Placer County Sewer Maintenance District No. 3.

Pursuant to Code of Federal Regulations, 40 CFR Section 122.63(a), minor modification of an NPDES permit is allowed to correct typographical errors. The mass effluent limitation for dichlorobromomethane and dibromochloromethane have been corrected as shown in underline/strikeout format in the following table. This change was consistently made in the tables in WDR Order R5-2007-0070 at section IV.A.1.a of the Limitations and Discharge Requirements, and sections IV.C.4.a and IV.D.1 of the Fact Sheet:

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Dichlorobromomethane	µg/L	0.56	--	1.13	--	--
	lbs/day <sup>1</sup>	<del>1.40</del> <u>0.00140</u>	--	<del>2.83</del> <u>0.00283</u>	--	--
Dibromochloromethane	µg/L	0.41	--	0.82	--	--
	lbs/day <sup>1</sup>	<del>1.03</del> <u>0.00103</u>	--	<del>2.05</del> <u>0.00205</u>	--	--

This letter serves as notification that the following minor modifications are made to WDR Order R5-2007-0070. You may download the corrected Order from the Central Valley Water Board's internet website at [http://www.waterboards.ca.gov/centralvalley/board\\_decisions/tentative\\_orders/](http://www.waterboards.ca.gov/centralvalley/board_decisions/tentative_orders/).

If you have any questions regarding this item, please contact Elizabeth Thayer at (916) 464-4671 or ethayer@waterboards.ca.gov.

*Original signed by*

Pamela C. Creedon  
Executive Officer

cc: Dave Smith, U.S. Environmental Protection Agency, Region IX, San Francisco US Army Corp of Engineers, Sacramento  
US Fish and Wildlife Service, Sacramento  
Phil Isorena, State Water Resources Control Board, Sacramento (w/enclosures)  
Department of Water Resources, Central District, Sacramento  
State Office of Historical Preservation, Sacramento  
Office of Drinking Water, Department of Public Health, Sacramento  
Department of Public Health, Environmental Management Branch, Sacramento  
Regional Manager, Department of Fish & Game, Region II, Rancho Cordova  
Bill Jennings, California Sportfishing Protection Alliance, Stockton

Will Dickinson, Deputy Director  
Placer County Department of Facility Services  
Sewer Maintenance District No. 3

-3-

2 September 2011