

LATE REVISIONS – 1 December 2011

- Item 12.** CITY OF ATWATER, ATWATER REGIONAL WASTEWATER TREATMENT FACILITY, MERCED COUNTY – Consideration of new Waste Discharge Requirements and new NPDES permit (NPDES No. CA0085308)

Attachment F – Fact Sheet, Section IV.D.1.a.

Page F-39, modify the last paragraph of Section IV.D.1.a. as follows:

~~For salinity, the Central Valley Water Board is considering limiting effluent salinity of municipal wastewater treatment facilities to an increment of 500 μ mhos/cm over the salinity of the municipal water supply as representing best practicable treatment or control. This Order requires the Discharger to monitor its municipal water supply for EC and total dissolved solids.~~