

LATE REVISIONS – 1/2 December 2011

ITEM 16 – UNCONTESTED WASTE DISCHARGE REQUIREMENTS

***Item 16 CITY OF PLYMOUTH, PLYMOUTH WASTEWATER TREATMENT FACILITY,
AMADOR COUNTY- CONSIDERATION OF WASTE DISCHARGE
REQUIREMENTS (REVISION)***

WASTE DISCHARGE REQUIREMENTS:

Page 6 Revise Finding 22 as follows:

The water balance provided in the RWD demonstrates that the WWTF has capacity for a monthly average dry weather wastewater inflow rate of 0.185 mgd, a maximum monthly inflow rate of 0.261 mgd, and annual total wastewater inflow rate of ~~76.3~~ **82.5** million gallons based on a 100-year return period 365-day precipitation event.

Formatted: No underline