

LATE REVISIONS – 6 June 2014

Item 19 United States Department of the Interior, National Park Service, Yosemite National Park, El Portal Wastewater Treatment Facility, Mariposa County
Consideration of NPDES Permit Renewal (NPDES CA0081759) and Rescission of Time Schedule Order R5-2011-0906

NPDES Order

Page 18 Revise Special Provision VI.C.4.e.vii. as follows:

- vii. By **<180 days from the effective date>**, the Discharger shall submit a biosolids use or disposal plan to the Central Valley Water Board. The plan shall describe at a minimum:
 - (a) Sources and amounts of biosolids generated annually.
 - (b) Location(s) of on-site storage and description of the containment area and containment features. The description shall include the Discharger's means of complying with Provisions VI.C.4.~~d.e.~~ and the expected date the Discharger plans to begin applying sludge to the lined sludge drying beds.

Monitoring and Reporting Program

Page E-9 Revise Section V.B.8.b. as follows:

- b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in Table 6 on page 52 of the Method Manual. A retest is only required in this case if the test results do not exceed the monitoring trigger specified in Special Provision VI.C.2.a.~~ii.~~ of this Order.

Fact Sheet

Page F-12 Revise Section IV.C.1. as follows:

1. Scope and Authority

CWA Section 301(b) and 40 C.F.R. 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. This Order contains requirements, expressed as a technology equivalence requirement, more stringent than secondary treatment requirements that are necessary to meet applicable water quality standards. The rationale for these requirements, which consist of tertiary treatment, is discussed in section IV.C.3.c.~~ii.~~ of this Fact Sheet.

Page F-16 Revise Section IV.C.2.c. as follows:

The allowance of a mixing zone and dilution credits is a discretionary act by the Central Valley Water Board. The Central Valley Water Board has determined that the maximum dilution credit on a constituent-by-constituent basis needed for this discharge is as shown in the following table (also discussed further in section IV.C.3.~~d.c.~~).