



June 30, 2014

Main Office

10060 Goethe Road
Sacramento, CA 95827-3553
Tel: 916.876.6000
Fax: 916.876.6160

James Marshall
Water Resources Control Engineer
Central Valley Regional Water Quality Control Board
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670

Treatment Plant

8521 Laguna Station Road
Elk Grove, CA 95758-9550
Tel: 916.875.9000
Fax: 916.875.9068

Subject: Comments on the Tentative Order Amending the Waste Discharge Requirements for Sacramento Regional Wastewater Treatment Plant

Dear Jim:

Board of Directors

- Representing:
- County of Sacramento
- County of Yolo
- City of Citrus Heights
- City of Elk Grove
- City of Folsom
- City of Rancho Cordova
- City of Sacramento
- City of West Sacramento

At its August 7-8, 2014 meeting, the Central Valley Regional Water Quality Control Board (Central Valley Water Board) will consider adoption of an order amending filtration and related requirements of Order R5-2010-0111-02. Sacramento Regional County Sanitation District (Regional San) proposes that the Central Valley Water Board consider the following two additions to the proposed amendment and that approval of the amendment incorporate these additions:

ADDITION 1. UPDATE OF SEASONAL OPERATIONS PLAN

In Section VI.C.7.a, at the end of footnote 2 add to the compliance schedule (on page 36), as follows.

This plan will be periodically updated, as necessary, based on accumulated operating data and experience.

ADDITION 2. STUDY OF FILTRATION OPERATIONS

Add a new special study in Section VI.C.2.f (on page 32), as follows:

f. Treatment Plant Operations Study. After a sufficient degree of operational experience following commencement of operation of filtration facilities as designed, built and operated, including at least three years of circumstances described in the Future Facility description in Section II.A.2 of the Fact Sheet where some BNR effluent does not receive filtration, a study of November-April performance of the filtration and disinfection system will be required of the Discharger. The study, to be conducted at a time determined by the Central Valley Regional Water Control Board, will summarize data including the amount (on a daily basis and annual basis) of effluent that did not receive filtration, influent and effluent flows, filter effluent turbidity, filter loading rates, effluent giardia and cryptosporidium data, and effluent E.coli and total coliform data.

Prabhakar Somavarapu
District Engineer

Ruben Robles
Director of Operations

Christoph Dobson
Director of Policy & Planning

Karen Stoyanowski
Director of Internal Services

Joseph Maestretti
Chief Financial Officer

Claudia Goss
Public Affairs Manager

www.srcsd.com

James Marshall


June 30, 2014

Page 2

Prior to the release of the proposed order, I informed representatives of the California Department of Public Health (CDPH) that additions of this sort would not be of concern to Regional San. Since that time, specific language has been prepared in concurrence with CDPH, and I confirm that Regional San has no objection to inclusion of these additions in the amended order.

Thank you for your consideration.

Sincerely,



Prabhakar Somavarapu

District Engineer

cc: Ken Landau, Central Valley Regional Water Quality Control Board
Kathleen Harder, Central Valley Regional Water Quality Control Board
Paul Simmons, Somach Simmons Dunn
Christoph Dobson, Regional San
Dave Ocenosak, Regional San
Robert Seyfried, Regional San
Ruben Robles, Regional San
Vyomini Upadhyay, Regional San