

## Marshall, James@Waterboards

---

**From:** Seyfried, Robert (SDA) <seyfriedr@sacsewer.com>  
**Sent:** Wednesday, June 18, 2014 2:53 PM  
**To:** Marshall, James@Waterboards; Harder, Kathleen@Waterboards  
**Cc:** Somavarapu, Prabhakar (SDA); Dobson, Christoph (SDA); Ocenosak, David (SDA); Upadhyay, Vyomini (SDA); psimmons@somachlaw.com; Brittany Lewis-Roberts  
**Subject:** Minor edits on the 2 Tentative Orders for Regional San

Jim and Kathy:

We have reviewed Attachment 1 (Tentative Order) and identified 2 minor errors or omissions:

1. Section II, B, pg-6- Facility Description: 3<sup>rd</sup> paragraph, "The CAP is to address elevated constituent concentrations that were observed in samples from groundwater monitoring wells down gradient of the ~~Dedication~~ **Dedicated** Land Disposals areas (DLDs)"
2. Factsheet, pg F-81, Pathogens: " Unfiltered BNR effluent and filtered wastewater would be combined and disinfected with chlorine **and dechlorinated** prior to discharge to the Sacramento River."

### Robert Seyfried

#### Senior Civil Engineer

*Sacramento Regional County Sanitation District &  
Sacramento Area Sewer District*

10060 Goethe Road, Sacramento, CA 95827

(916) 876-6068 Office

(916) 591-1646 Cell

[seyfriedr@sacsewer.com](mailto:seyfriedr@sacsewer.com)



---

#### EMAIL DISCLAIMER:

This email and any attachments thereto may contain private, confidential, and privileged material for the sole use of the intended recipient. Any review, copying, or distribution of this email (or any attachments thereto) by other than the intended recipient is strictly prohibited.

If you are not the intended recipient, please contact the sender immediately and permanently delete the original and any copies of this email and any attachments thereto.

---