

Central Valley Regional Water Quality Control Board  
16/17 April 2015 Board Meeting

Staff Revisions on  
Tentative Order to Amend Time Schedule Order No. R5-2010-0058 for  
Paradise Irrigation District  
Paradise Water Treatment Plant  
Butte County

---

At a public hearing scheduled for 16/17 April 2015, the Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board) will consider adoption of a tentative order to amend Time Schedule Order No. R5-2010-0058. This document explains staff revisions that have been made to the tentative order:

---

**Central Valley Water Board Modifications to Tentative Order**

---

Water Board staff has made the following modifications to the tentative order:

1. Attachment 1, Time Schedule Order No. R5-2010-0058-01, Page 5, Finding 21. This finding was modified to include the following language: "However, in this case, based on professional judgment, and evaluation of facility performance, the interim limit for aluminum was not set at the maximum detected concentration of 3600 ug/L but was set at 790 ug/L which corresponds to the second highest detected concentration and is more representative of the expected variability of the effluent." The tables on pages 6 and 7 were also revised to show an interim limitation of 790 ug/L for aluminum.