

LATE REVISIONS
Olivehurst Public Utility District
Wastewater Treatment Facility
YUBA COUNTY

NPDES Permit Renewal (NPDES No. CA0077836)
Regional Water Quality Control Board, Central Valley Region
Board Meeting – 18 February 2016
ITEM #10

Item #10. NPDES Permits

Olivehurst Public Utility District, Wastewater Treatment Facility, Yuba County, (NPDES Permit CA0077836)

LATE REVISIONS

Late Revisions recommended for the above mentioned NPDES permit renewal:

Table F-10. Salinity Water Quality Criteria/Objectives

Amend Table F-10 and footnotes as shown in underline/strikeout format below:

Parameter	Agricultural WQ Objective ¹	Secondary MCL ^{2,3}	USEPA NAWQC	Effluent	
				Average ⁴³	Maximum
EC (µmhos/cm)	Varies	900, 1600, 2200	N/A	694	875
TDS (mg/L)	Varies	500, 1000, 1500	N/A	112	138
Sulfate (mg/L)	Varies	250, 500, 600	N/A	23	28
Chloride (mg/L)	Varies	250, 500, 600	860 1-hr 230 4-day	455	513

- ¹ Narrative chemical constituent objective of the Basin Plan. Procedures for establishing the applicable numeric limitation to implement the narrative objective can be found in the Policy for Application of Water Quality, Chapter IV, Section 8 of the Basin Plan., However, the Basin Plan does not require improvement over naturally occurring background concentrations. In cases where the natural background concentration of a particular constituent exceeds an applicable water quality objective, the natural background concentration will be considered to comply with the objective.
- ² The secondary MCLs are stated as a recommended level, upper level, and a short-term maximum level.
- ³ The secondary MCL objectives are specified as TDS or EC in addition to sulfate and chloride per the Basin Plan.
- ⁴³ Maximum calendar annual average.