

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 76-61

WASTE DISCHARGE REQUIREMENTS
FOR
MITCHELL CAMP DEVELOPMENT CORPORATION
Palo Verde - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Mitchell Camp Development Corporation (hereinafter also referred to as the discharger), P. O. Box 111, Palo Verde, California 92266, submitted a Report of Waste Discharge dated April 7, 1976.
2. The discharger is discharging an average of 13,020 gallons-per-day of domestic sewage from a travel trailer park having a total of 62 trailer spaces and 10 cabins. The proposed development of this 46.5 acre park (with frontage on the Colorado River), is a maximum of 157 trailer spaces and 45 cabin sites. The wastewater is discharged through septic tanks into an oxidation pond located in the NE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T10S, R21E, SBB&M.
3. The discharge of this travel trailer park has been subject to waste discharge requirements adopted in Board Resolution No. 66-15.
4. The Water Quality Control Plan for the East Colorado River Basin was adopted by the Board on April 10, 1975, and this Order implements the objectives stated in the Plan.
5. The beneficial uses of the groundwaters of the Colorado Hydrologic Unit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
6. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.

*Superseded
by 84-57
5/16/84*

7. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall cause a pollution or a nuisance.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. A minimum depth of freeboard of at least two feet shall be maintained in the earthen basins.
4. Basins from which wastewater may infiltrate shall not be located within 200 feet laterally of any water supply well.
5. There shall be no discharge of sewage within 200 feet of the Colorado River.
6. Adequate protective works shall be provided to assure that flood or surface drainage waters do not erode or otherwise render the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the discharge facilities.
8. Disposal by ponding shall be conducted in such a manner that there shall be no stranded or exposed sewage solids.
9. Septic tank cleanings shall be discharged only by a duly authorized service.
10. There shall be no discharge of water softener brines.
11. Facilities shall be available to handle wastewater in the event of commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report thereon to the Board.



2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. In the event of any change in operation, or in control or ownership of land and/or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify this Board of such change; and
 - b. Notify the succeeding owner or operator by letter of the existence of this Order, a copy of which shall be filed with this Board.
4. This Order supersedes Board Resolution No. 66-15.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 18, 1976.



Executive Officer

To Blythe ↑ 26 miles



Scale:

1" = 1 mile

SITE MAP

MITCHELL CAMP DEVELOPMENT CORPORATION
Palo Verde - Imperial County
NE $\frac{1}{4}$ of NW $\frac{1}{4}$ of Section 23, T10S, R21E, SBB&M
U.S.G.S. Cibola 15 min. Topographic Map

Order No. 76-61