

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 77-60

WASTE DISCHARGE REQUIREMENTS
FOR
PILOT KNOB CAMPGROUND
West of Winterhaven - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Robert J. Bryson (hereinafter also referred to as the discharger), 3707 West Hwy. 80, Winterhaven, CA 92283, submitted a Report of Waste Discharge dated June 11, 1977.
2. The discharger is discharging a maximum of 8,500 gallons-per-day of domestic sewage from a travel trailer park having 57 trailer spaces, 2 restrooms, and a laundry room. The wastewater is discharged through a septic tank/leach field disposal system located in the SW $\frac{1}{4}$ of Section 21, T16S, R21E, SBB&M.
3. The discharge of this travel trailer park has been subject to waste discharge requirements adopted in Board Order No. 72-31. The discharger states that there has been no significant change in the discharge. The discharge site is located in an isolated desert area where there is more than sufficient space for expansion of the subsurface disposal system.
4. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Amos-Ogilby Hydrologic Unit.
5. The beneficial use of the groundwaters of the Amos-Ogilby Hydrologic Unit is agricultural supply.
6. The discharger reports that wastewater from a swimming pool is used for irrigation of landscape plantings.
7. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

*Revised
9/22/82
42-36*

8. The Board in a public meeting heard and considered all comments pertaining to the discharge.
9. This travel trailer park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et seq.) and the State Guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:


A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in the California Water Code.
2. No wastewater other than domestic sewage and wastewater from a swimming pool shall be discharged at this location.
3. Sewage effluent discharged subsurface shall be retained underground with no materials of sewage origin evident on the ground surface.
4. There shall be no discharge of sewage within 200 feet of any water supply well.
5. Adequate protective works shall be provided to assure that flood or surface drainage waters do not erode or otherwise render portions of the treatment and discharge facilities inoperable.
6. Septic tank cleanings shall be discharged only by a duly authorized service.


B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report thereon to the Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. In the event of any change in operations, or in control or ownership of land and/or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify this Board of such change; and
 - b. Notify the succeeding owner or operator by letter of the existence of this Order, a copy of which shall be filed with this Board.
4. This Order supersedes Board Resolution No. 72-31.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on Sept. 21, 1977.


Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP
PILOT KNOB CAMPGROUND
West of Winterhaven - Imperial County
SW $\frac{1}{4}$, Section 21, T16S, R21E, SBB&M
Ogilby and Yuma 15' Topographic Maps

Order No. 77-60