

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 81-28

WASTE DISCHARGE REQUIREMENTS
FOR
DESERT GARDENS MOBILEHOME PARK
Southeast of Desert Hot Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Desert Gardens Mobilehome Park (hereinafter also referred to as the discharger), 4716 Vineland Street, North Hollywood, CA 91602, submitted a Report of Waste Discharge, dated March 31, 1980.
2. The discharger proposes to discharge a maximum of 45,000 gallons per day of domestic sewage from a mobile home park designed to have 179 spaces. Wastewater would be disposed of by means of septic tank/seepage pit disposal systems to be located in the SE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 11, T3S, R5E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).
5. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
6. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
7. The Board has notified the discharger and interested persons of its intent to prescribe waste discharge requirements for the proposed discharge.

*Reconsidered
by
87-37
03/18/87*

8. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
9. The Riverside County Board of Supervisors has approved Negative Declaration EA No. 13250 (filing date October 14, 1980) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.



4. Prior to any change of ownership of this mobile home park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the development, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this development is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region on January 28, 1981.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1" = 2,000'

SITE MAP
DESERT GARDENS MOBILEHOME PARK
Southeast of Desert Hot Springs - Riverside County
SE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 11, T3S, R5E, SBB&M
Seven Palms Valley 7.5 min. Topographic Map

Order No. 81-28