

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 81-42

WASTE DISCHARGE REQUIREMENTS
FOR
TRACT NO. 17377
City of Palm Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. J.F. Temple Construction Company (hereinafter also referred to as the discharger), 729 Eugene Road, Palm Springs, CA 92264, submitted a Report of Waste Discharge dated December 23, 1980.
2. The discharger proposes to discharge a design flow of 87,000 gallons-per-day of domestic sewage from a 436-unit condominium complex. The wastewater is to be discharged into septic tank/seepage pit disposal systems located in the S 1/2 of the SW 1/4 of Section 34, T3S, R4E, SBB&M.
3. The discharger informs that dry sewers are to be installed along with the systems described in Finding No. 2 (above), to facilitate eventual connection to the existing sewer line on San Rafael Drive adjacent to the complex.
4. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
5. Wastewater from 4 swimming pools would be periodically discharged onto landscape plantings.
6. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 4 (above).
7. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
8. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply

Rescinded
11/28/90
90-080
-1-

Rescinded
7/17/83

9. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
10. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
11. The City of Palm Springs has approved Negative Declaration Case No. 3.395 (filing date April 24, 1981) for this proposed condominium development. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits until such time as this complex is connected to a municipal sewerage system.
2. The subsurface sewerage system should be designed and constructed to facilitate possible connection to the City of Palm Springs sewerage system when capacity is available.

3. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
4. Prior to any change of management or ownership of the sewage collection and disposal system (such as to a homeowner's association), the discharger shall:
 - a. Specify as a condition of transfer that the area utilized for sewage collection and disposal, and replacement thereof as set forth in Provision B.1. (above), remain servient to the development until such time as this development is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin, on May 20, 1981.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 81-42
FOR
PALM SPRINGS VILLAS II
Palm Springs - Riverside County**

Location: Portion of the S $\frac{1}{2}$ of the SW $\frac{1}{4}$ of Section 34, T3S, R4E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of condominiums presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:



California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:

Arthur Swajian
Executive Officer

August 12, 1987
Date



Scale:
1" = 2,000'

SITE MAP
TRACT NO. 17377
City of Palm Springs - Riverside County
S 1/2 of the SW 1/4 of Section 34, T3S, R4E, SBB&M
USGS Palm Springs 7.5 min. Topographic Map

Order No. 81-42