

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 82-17

WASTE DISCHARGE REQUIREMENTS
FOR
SILVER SANDS MOBILE HOME ESTATES
Southeast of Desert Hot Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Barney and Eva Helser (hereinafter also referred to as the discharger), Route 1, Box 276-L, Oceanpark, WA 98640, submitted a Report of Waste Discharge dated August 21, 1981.
2. The discharger proposes to discharge a maximum of 34,000 gallons-per-day of domestic sewage from a mobile home park designed to have 125 mobile home spaces and a recreation building. Wastewater would be disposed of by means of septic tank/seepage pit disposal systems to be located in the NW 1/4 of the SW 1/4 of Section 16, T3S, R5E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).
5. Wastewater from a swimming pool and a hot pool would be periodically discharged into a separate seepage pit.
6. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
7. The beneficial uses of the groundwater of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.

Recorded
11/28/90
90-080

9. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
10. The Riverside County Planning Department has approved Negative Declaration CU No. 2542 (filing date September 10, 1981) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming pool and hot pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool and hot pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

4. Prior to any change of ownership of this mobile home park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the development, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this development is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin, on March 24, 1982.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 82-17
FOR
SILVER SANDS MOBILE HOME ESTATES
Southeast of Desert Hot Springs - Riverside County**

Location: Portion of the NW $\frac{1}{4}$, SW $\frac{1}{4}$ of Section 16, T3S, R5E, SBB&M

MONITORING

This discharger shall submit an annual status report on the following:

1. Number of spaces presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Immediate reporting of any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

ORDERED BY:

Arthur Levajian
Executive Officer

July 20, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1" = 2,000'

SITE MAP
SILVER SANDS MOBILE HOME ESTATES
Southeast of Desert Hot Springs - Riverside County
Portion of NW 1/4, SW 1/4 of Section 16, T3S, R5E, SBB&M
USGS Seven Palms Valley 7.5 min. Topographic Map

Order No. 82-17