

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

ORDER NO. 83-104

WASTE DISCHARGE REQUIREMENTS  
FOR  
RIVER SHORE ESTATES  
Northeast of Earp - San Bernardino County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Walter L. McDade (hereinafter also referred to as the discharger), P. O. Box 114, Earp, California 92242, verified on August 27, 1983, that the information contained in Findings No. 3 and 4, below are accurate.
2. The discharge from this mobile home park has been subject to waste discharge requirements adopted in Board Order No. 73-17.
3. The discharger is discharging a maximum of 37,000 gallons-per-day of domestic sewage from a mobile home park consisting of 186 mobile home spaces, a laundry room and two restrooms. Wastewater is discharged into oxidation basins (for disposal by infiltration and evaporation) located in the NW $\frac{1}{4}$  of the NE $\frac{1}{4}$  of Section 10, T1N, R26E, SBB&M.
4. There are no domestic wells within 500 feet of the sewage disposal facility described in Finding No. 2.
5. The Water Quality Control Plan for the East Colorado River Basin Region was adopted on April 10, 1975. The Basin Plan contains water quality objectives for the Colorado Hydrologic Unit.
6. The beneficial uses of the ground water of the Colorado Hydrologic Unit are:
  - a. Municipal supply
  - b. Industrial supply
  - c. Agricultural supply
7. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
8. The Board in a public meeting heard and considered all comments pertaining to the discharge.
9. This sewage disposal facility constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State Guidelines because

*Change of Ownership  
5/12/88  
Lynn Bradley*

*Approved  
89-002  
1/25/89*

the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. A minimum freeboard depth of at least two feet shall be maintained in each basin.
4. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
5. Adequate protective works shall be provided to assure that a flood which would be expected to occur on a frequency of once in a 100 year period, would not erode or otherwise render portions of the treatment and discharge facilities inoperable.
6. Treated or untreated sludge, or similar solid waste materials, shall not be discharged to or enter any drainage channels or Colorado River.
7. There shall be no surface flow of wastewater away from the discharge facilities, and there shall be no direct discharge to any drainage channel or to Colorado River.
8. Treatment and disposal by ponding shall be conducted in such manner that there shall be no stranded or exposed sewage solids.
9. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
10. Infiltration facilities shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater.
11. Standby power and pumping facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any

material change in location of discharge, the discharger shall report in writing to the Regional Board.

2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of any change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:
  - a. Notify the Board of such change; and
  - b. Notify the succeeding owner or operator by letter of the existence of this Order, a copy of which shall be filed with this Board.
4. This Order supersedes Board Order No. 73-17.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 16, 1983.

  
\_\_\_\_\_  
Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 83-104  
FOR  
RIVER SHORE ESTATES  
Northeast of Earp - San Bernardino County**

Location of Discharge: NW $\frac{1}{4}$  of NE $\frac{1}{4}$  of Section 10, T1N, R26E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of mobile home and RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260


2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.

ORDERED BY:

*Arthur Sevajian*  
Executive Officer

*Jan. 26, 1988*  
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:  
1" = 1 mi.

SITE MAP

RIVER SHORE ESTATES  
 Northeast of Earp - Riverside County  
 Portion of the NW 1/4, NE 1/4 of Section 10, T11N, R26E, SBB&M  
 USGS Parker Dam Area 15 min. Topographic Map

Order No. 83-104