

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

ORDER NO. 83-109

NPDES NO. CA0104299

WASTE DISCHARGE REQUIREMENTS  
FOR  
IMPERIAL COMMUNITY COLLEGE DISTRICT  
Northeast of El Centro - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Imperial Community College District, (hereinafter also referred to as the discharger), P. O. Box 158, Imperial, California 92251, submitted an updated NPDES Application for Permit to Discharge dated September 13, 1983. Said application is assigned Application No. CA0104299.
2. The discharger presently discharges a peak month average daily flow of 52,000 gallons-per-day and a peak week average daily flow of 73,000 gallons-per-day of wastewater from an activated sludge type treatment plant, which is designed for an average daily flow of 150,000 gallons-per-day of sewage into Central Drain near the SE corner of Section 22, T15S, R14E, SBB&M. The wastewater flows 4 miles and enters Alamo River 39 miles from Salton Sea.
3. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Regional Board on April 10, 1975. The Basin Plan contains water quality objectives for Imperial Hydrologic Unit.
4. The beneficial uses of water in Alamo River, and Imperial Valley Drains discharging thereto are:
  - a. Transport of dissolved solids to Salton Sea for agricultural soil salinity control.
  - b. Freshwater replenishment for Salton Sea.
  - c. Warm freshwater habitat for fish and wildlife.
  - d. Recreation - non-water contact.
5. The issuance of waste discharge requirements for this discharge is exempt from the provisions of Chapter 3 (commencing with Section 21000, et. seq.) of Division 13 of the Public Resources Code in accordance with Water Code Section 13389.

*Replaced by  
88-113*

6. The discharge has been subject to waste discharge requirements adopted in Order No. 79-22 (NPDES No. CA0104299) which allows discharge to Central Drain.
7. The Board has notified the discharger and interested agencies and persons of its intent to update requirements for the existing discharge and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.
8. The Board in a public meeting heard and considered all comments pertaining to the discharge.
9. This Order shall serve as a National Pollutant Discharge Elimination System Permit pursuant to Section 402 of the Federal Clean Water Act, or amendments thereto, and shall take effect at the end of ten days from date of hearing provided the Regional Administrator has no objections.

IT IS HEREBY ORDERED, Imperial Community College District, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, and the provisions of the Federal Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

A. Effluent Limitations

1. Representative samples of wastewater discharged to Central Drain shall not contain constituents in excess of the following limits:

| Constituent           | Unit    | 30-Day<br>Arithmetic<br>Mean<br>Discharge<br>Rate | 7-Day<br>Arithmetic<br>Mean<br>Discharge<br>Rate |
|-----------------------|---------|---|--|
| 20°C BOD <sub>5</sub> | lbs/day | 38  | 56   |
|                       | mg/l    | 30  | 45   |
| Suspended Solids      | lbs/day | 38  | 56   |
|                       | mg/l    | 30  | 45   |
| Settleable Matter     | ml/l    | 0.3   | 0.5  |

2. The arithmetic mean of the values for effluent samples collected for 20°C BOD<sub>5</sub> and for suspended solids in any 30-day period shall not be greater than 15 percent of the arithmetic mean of the values for influent samples collected during the same 30-day period (85 percent removal).
3. The peak month average daily flow shall not exceed 150,000 gallons-per-day.
4. The effluent values for pH shall remain within the limits of 6.0 to 9.0.


B. Receiving Water Limitations

1. Wastewater discharged to Central Drain shall not:
  - a. Depress the dissolved oxygen content of said Drain below 5.0 mg/l.
  - b. Cause presence of oil, grease, scum, sludge, or solids.
  - c. Contain heavy metals or associated chemicals or pesticides in concentrations toxic to fish and other aquatic life.
2. This discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Regional Board or the State Water Resources Control Board as required by the Federal Clean Water Act and regulations adopted thereunder.

C. Provisions

1. Neither the treatment nor the discharge of wastes shall cause a pollution or a nuisance, as defined in Division 7 of the California Water Code.
2. Adequate protective works shall be provided to assure that a flood which would be expected to occur on a frequency of once in a 100-year period, would not erode or otherwise render portions of the treatment and discharge facilities inoperable.
3. This Order supersedes this Board's Order No. 79-22.
4. This Order includes the attached "Monitoring and Reporting Program No. 83-109, and future revisions thereto, as specified by the Executive Officer.
5. This Order expires five (5) years from November 16, 1983; and the discharger shall file a Report of Waste Discharge in accordance with Title 23, California Administrative Code, not later than 180 days in advance of such date as an application for issuance of new waste discharge requirements.
6. Facilities shall be available to keep the plant in operation in the event of commercial power failure.
7. The discharger's wastewater treatment plant shall be supervised and operated by persons possessing certification of appropriate grade pursuant to Chapter 3, Subchapter 14, Title 23, California Administrative Code.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 16, 1983.

  
\_\_\_\_\_  
Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 83-109  
FOR  
IMPERIAL COMMUNITY COLLEGE DISTRICT  
Northeast of El Centro - Imperial County**

**Location of Discharge:** Central Drain near the SE corner of Section 22, T15S, R14E, SBB&M

**EFFLUENT MONITORING**

Wastewater discharged into Central Drain shall be monitored for the following constituents. All samples shall be taken between 6 a.m. and 6 p.m. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.

| <u>Constituent</u>    | <u>Unit</u> | <u>Type of Sample</u> | <u>Sampling Frequency</u> |
|-----------------------|-------------|-----------------------|---------------------------|
| 20°C BOD <sub>5</sub> | mg/l        | 8-Hr. Composite       | Monthly                   |
| Suspended Solids      | mg/l        | 8-Hr. Composite       | Monthly                   |
| Settleable Matter     | ml/l        | Grab at Peak Flow     | Weekly                    |
| pH                    | pH Units    | Grab                  | Weekly                    |
| Dissolved Oxygen      | mg/l        | Grab                  | Weekly                    |
| Flow                  | Gallons     | Daily <sup>1</sup>    | Reported Monthly          |

**INFLUENT MONITORING**

The waste water influent to the treatment facilities shall be monitored for 20°C BOD<sub>5</sub> and for Suspended Solids, quarterly, 8-Hr. Composite.

- 
1. For each day with average monthly flow calculated

REPORTING

Monthly and weekly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month. Quarterly reports shall be submitted by January 15, April 15, July 15, and October 15 of each year.

The discharger shall implement the above monitoring program within 30 days of the effective date of this Order No. 83-109.

Forward monitoring reports to:


California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

ORDERED BY:

Arthur Sevjan  
Executive Officer

December 2, 1983  
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

IMPERIAL COMMUNITY COLLEGE DISTRICT  
 Northeast of El Centro - Imperial County  
 Near the SE corner of Section 22, T15S, R14E, SBB&M  
 USGS Brawley and Holtville 15 min. Topographic Maps

Order No. 83-109