

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 84-110

WASTE DISCHARGE REQUIREMENTS
FOR
TRAMVIEW MOBILE HOME PARK
Southeast of Palm Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Continental Parks, Inc. (hereinafter also referred to as the discharger), 825 Sutter Street, San Francisco, California, 94109, via the park manager, verified updated information on the discharge of waste on August 27, 1984.
2. The discharger is discharging a maximum of 60,000 gallons-per-day of domestic sewage from a mobile home and travel trailer park having 269 mobile home spaces, six (6) travel trailer spaces, three (3) restrooms, three (3) laundromats, 16 cabana units and a clubhouse. The wastewater is discharged into septic tank/seepage pit disposal systems located in the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 32, T4S, R5E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
4. The discharge has been subject to waste discharge requirements contained in Board Order No. 77-66.
5. There are no domestic wells within 200 feet of the discharge facilities described in Findings No. 2 and 3 (above).
6. The discharger states that wastewater from a swimming pool and a therapeutic pool is used for irrigation of landscape plantings.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on May 16, 1984. The Basin Plan contains water quality objectives for Coachella Hydrologic Subunit.
8. The beneficial uses of ground water of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
9. A 12-inch community sewer line runs through the park.

*Replaced by
95-003*

10. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
11. The Board in a public meeting heard and considered all comments pertaining to the discharge.
12. This mobile home and travel trailer park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming and hot pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool and hot pool wastewater shall not be discharged into a sewage disposal system.


B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

4. Prior to any change of ownership of this mobile home and travel trailer park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

5. This Order supersedes Board Order No. 77-66.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 14, 1984.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 84-110
FOR
TRAMVIEW MOBILE HOME PARK
Southeast of Palm Springs - Riverside County

Location: Portion of the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 32, T4S, R5E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of spaces, restrooms, motel units and laundry rooms presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By: Arthur Sogjan

Executive Officer

August 12, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



Palm Springs
1 mile



Scale:
1" = 2,000'

SITE MAP

TRAMVIEW MOBILE HOME PARK
Southeast of Palm Springs - Riverside County
Portion of NE $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 32, T4S, R5E, SBB&M
USGS Cathedral City 7.5 min. Topographic Map