

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**ORDER NO. 85-104**

**WASTE DISCHARGE REQUIREMENTS  
FOR  
HENRY'S SANITATION SERVICE  
East of Borrego Springs - San Diego County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Henry Flores (hereinafter also referred to as the discharger), P.O. Box 787, Borrego Springs, California, 92004, verified the below updated information in Findings No. 2 and 3 on September 16, 1985.
2. The discharger is discharging a maximum of 3,000 gallons-per-day of domestic sewage from pumping out septic tanks, seepage pits, cesspools, service station holding tanks, restaurant grease pits and chemical toilets.
3. The discharger discharges the waste (collected in a 1200 gallon capacity tank truck) by uniformly spreading it over the surface of 5 acres of natural desert located in a portion of E $\frac{1}{2}$ , SE $\frac{1}{4}$ , SW $\frac{1}{4}$  of Section 36, T10S, R6E, SBB&M. The discharger states that the wastes are disked into the soil within 24 hours after spreading.
4. The discharge at this site has been subject to waste discharge requirements adopted in Board Order No. 81-53.
5. The discharge area is underlain by recent alluvial fan deposits consisting of principally coarse sand. The reported depth to the water table from records of nearby wells in the area is approximately 100 feet below ground surface. There are no wells within 500 feet of the disposal site.
5. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for the Anza-Borrego Hydrologic Unit.
7. The beneficial uses of the groundwaters of the Anza-Borrego Hydrologic Unit are:
  - a. Municipal supply
  - b. Industrial supply
  - c. Agricultural supply

SUPERSEDED By  
90-076  
11/28/90

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

ORDER NO. 85-104

WASTE DISCHARGE REQUIREMENTS  
FOR  
HENRY'S SANITATION SERVICE  
East of Borrego Springs - San Diego County

The California Regional Water Quality Control Board, Colorado River Basin Region,  
finds that:

1. Henry Flores (hereinafter also referred to as the discharger), P.O. Box 787, Borrego Springs, California, 92004, verified the below updated information in Findings No. 2 and 3 on September 15, 1985.
2. The discharger is discharging a maximum of 3,000 gallons-per-day of domestic sewage from pumping out septic tanks, seepage pits, cesspools, service station holding tanks, restaurant grease pits and chemical toilets.
3. The discharger discharges the waste (collected in a 1200 gallon capacity tank truck) by uniformly spreading it over the surface of 5 acres of natural desert located in a portion of E $\frac{1}{2}$ , SE $\frac{1}{4}$ , SW $\frac{1}{4}$  of section 38, T10S, R9E, S8BXM. The discharger states that the wastes are disked into the soil within 24 hours after spreading.
4. The discharge at this site has been subject to waste discharge requirements adopted in Board Order No. 81-83.
5. The discharge area is underlain by recent alluvial fan deposits consisting of principally coarse sand. The reported depth to the water table from records of nearby wells in the area is approximately 100 feet below ground surface. There are no wells within 500 feet of the disposal site.
6. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for the Anza-Borrego Hydrologic Unit.
7. The beneficial uses of the groundwaters of the Anza-Borrego Hydrologic Unit are:
  - a. Municipal supply
  - b. Industrial supply
  - c. Agricultural supply

8. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
9. The Board in a public hearing heard and considered all comments pertaining to the discharge.
10. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Chapter 3 of Title 14, the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the discharge of wastewater nor the discharge operation shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than that specified in Finding No. 2 (above) shall be discharged at the designated land disposal site.
3. The discharge shall not exceed 3,000 gallons-per-operating day.
4. The disposal area shall be protected by natural or artificial features so as to assure protection from any washout and from inundation which could occur as a result of flooding.
5. There shall be no surface exposure of wastes at the close of a day's operation.
6. There shall be no concentration of waste within limited areas of the reported disposal site.
7. There shall be no ponding of discharged waste effluent or surface flow of this wastewater away from the designated disposal area.

B. Provisions

1. Prior to any substantial change in the quality or quantity of wastes discharged or the location of discharge, the discharger shall report in writing to the Regional Board.
2. The discharger shall comply with the "Monitoring and Reporting Program No. 85-104", and future revisions thereto, as specified by the Executive Officer.
3. In the event of any change in the operation or in control or ownership of the land used as the discharge area, the discharger shall:

8. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
9. The Board in a public hearing heard and considered all comments pertaining to the discharge.
10. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301, Chapter 3 of Title 14, the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the discharge of wastewater nor the discharge operation shall create a pollution or nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than that specified in Finding No. 2 (above) shall be discharged at the designated land disposal site.
3. The discharge shall not exceed 3,000 gallons-per-operating day.
4. The disposal area shall be protected by natural or artificial features so as to assure protection from any washout and from inundation which could occur as a result of flooding.
5. There shall be no surface exposure of wastes at the close of a day's operation.
6. There shall be no concentration of waste within limited areas of the reported disposal site.
7. There shall be no ponding of discharged waste effluent or surface flow of this wastewater away from the designated disposal area.

B. Provisions

1. Prior to any substantial change in the quality or quantity of wastes discharged or the location of discharge, the discharger shall report in writing to the Regional Board.
2. The discharger shall comply with the "Monitoring and Reporting Program No. 85-104", and future revisions thereto, as specified by the Executive Officer.
3. In the event of any change in the operation or in control or ownership of the land used as the discharge area, the discharger shall:

- a. Report in writing to the Regional Board.
- b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
4. Nothing contained herein shall be construed to allow the discharger to discharge wastes onto any land which is not under his ownership or control.
5. This Order supersedes Board Order No. 81-53.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 20, 1985.

  
\_\_\_\_\_  
Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 85-104  
FOR  
HENRY'S SANITATION SERVICE  
East of Borrego Springs - San Diego County

Location of Discharge: Portion of E $\frac{1}{2}$ , SE $\frac{1}{4}$ , SW $\frac{1}{4}$ , Section 36, T10S, R6E, SBB&M

MONITORING

The discharger shall report to the Regional Board concerning the following:

1. Volume of waste discharged during quarter. This information may be reported as the number of truckloads, and an estimate of the average volume per truckload (in gallons).


REPORTING

The quarterly reports shall be submitted by January 15, April 15, July 15, and October 15 of each year.

Mail reports to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

ORDERED BY:

  
Executive Officer

November 20, 1985  
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 82-104

HENRY'S SERVICE  
East of Borrego Springs - San Diego County

Location of Discharge: Portion of R.F. 261, S.W. 1/4, Section 38, T10S, R8E, S8R&M

MONITORING

The discharger shall report to the Regional Board concerning the following:

1. Volume of waste discharged during quarter. This information may be reported as the number of truckloads, and an estimate of the average volume per truckload (in gallons).

REPORTING

The quarterly reports shall be submitted by January 15, April 15, July 15, and October 15 of each year.

Mail reports to:


California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

ORDERED BY:

Executive Officer

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



Scale:  
1"=2,000'

SITE MAP

HENRY'S SANITATION SERVICE

East of Borrego Springs - San Diego County  
 E $\frac{1}{4}$ , SE $\frac{1}{4}$ , SW $\frac{1}{4}$  of Section 36, T10S, R6E, SBB&M  
 USGS Clark Lake 7.5 min. Topographic Map

Order No. 85-104