

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 86-78

**WASTE DISCHARGE REQUIREMENTS
FOR
K - D RANCHES RV PARK
Northwest of Niland - Imperial County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Richard and Katherine Ellis (hereinafter also referred to as the discharger), Route 1, Box 12, Niland, California, 92257, submitted a Report of Waste Discharge, dated July 11, 1986.
2. The discharger proposes to discharge a maximum of 18,000 gallons-per-day of domestic sewage from a recreational vehicle park that would have 70 RV spaces, four (4) restrooms with showers, ten (10) motel units, a laundry room, and a dining room. The wastewater would be discharged into two (2) waste stabilization basins for disposal by evaporation and infiltration. The basins are to be located in the SW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 13, T9S, R12E, SBB&M.
3. There are no domestic wells within 500 feet of the sewage disposal facilities described in Finding No. 2 (above).
4. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984.
5. Ground waters in the area, except for local and limited concentrations, are saline and are not beneficially used.
6. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
7. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
8. The Imperial County Planning Commission has approved Negative Declaration No. EA 1724-86 (approval date May 28, 1986) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

*Rescinded
11/28/90
90-080*

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged into the sewage disposal system described in Finding No. 2 (above).
3. A minimum depth of freeboard of at least two (2) feet shall be maintained in each of the earthen basins.
4. Treated or untreated sludge, or similar solid wastes, shall be disposed only at locations approved by the Regional Board.
5. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the discharge facilities.
8. There shall be no discharge, bypass, or flow of treated or untreated sewage to any channel which drains to the Salton Sea.
9. Treatment and disposal by ponding shall be conducted in such manner that there shall be no stranded or exposed sewage solids.
10. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
11. Standby facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.

3. In the event of any change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:

- a. Notify the Board of such change; and
- b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 17, 1986.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 86-78
FOR
K-D RANCHES RV PARK
Northwest of Niland - Imperial County

Location of Discharge: SW $\frac{1}{4}$ of NW $\frac{1}{4}$ of Section 13, T9S, R12E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of motel units, mobile home and RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.

ORDERED BY:

Arthur Swazian
Executive Officer


Jan. 26, 1988
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

K - D RANCHES RV PARK
 Northwest of Niland - Imperial County
 Portion of the SW $\frac{1}{4}$, NW $\frac{1}{4}$ of Section 13, T9S, R12E, SBB&M
 USGS Frink 15 min. Topographic Map



PRELIMINARY SEWAGE DISPOSAL FACILITIES SKETCH
 K - D RANCHES RV PARK
 Northwest of Niland - Imperial County