

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

ORDER NO. 88-113  
NPDES NO. CA 0104299

**WASTE DISCHARGE REQUIREMENTS  
FOR  
IMPERIAL COMMUNITY COLLEGE DISTRICT  
Northeast of El Centro - Imperial County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Imperial Community College District, (hereinafter also referred to as the discharger), P. O. Box 158, Imperial, California 92251, submitted an NPDES Application dated April 26, 1988 to renew it's permit to discharge wastewater into the Central Drain. Said application is assigned Application No. CA 0104299.
2. The discharger presently discharges a peak month average daily flow of 52,000 gallons-per-day and a peak week average daily flow of 73,000 gallons-per-day of wastewater from an activated sludge type treatment plant, which is designed for an average daily flow of 150,000 gallons-per-day of sewage into the Central Drain near the SE corner of Section 22, T15S, R14E, SBB&M. The wastewater flows approximately 4 miles and enters the Alamo River approximately 39 miles from Salton Sea.
3. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Plan contains water quality objectives for the Imperial Hydrologic Unit.
4. The beneficial uses of water in the Alamo River and Imperial Valley Drains discharging thereto are:
  - a. Freshwater replenishment for Salton Sea.
  - b. Warmwater habitat for fish and wildlife.
  - c. Recreation - non-water contact.
5. The discharge has been subject to waste discharge requirements adopted in Board Order No. 83-109 (NPDES No. CA0104299) which permits discharge to the Central Drain.
6. In accordance with Water Code Section 13389, the issuance of waste discharge requirements for this discharge is exempt from the provisions of the California Environmental Quality Act described in Chapter 3 (commencing with Section 21100 et. seq.), Division 13 of the Public Resources Code.
7. The purpose of this Order is to renew waste discharge requirements contained in Order No. 83-109.
8. The Board has notified the discharger and interested agencies and persons of its intent to renew waste discharge requirements for the said discharge and

*Superseded  
by Bd. Ord. #  
94-015  
3/15/94*

has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations, if any.

9. The Board in a public meeting heard and considered all comments pertaining to the existing discharge.

10. This Order shall serve as a National Pollutant Discharge Elimination System Permit pursuant to Section 402 of the Federal Water Pollution Control Act, or amendments thereto, and shall take effect at the end of ten days from date of adoption provided the EPA Regional Administrator has no objections.

IT IS HEREBY ORDERED, Imperial Community College District, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, and the provisions of the Federal Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

A. Effluent Limitations

1. Representative samples of wastewater discharged to the Central Drain shall not contain constituents in excess of the following limits:

Constituent	Unit	30-Day Arithmetic Mean Discharge Rate <sup>1</sup>	7-Day Arithmetic Mean Discharge Rate <sup>2</sup>
20°C BOD <sub>5</sub>	mg/l	30	45
Suspended Solids	mg/l	30	45
Settleable Matter	ml/l	0.3	0.5

2. The 30-day average percent removal of the pollutant parameters BOD<sub>5</sub> and suspended solids shall not be less than 85 percent.

3. The effluent values for pH shall be maintained within the limits of 6.0 to 9.0.

B. Receiving Water Limitations

1. Wastewater discharged to the Central Drain shall not:

- a. Cause presence of oil, grease, scum, sludge, or solids.
- b. Contain heavy metals or associated chemicals or pesticides in concentrations toxic to fish and other aquatic life.

---

1. 30-Day mean: The arithmetic mean of pollutant parameter values of samples collected in a period of 30 consecutive days.  
 2. 7-Day mean: The arithmetic mean of pollutant parameter values of samples collected in a period of 7 consecutive days.

2. This discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Regional Board or the State Water Resources Control Board as required by the Federal Water Pollution Control Act and regulations adopted thereunder.

C. Provisions

1. Neither the treatment nor the discharge of wastewater shall create pollution or nuisance as defined in Division 7 of the California Water Code.
2. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
3. This Order includes the attached "Monitoring and Reporting Program No. 88-113", and future revisions thereto, as specified by the Executive Officer.
4. Bioassays shall be performed annually to evaluate the toxicity of the discharged wastewater in accordance with the following procedures:
  - a. Within 4 months of the effective date of this Order, the discharger shall begin conducting bioassays on the fish species *Primephales promelas* (fathead minnow) and *Ceriodaphnia*. Fish bioassays shall be performed according to the protocol given in EPA/600/4-85/014 - Short Term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Freshwater Organisms.
  - b. The bioassay test specified above in 4.a. shall be performed quarterly for a period of at least one year (minimum of four tests per organism).
  - c. When the program described above in 4.a. and 4.b. have been completed, this permit will be reopened. At that time, effluent variability will be calculated and a numerical effluent limit established for toxicity. Compliance monitoring shall then be based on annual bioassays of the organism which showed greater sensitivity during the effluent characterization program. Selection of the more sensitive species will be made by the Regional Board.
5. This Order expires five (5) years from September 22, 1988; and the discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, at least 180 days in advance of such date as an application for issuance of new waste discharge requirements.
6. Facilities shall be available to keep the plant in operation in the event of commercial power failure.
7. The discharger's wastewater treatment plant shall be supervised and operated by persons possessing certification of appropriate grade pursuant to Chapter 4, Subchapter 14, Title 23, California Code of Regulations.
8. The discharger shall exclude from the wastewater treatment plant any liquid or solid waste, which could adversely effect the plant operation or effluent quality. The excluded liquid or solid waste shall be disposed of in accordance with applicable regulations.

IT IS FURTHER ORDERED that Board Order No. 83-109 be superceded by this Order.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on SEP 22 1988.

  
\_\_\_\_\_  
Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 88-113  
FOR  
IMPERIAL COMMUNITY COLLEGE DISTRICT  
Northeast of El Centro - Imperial County**

Location of Discharge: Central Drain near the SE corner of Section 22, T15S, R14E,  
SBB&M

**EFFLUENT MONITORING**

Wastewater discharged into the Central Drain shall be monitored for the following constituents. All samples shall be taken between 6 a.m. and 6 p.m. A sampling station shall be established at the point of discharge and shall be located where representative samples of the effluent can be obtained.

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
20°C BOD <sub>5</sub>	mg/l	8-Hr. Composite	Monthly
Suspended Solids	mg/l	8-Hr. Composite	Monthly
Settleable Matter	ml/l	Grab at Peak Flow	Weekly
pH	pH Units	Grab	Weekly
Dissolved Oxygen	mg/l	Grab	Weekly
Flow	Gallons	Daily <sup>1</sup>	Reported Monthly
Bioassay			Annually

**INFLUENT MONITORING**


The wastewater influent to the treatment facilities shall be monitored for 20°C BOD<sub>5</sub> and Suspended Solids, quarterly, 8-Hr. Composite.

---

<sup>1</sup> For each day with average monthly flow calculated



CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:  
1" = 1 mi.

El Centro  
2 miles

SITE MAP

IMPERIAL COMMUNITY COLLEGE DISTRICT  
 Northeast of El Centro - Imperial County  
 Near the SE corner of Section 22, T15S, R14E, SBB&M  
 USGS Brawley and Holtville 15 min. Topographic Maps

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**STANDARD PROVISIONS  
FOR  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT  
December 23, 1985**

1. The permittee must comply with all of the terms, requirements and conditions of this permit. Any violation of this permit constitutes violation of the Clean Water Act, its regulations and the California Water Code, and is grounds for enforcement action, permit termination, permit revocation and reissuance, denial of application for permit reissuance; or a combination thereof. (40 CFR 122.41 (a))\*
2. The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement. (40 CFR 112.41 (a) (1))
3. The Clean Water Act (CWA) provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, or 308 of the CWA is subject to a civil penalty not to exceed \$10,000 per day of such violation. Any person who willfully or negligently violates permit conditions implementing these sections of the CWA is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than 1 year, or both. (40 CFR 122.41 (a)(2))

The California Water Code provides that any person who violates a waste discharge requirement (same as permit condition), or a provision of the California Water Code is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$20 per gallon per day of violation; or some combination thereof, depending on the violation, or upon the combination of violations.\*

Violation of any of the provisions of the NPDES program or of any of the provisions of this permit may subject the violator to any of the penalties described herein, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.\*

4. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. (40 CFR 122.41 (b))

---

\*These paragraphs are added or modified pursuant to the California Water Code.

5. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit (40 CFR 122.41 (c))
6. The permittee shall take all reasonable steps to minimize or prevent any discharge that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR 122.41 (d))
7. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities, or similar systems that are installed by a permittee, only when necessary to achieve compliance with the conditions of this permit. (40 CFR 122.41 (e))
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. (40 CFR 122.41 (f))
9. This permit does not convey any property rights of any sort, or any exclusive privilege. (40 CFR 122.41 (g))
10. The permittee shall furnish, within a reasonable time, any information the Regional Board or EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit. The permittee shall also furnish to the Regional Board, upon request, copies of records required to be kept by this permit. (40 CFR 122.41 (h))
11. The Regional Board, EPA, and other authorized representatives shall be allowed:
  - a. Entry upon premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of the permit;
  - b. Access to copy any records that are kept under the conditions of this permit;
  - c. To inspect any facility, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
  - d. To photograph, sample, and monitor for the purpose of assuring compliance with this permit, or as otherwise authorized by the Clean Water Act. (40 CFR 122.41 (i))
12. Monitoring and records
  - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
  - b. The permittee shall retain records of all monitoring information, including all calibration and maintenance monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application

for this permit, for a period of at least three years from the date of the sample, measurement, report, or application. This period may be extended by request of the Regional Board or EPA at any time.

c. Records of monitoring information shall include:

- (i) The date, exact place, and time of sampling or measurements;
- (ii) The individual(s) who performed the sampling or measurements;
- (iii) The date(s) analyses were performed;
- (iv) The individual(s) who perform the analyses;
- (v) The analytical techniques or methods used; and
- (vi) The results of such analyses.

d. Monitoring must be conducted according to test procedures under 40 CFR Part 136, unless other test procedures have been specified in this permit.

e. The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both. (40 CFR 122.41 (j))

13. All applications, reports, or information submitted to the Regional Board shall be signed and certified in accordance with 40 CFR 122.22 (40 CFR 122.41 (k) (l))

14. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both (40 CFR 122.41 (k)(2))

15. Reporting requirements

a. The permittee shall give advance notice to the Regional Board as soon as possible of any planned physical alterations or additions to the permitted facility.

b. The permittee shall give advance notice to the Regional Board of any planned changes in the permitted facility or activity that may result in noncompliance with permit requirements.

c. This permit is not transferable to any person except after notice to the Regional Board. The Regional Board may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

d. Monitoring results shall be reported at the intervals specified elsewhere in this permit.

- (i) Monitoring results must be reported on a Discharge Monitoring Report (DMR).
  - (ii) If the permittee monitors any pollutant more frequently than required by this permit using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
  - (iii) Calculations for all limitations that require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
- e. Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any compliance schedule of this permit, shall be submitted no later than 14 days following each schedule date.
- f. Twenty-four hour reporting.
- (i) The permittee shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times and, if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
  - (ii) The following shall be included as information that must be reported within 24 hours under this paragraph:
    - (a) Any unanticipated bypass that exceeds any effluent limitation in the permit.
    - (b) Any upset that exceeds any effluent limitation in the permit.
    - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed in this permit to be reported within 24 hours.
  - (iii) The Regional Board may waive the above-required written report on a case-by-case basis.
- g. The permittee shall report all instances of noncompliance not otherwise reported under the above paragraphs at the time monitoring reports are submitted. The reports shall contain all information listed in paragraph 15(f) above. (40 CFR 122.41 (1))
16. Bypass (the intentional diversion of waste streams from any portion of a treatment facility) is prohibited. The Regional Board may take enforcement action against the discharger for bypass unless:
- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage. (Severe property damage means substantial physical damage to property, damage to the treatment facilities that causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production).
  - b. There were no feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated waste, or maintenance during

normal periods of equipment down time. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass that could occur during normal periods of equipment downtime or preventive maintenance; and

- c. The permittee submitted a notice at least ten days in advance of the need for a bypass to the appropriate Regional Board.

The permittee may allow a bypass to occur that does not cause effluent limitations to be exceeded, but only if it is for essential maintenance to assure efficient operation. In such a case, the above bypass conditions are not applicable.

The permittee shall submit notice of an unanticipated bypass as required in paragraph 15 (f) above. (40 CFR 122.41 (m))

17. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper action. A permittee that wishes to establish the affirmative defense of an upset in an action brought for noncompliance shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- a. An upset occurred and that the permittee can identify the cause(s) of the upset;
- b. The permitted facility was being properly operated at the time of the upset;
- c. The permittee submitted notice of the upset as required in paragraph 15 (f) above; and
- d. The permittee complied with any remedial measures required under paragraph 5.

No determination made before an action for noncompliance, such as during administrative review of claims that noncompliance, was caused by an upset, is final administrative action subject to judicial review.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof. (40 CFR 122.41 (n))

18. All existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Regional Board as soon as they know or have reason to believe:

- a. That any activity has occurred or will occur that would result in the discharge of any toxic pollutant that is not limited in this permit, if that discharge will exceed the highest of the following "notification levels:"

- (i) One hundred microgram per liter (100 ug/l);
- (ii) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
- (iii) Five (5) times the maximum concentration value reported for that pollutant in the permit application; or

(iv) The level established by the Regional Board in accordance with (40 CFR 122.44 (f))

b. That they have begun or expect to begin to use or manufacture as an intermediate or final product of byproduct any toxic pollutant that was not reported in the permit application. (40 CFR 122.42 (a))

19. All POTW's must provide adequate notice to the Regional Board of:

a. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to Sections 301 or 306 of the Clean Water Act, if it were directly discharging those pollutants.

b. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.

Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR 122.42 (b))

END

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**FACT SHEET  
APPLICATION FOR WASTE DISCHARGE REQUIREMENTS  
TO DISCHARGE TO STATE WATERS**

PUBLIC NOTICE NO. 7-88-7  
APPLICATION NPDES NO. CA 0104299  
ORDER NO. 88-113

Imperial Community College District, (hereinafter also referred to as the discharger), P. O. Box 158, Imperial, California 92251, has submitted a National Pollutant Discharge Elimination System Application to renew current Waste Discharge Requirements for a discharge of wastewater into State waters.

On the basis of preliminary staff reviews and application of lawful standards and regulations, the Regional Board proposes to renew waste discharge requirements for the discharge. The tentative proposed determinations are described below:

I. Description of Proposed Discharge

The applicant, Imperial Community College District, has a sewage treatment plant serving a current population of 3,000. The plant uses an activated sludge treatment process to treat wastewater for the parameters biochemical oxygen demand and suspended solids at the secondary level of treatment consistent with 40 CFR Part 133.102 requirements for secondary treatment. Chlorination of the effluent is not done prior to discharge.

The discharger presently discharges a peak month average daily flow of 52,000 gallons-per-day and a peak week average daily flow of 73,000 gallons-per-day of wastewater from an activated sludge type treatment plant, which is designed for an average daily flow of 150,000 gallons-per-day of sewage into Central Drain near the SE corner of Section 22, T15S, R14E, SBB&M. The wastewater flows approximately 4 miles and enters the Alamo River approximately 39 miles from Salton Sea.

II. Rationale for Effluent and Receiving Water Limitations

1. Receiving Waters

The effluent from the sewage treatment plant is discharged into Central Drain. The effluent flows approximately 4 miles and enters the Alamo River approximately 39 miles from Salton Sea.

The flow in the Alamo River is approximately composed as follows:

- a. Agricultural drainage from Imperial Valley (about 98.5 percent of the total flow).
- b. Community and industrial wastewaters from Imperial Valley sources (about 1.4 percent of total flow).
- c. Agricultural drainage from Mexico (about 0.1 percent of the total flow).

Alamo River at the International Boundary, has a total dissolved solids content averaging about 3,300 mg/l and a flow of 2 cf/sec. The 20°C BOD<sub>5</sub> averages 5.0 mg/l, and suspended solids is about 100 mg/l. It is estimated that the flow in the Alamo River at the intersection of Central Drain would be about 300 cf/sec. average.

The Alamo River is a large agricultural drainage wasteway. The flow in the Alamo River is composed predominantly of farm drainage waters. The Alamo River empties into Salton Sea. The water in Salton Sea is approximately thirteen times as saline as the drainage water which replenishes and sustains it.

- 2. The beneficial uses of water in Alamo River and the Imperial Valley Drains discharging thereto are:
  - a. Freshwater replenishment for Salton Sea.
  - b. Warmwater habitat for fish and wildlife.
  - c. Recreation - non-water contact.

3. Effluent Limitations

a. <u>Constituent</u>	<u>Unit</u>	30-Day Arithmetic Mean Discharge Rate	7-Day Arithmetic Mean Discharge Rate
20°C BOD <sub>5</sub>	mg/l	30	45
Suspended Matter	mg/l	30	45
Settleable Matter	ml/l	0.3	0.5

- b. The effluent values for pH shall remain within the limits of 6.0 to 9.0.

4. Basis of Effluent Limitations

- a. Suspended Solids, BOD and pH:

EPA standards for secondary treatment in 40 CFR Part 133.102 have been applied.

b. Settleable Matter:

This limitation is intended to prevent formation of sludge deposits at the point of discharge as required in the Basin Plan's General Surface Water Objectives (page 4-2).

III. Monitoring Requirements

1. Imperial Community College District is required to monitor the treatment plant effluent as follows:
  - a. Monthly for BOD and suspended solids
  - b. Weekly for settleable matter, pH, dissolved oxygen and flow
  - c. Annually for bioassay tests
2. The wastewater influent to the treatment facilities shall be monitored for 20°C BOD<sub>5</sub> and for Suspended Solids, quarterly, 8-Hr. Composite.

IV. Written Comments

All interested persons and agencies are invited to submit written comments on the proposed discharge and the Executive Officer's proposed determinations. Comments should be submitted not later than by September 1, 1988 either in person or by mail to:

Executive Officer.  
California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

The application number shall appear next to the above address on the envelope and on the first page of any submitted comments. All comments received by the above date will be considered in the formulation of the final determinations.

V. Information and Copying

Persons wishing further information may write to the above address or call the Regional Board at (619) 346-7491. Copies of the application, proposed waste discharge requirements and other documents (other than those which the Executive Officer maintains as confidential), are available at the Regional Board office for inspection and copying.

VI. Register of Interested Persons

Any person interested in a particular application or group of applications may leave his/her name and address and phone number as part of the file for the application. This list of names will be maintained as a means for persons with an interest in an application to contact others with similar interest.

## VII. Public Hearing

If submitted comments indicate a significant public interest in the application or if the Executive Officer believes useful information may be produced thereby, the Executive Officer, at his discretion, may hold a public hearing on the application. Any person may request the Executive Officer to hold a public hearing on the Application.

Public notice of a hearing will be circulated at least 30 days in advance of the hearing which will be held in the vicinity of the discharge. Further information regarding the conduct and nature of public hearings concerning discharge permits may be obtained by writing or visiting the Colorado River Basin Region office.