

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 90-060

WASTE DISCHARGE REQUIREMENTS
FOR
DEDOLPH RV PARK
Northwest of Niland - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. James R. Dedolph (hereinafter also referred to as the discharger), 1605 Main Street, Brawley, California 92227, supplied the updated information on the discharge of waste on July 11, 1990.
2. The discharger proposes to discharge a maximum of 83,000 gallons per day of domestic sewage from a recreational vehicle park that would consist of 800 RV Spaces, 8 restrooms with showers and a laundry room. The wastewater from this park would be discharged into two infiltration basins. The discharge site is located in the NW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 32, T10S, T14E, SBB&M.
3. This discharge has been subject to waste discharge requirements adopted in Board Order No. 85-075. However, the park was never constructed.
4. The Water Quality Control Plan for the Colorado River Basin Region of California designates the beneficial uses of ground and surface waters in this Region.
5. There are no domestic wells within 500 feet of the discharge facilities described in Finding No. 2, (above).
6. The beneficial uses of ground waters in the Imperial Hydrologic Unit are:
 - a. Municipal supply (MUN)
 - b. Industrial supply (IND)
7. Shallow ground waters in the vicinity of the discharge location are saline and are not beneficially used.
8. The Board has notified the discharger and all known interested agencies and persons of its intent to update waste discharge requirements for this discharge.
9. The Board in a public meeting heard and considered all comments pertaining to this discharge.

*Change of
Name & Ownership
6/24/92 92-039
Bird's Nest RV Park
owners
Jack & Mark Beal*

*Rescinded
3/26/97*

10. The Imperial County Planning Commission has approved Negative Declaration No. EA 1653-85 (approval date June 13, 1985) for this proposed park. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.


IT IS HEREBY ORDERED, that the discharger shall comply with the following specifications:

1. The treatment or disposal of wastes at this facility shall not cause pollution or nuisance as defined in Sections 13050(l) and 13050(m) of Division 7 of the California Water Code.
2. No wastewater other than domestic wastewater shall be discharged into the sewerage system described in Finding No. 2, (above).
3. A minimum depth of freeboard of two (2) feet shall be maintained at all times in each infiltration basin.
4. Treated or untreated sludge, or any solid waste materials, shall be disposed only at locations approved by the Regional Board's Executive Officer.
5. Adequate measures shall be taken to assure that unauthorized persons are effectively excluded from contact with the wastewater.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the designated disposal areas.
8. Disposal by ponding shall be conducted in such a manner that there shall be no stranded or exposed sewage solids.
9. A surface aerobic environment shall be maintained in each basin.
10. Infiltration facilities (basins) shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater by evaporation.
11. Facilities shall be available to keep the plant in operation in the event of commercial power failure.
12. The discharger shall comply with "Monitoring and Reporting Program No. 90-060," and future revisions thereto, as specified by the Regional Board's Executive Officer.
13. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater treated or discharged, or any material change in the location of discharge, the discharger shall report all pertinent information in writing to the Regional Board.

14. Prior to any change in ownership or management of this operation, the discharger shall transmit a copy of this Board Order to the succeeding owner/operator, and forward a copy of the transmittal letter to the Regional Board.

IT IS FURTHER ORDERED that Board Order No. 85-075 be superseded by this Board Order.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 19, 1990.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 90-060
FOR
DEDOLPH RV PARK
Northwest of Niland - Imperial County

Location of Discharge: NW $\frac{1}{4}$ of NW $\frac{1}{4}$ of Section 32, T10S, T14E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.


ORDERED BY:

Philip A. Guenberg
Executive Officer

September 19, 1990

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7




SITE MAP NO. 1

DEDOLPH RV PARK

Northwest of Niland - Imperial County

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -1



SITE MAP NO. 2

DEDOLPH RV PARK
 Northwest of Niland - Imperial County
 NW 1/4, NW 1/4 of Section 32, T10S, R14E, SBB&M
 USGS Wister 7.5min. Topographic Map