

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 90-062

WASTE DISCHARGE REQUIREMENTS
FOR
VALLEY VIEW TRAILER VILLAGE
Thermal - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Zivadin Babich, owner, 3158 Los Placitas, Las Cruces, New Mexico, 88001, has leased Valley View Trailer Village to Carmen Rubio (hereinafter both are referred to as the discharger), P.O. Box 864, 88-041 Avenue 56, Thermal, California 92274, who verified on July 11, 1990 that the below updated information in Finding No. 2 is accurate.
2. The discharger is discharging a maximum of 8,000 gallons-per-day of domestic sewage from a mobile home park having 42 mobile home spaces. The wastewater is piped approximately 300 feet behind the park into a system of septic tanks that are pumped into two (2) oxidation basins for disposal by evaporation and infiltration. The disposal area is located in the NW $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T6S, R8E, SBB&M.
3. The disposal site is about one (1) mile east of the nearest sewer line on Avenue 56.
4. The discharge of this mobile home park has been subject to waste discharge requirements adopted in Board Order No. 85-069.
5. There are no domestic wells within 500 feet of the sewage disposal facilities described in Finding No. 2 (above).
6. The Water Quality Control Plan for the Colorado River Basin Region of California designates the beneficial uses of ground and surface waters in this Region.
7. The beneficial uses of ground waters in the Coachella Hydrologic Subunit are:
 - a. Municipal supply (MUN)
 - b. Industrial supply (IND)
 - c. Agricultural supply (AGR)
8. The Board has notified the discharger and all known interested agencies and persons of its intent to update waste discharge requirements for this discharge.

9. The Board in a public meeting heard and considered all comments pertaining to this discharge.
10. In accordance with Section 15301, Chapter 3, Title 14, of the California Code of Regulations, the issuance of these waste discharge requirements, which govern the operation of an existing facility involving negligible or no expansion of use beyond that previously existing, is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.).

IT IS HEREBY ORDERED, that the discharger shall comply with the following:

A. Discharge Specifications


1. The treatment or disposal of wastes at this facility shall not cause pollution or nuisance as defined in Sections 13050(l) and 13050(m) of Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged into the sewage disposal system described in Finding No. 2 (above).
3. A minimum depth of freeboard of two (2) feet shall be maintained at all times in each of the earthen basins.
4. Treated or untreated sludge, or similar solid waste materials, shall be disposed only at locations approved by the Regional Board's Executive Officer.
5. Adequate measures shall be taken to assure that unauthorized persons are effectively excluded from contact with the wastewater.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the designated disposal areas.
8. There shall be no discharge, bypass, or flow of treated or untreated sewage to surface waters.
9. Septic tank cleanings shall be discharged only by a duly authorized service.
10. Disposal by ponding shall be conducted in such a manner that there shall be no stranded or exposed sewage solids.
11. A surface aerobic environment shall be maintained in each basin.
12. Infiltration facilities (basins) shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater by evaporation.
13. Standby facilities shall be provided to keep the sewage facilities operating in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater treated or discharged, or any material change in the location of discharge, the discharger shall report all pertinent information in writing to the Regional Board.
2. The discharger shall comply with "Monitoring and Reporting Program No. 90-062," and future revisions thereto, as specified by the Regional Board's Executive Officer.
3. Prior to any change in ownership or management of this operation, the discharger shall transmit a copy of this Board Order to the succeeding owner/operator, and forward a copy of the transmittal letter to the Regional Board.

IT IS FURTHER ORDERED that Board Order No. 85-069 be superseded by this Board Order.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 19, 1990.


Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 90-062
FOR
VALLEY VIEW TRAILER VILLAGE
Thermal - Riverside County

Location of Discharge: Portion of the NW $\frac{1}{4}$, NW $\frac{1}{4}$ of Section 23, T6S, R8E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of spaces presently connected to the facility's sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.
3. Explain any surfacing of wastewater or other failures of the system over the past year.
4. Estimate the maximum daily flow (gpd) of sewage discharged to the basin(s).

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Report immediately any failures of the sewage disposal system by telephone and follow-up by letter.



ORDERED BY: Philip A. Gruenberg

Executive Officer

September 19, 1990

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SCALE:
1" = 1 mi.

SITE MAP

VALLEY VIEW TRAILER VILLAGE
Thermal - Riverside County
NW $\frac{1}{4}$, NW $\frac{1}{4}$ of Section 23, T6S, R8E, SBB&M
USGS Coachella 15 min. Topographic Map

Order No. 90-062