

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 91-007

WASTE DISCHARGE REQUIREMENTS
FOR
TARMAC CALIFORNIA, INC.
North of Needles - San Bernardino County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Tarmac California, Inc. (hereinafter also referred to as the discharger), P.O. Box 14050, Palm Desert, California, 92255-4050, submitted a Report of Waste Discharge, dated November 6, 1990.
2. The discharger proposes to discharge a maximum total of 100,000 gallons-per-day of wastewater from facilities which would consist of a washer at a sand and gravel processing plant that would discharge into three unlined basins. The wastewater is to be recirculated for use in the washing operations, and also, spread on on-site roads for dust control. The disposal basins are located in the SW $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 15, T11N, R21E, SBB&M.
3. There are no domestic wells within 500 feet of the discharge facilities described in Finding No. 2, above.
4. The Water Quality Control Plan for the Colorado River Basin Region of California designates the beneficial uses of ground and surface waters in this Region.
5. The beneficial uses of ground waters in the Piute Hydrologic Unit are:
 - a. Municipal supply (MUN)
 - b. Industrial supply (IND)
 - c. Agricultural supply (AGR)
6. The Board has notified the discharger and all known interested agencies and persons of its intent to prescribe waste discharge requirements for this discharge.
7. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.
8. The San Bernardino County Planning Commission approved Negative Declaration No. DS1329-441N on April 18, 1991, for this project. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

*Change Name
& Ownership
Bd. Ord # 92-066
11/18/92*

*Rescinded
11/22/97*

IT IS HEREBY ORDERED, that the discharger shall comply with the following:


A. Discharge Specifications

1. The treatment or disposal of wastes at this facility shall not cause pollution or nuisance as defined in Sections 13050(1) and 13050(m) of Division 7 of the California Water Code.
2. Infiltrating wastewaters shall not contain a total dissolved solids content in excess of 1150 mg/l.
3. Wastewater with a TDS in excess of the limit prescribed in Discharge Specification No. 2, above shall be retained in impervious basins with ultimate discharge at a location approved by the Regional Board.
4. There shall be no surface flow of wastewater away from the designated disposal areas.
5. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.

B. Provisions

1. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater treated or discharged, or any material change in the location of discharge, the discharger shall report all pertinent information in writing to the Regional Board; and obtain revised requirements before any modifications are implemented.
2. Prior to any change in ownership or management of this operation, the discharger shall transmit a copy of this Board Order to the succeeding owner/operator, and forward a copy of the transmittal letter to the Regional Board.
3. The discharger shall comply with "Monitoring and Reporting Program No. 91-007", and future revisions thereto, as specified by the Regional Board's Executive Officer.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on May 15, 1991.


Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 91-007
FOR
TARMAC CALIFORNIA, INC.
North of Needles - San Bernardino County

Location of Discharge: SW $\frac{1}{4}$, NE $\frac{1}{4}$, Section 15, T11N, R21E, SBB&M

MONITORING

Samples shall be taken of wastewater contained in the infiltration basins and monitored for the following:

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Dissolved Solids	mg/l	Grab	Quarterly

REPORTING

Quarterly monitoring reports shall be submitted to the Regional Board by January 15, April 15, July 15, and October 15 of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


ORDERED BY:

Philip A. Guesberg
Executive Officer

May 15, 1991

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

TARMAC CALIFORNIA, INC.
North of Needles - San Bernardino County
SW $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 15, T11N, R21E, SBB&M
USGS Mt. Manchester, CA 7.5 min. Topographic Map

Order No. 91-007