

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 91-038

WASTE DISCHARGE REQUIREMENTS
FOR
BEAUMONT CONCRETE COMPANY
Banning - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Beaumont Concrete Company (hereinafter also referred to as the discharger), P.O. Box 216, Banning, California, 92223 verified the below updated information on the discharge of wastes on April 21, 1991.
2. The discharger is currently discharging an average daily flow of 16,000 gpd of wastewater from a gravel crushing plant located in the SE $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 3, T3S, R1E, SBB&M. Wastewater is discharged into unlined basins with final disposal by evaporation and infiltration.
3. There are no domestic wells within 500 feet of the discharge facilities described in Finding No. 2, above. An analysis of a recent water sample of an on-site well had a total dissolved solids concentration of about 160 mg/l.
4. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted May 15, 1991 and designates the beneficial uses of ground and surface waters in this Region.
5. The beneficial uses of ground waters in the San Gorgonio Hydrologic Subunit are:
 - a. Municipal supply (MUN)
 - b. Industrial supply (IND)
 - c. Agricultural supply (AGR)
6. This discharge has been subject to waste discharge requirements adopted in Board Order No. 84-084.
7. The Board has notified the discharger and all known interested agencies and persons of its intent to update waste discharge requirements for this discharge.
8. The Board in a public meeting heard and considered all comments pertaining to this discharge.

CHANGE NAME / OWNERSHIP
BY BOARD ORDER NO. 99-019 6/10/99

9. In accordance with Section 15301, Chapter 3, Title 14 of the California Code of Regulations, the issuance of these waste discharge requirements, which govern the operation of an existing facility involving negligible or no expansion of use beyond that previously existing, is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.).

IT IS HEREBY ORDERED, that the discharger shall comply with the following:

A. Discharge Specifications


1. The treatment or disposal of wastes at this facility shall not cause pollution or nuisance as defined in Sections 13050(1) and 13050(m) of Division 7 of the California Water Code.
2. Infiltrating wastewater shall not contain a total dissolved solids content in excess of 450 mg/l.
3. Discharge of wastewater with a TDS in excess of the limit prescribed in Discharge Specification No. A.2, above is prohibited, except that the use of this wastewater for on-site dust control is not prohibited.
4. There shall be no surface flow of wastewater away from the designated disposal areas.
5. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.

B. Provisions

1. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater treated or discharged, or any material change in the location of discharge, the discharger shall report all pertinent information in writing to the Regional Board; and obtain revised requirements before any modifications are implemented.
2. Prior to any change in ownership or management of this operation, the discharger shall transmit a copy of this Board Order to the succeeding owner/operator, and forward a copy of the transmittal letter to the Regional Board.
3. The discharger shall comply with "Monitoring and Reporting Program No. 91-038", and future revisions thereto, as specified by the Regional Board's Executive Officer.

IT IS FURTHER ORDERED that Board Order No. 84-084 be superseded by this Board Order.

I, Philip A. Gruenberg, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 20, 1991.



Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 91-038
FOR
BEAUMONT CONCRETE COMPANY
Banning - Riverside County

Location of Discharge: SE $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 3, T3S, R1E, SSB&M

MONITORING

Samples shall be taken of wastewater contained in the infiltration basins and monitored for the following:

<u>Constituents</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Dissolved Solids	mg/l	Grab	Quarterly

REPORTING

Quarterly monitoring reports shall be submitted to the Regional Board by January 15, April 15, July 15, and October 15 of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


ORDERED BY:

Philip A. Guendler
Executive Officer

November 20, 1991

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



SITE MAP
 BEAUMONT CONCRETE COMPANY
 Banning - Riverside County
 SE $\frac{1}{4}$, NE $\frac{1}{4}$, Sec. 3, T3S, R1E, SBB&M
 USGS Cabazon 7.5 min. Topographic Map

Order No. 91-038