

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 00-100

FOR

HEBER PUBLIC UTILITY DISTRICT, OWNER/OPERATOR

MUNICIPAL WASTEWATER TREATMENT PLANT

Heber – Imperial County

Location of Discharge: NW ¼, NE ¼ of Section 28, T16S, R14E, SBB&M

MONITORING

The collection, preservation and holding times of all samples shall be in accordance with U.S. Environmental Protection Agency approved procedures. Unless otherwise approved by the Regional Board's Executive Officer, all analyses shall be conducted by a laboratory certified for such analysis by the State Department of Health Services. All Analyses shall be conducted in accordance with the latest edition of "Guidelines Establishing Test Procedures for Analysis of Pollutants" (40 CFR 136), promulgated by the United States Environmental Protection Agency.

Compliance with the discharge limitations shall be determined at the end of the treatment process or as specified in the Board Order.

If the facility is not in operation, or there is no discharge during a required reporting period, the discharger shall either forward a letter, or write a notation on the required monthly monitoring report to the Regional Board, indicating that there has been no activity during the required reporting period.

INFLUENT MONITORING

The wastewater influent to the treatment facilities shall be monitored as follows:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
20°C BOD ₅	mg/L ¹	24-Hr. Composite	Weekly
Total Suspended Solids	mg/L	24-Hr. Composite	Weekly

¹ mg/L – milligrams-per-Liter

EFFLUENT MONITORING

A sampling station shall be established at the point of discharge and shall be located where representative samples of effluent can be obtained. Wastewater discharged into the Central Drain 3-D No. 1 shall be monitored for the following constituents:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Daily Effluent Discharge	MGD ²	Flow Meter Reading	Daily ³
pH	-----	Grab	Daily
Chlorine Residual	mg/L	Grab	Daily ⁴
Suspended Solids	mg/L	24-Hr. Composite	Weekly
20°C BOD ₅	mg/L	24-Hr. Composite	Weekly
Temperature	°F	Grab	Weekly
E. Coli	MPN ⁵ /100 ml	Grab	Five Samples per Month ⁶
Total Dissolved Solids	mg/L	Grab	Monthly
Nitrates as Nitrogen (N)	mg/L	24-Hr. Composite	Monthly
Nitrites as N	mg/L	24-Hr. Composite	Monthly
Ammonia Nitrogen as N	mg/L	24-Hr. Composite	Monthly
Total Nitrogen as N	mg/L	24-Hr. Composite	Monthly
Total Phosphorus as Phosphorus (P)	mg/L	24-Hr. Composite	Monthly
Ortho-Phosphate as P	mg/L	24-Hr. Composite	Monthly
Oil and Grease	mg/L	24-Hr. Composite	Annually

² MGD – Million Gallons-Per-Day

³ Reported monthly with monthly average daily flow

⁴ Monitoring of the effluent for chlorine residual shall begin on the date the chlorination facility is placed into operation.

⁵ MPN – Most Probable Number

⁶ Monitoring for E.coli shall begin August 1, 2001

RECEIVING WATER MONITORING

All receiving water samples shall be grab samples. Sampling stations shall be as follows:

<u>Station</u>	<u>Description</u>
R-1	Not to exceed 100 feet upstream from the point of discharge. A greater distance may be acceptable provided the discharger submits proper justification that the prescribed distance is inaccessible.
R-2	Not to exceed 200 feet downstream of the discharge pipe outlet.

<u>Constituent</u>	<u>Unit</u>	<u>Station</u>	<u>Sampling Frequency</u>
Temperature	°F	R-1, R-2	Monthly
Dissolved Oxygen	mg/L	R-1, R-2	Monthly
pH	-----	R-1, R-2	Monthly
Hardness (CaCO ₃)	mg/L	R-1, R-2	Monthly
Total Dissolved Solids	mg/L	R-1, R-2	Monthly
Nitrates as Nitrogen (N)	mg/L	R-1, R-2	Monthly
Nitrites as N	mg/L	R-1, R-2	Monthly
Ammonia Nitrogen as N	mg/L	R-1, R-2	Monthly
Total Nitrogen as N	mg/L	R-1, R-2	Monthly
Total Phosphorus as Phosphorus (P)	mg/L	R-1, R-2	Monthly
Ortho-Phosphate as P	mg/L	R-1, R-2	Monthly

In conducting the receiving water sampling, a log shall be kept of the receiving water conditions at Stations R1 and R2. Attention shall be given to the presence or absence of:

- | | |
|---------------------------------|-------------------------------------------|
| a. Floating or suspended matter | d. Visible film, sheen or coating |
| b. Discoloration | e. Fungi, slime, or objectionable growths |
| c. Aquatic life | f. Potential nuisance conditions |

Notes on receiving water conditions shall be summarized in the monitoring report.

2,3,7,8- TETRACHLORODIBENZO-P-DIOXIN (TCDD)
EQUIVALENT MONITORING

By May 18, 2001, the discharger shall begin monitoring its effluent for the presence of 17 (Toxic equivalency factors for 2,3,7,8-tetrachlorodibenzo-p-dioxin equivalents) congeners once during the dry weather and once during the wet weather within a period of three consecutive years. The congeners and Toxic Equivalent Factors can be found in Table 4 of the *"Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California."* A copy of Table No. 4 is shown below.

Table 4

<u>Congener</u>	<u>TEF</u>
2,3,7,8- Tetra-Chlorodibenzo-p-dioxins (CDD)	1
1,2,3,7,8- Penta-CDD	1.0
1,2,3,4,7,8- Hexa-CDD	0.1
1,2,3,6,7,8- Hexa-CDD	0.1
1,2,3,7,8,9- Hexa-CDD	0.1
1,2,3,4,6,7,8- Hepta-CDD	0.01
OctaCDD	0.0001
2,3,7,8- Tetra- Chlorinated dibenzofurans (CDF)	0.1
1,2,3,7,8- Penta-CDF	0.05
2,3,4,7,8- Penta-CDF	0.5
1,2,3,4,7,8- Hexa-CDF	0.1
1,2,3,6,7,8- Hexa-CDF	0.1
1,2,3,7,8,9- Hexa-CDF	0.1
2,3,4,6,7,8- Hexa-CDF	0.1
1,2,3,4,6,7,8- Hepta-CDF	0.01
1,2,3,4,7,8,9- Hepta-CDF	0.01
Octa-CDF	0.0001

The discharger shall report for each congener the analytical results of the effluent monitoring, including the quantifiable limit and the Method Detection Limit⁷, and the measured or estimated concentration. In addition, the discharger shall multiply each measured or estimated congener concentration by its respective Toxic Equivalent Factors⁸ value and report the sum of these values. This information shall be submitted as part of the discharger's monitoring reports.

OPERATION AND MAINTENANCE

The discharger shall inspect and document any operation/maintenance problems by inspecting each unit process. The report shall include a listing of flow metering locations and dates of calibration of each flow meter. The results of the operation and maintenance inspections shall be forwarded to this Regional Board annually.

PRETREATMENT REPORT

In the event that the discharger is required to implement a pretreatment program then the discharger shall submit reports as required in accordance with Section F. Pretreatment and Appendix – Requirements for Pretreatment Annual Report of the Waste Discharge Requirements.

SLUDGE MONITORING

The discharger shall report quarterly on the quantity, location and method of disposal of all sludge and similar solid material being produced at the wastewater treatment plant facility.

Sludge that is generated at the treatment facility and removed for disposal shall be sampled and analyzed for the following:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Arsenic	mg/kg ⁹	Grab	Annually
Cadmium	mg/kg	Grab	Annually
Copper	mg/kg	Grab	Annually
Lead	mg/kg	Grab	Annually
Mercury	mg/kg	Grab	Annually
Molybdenum	mg/kg	Grab	Annually
Nickel	mg/kg	Grab	Annually
Selenium	mg/kg	Grab	Annually

⁷ As determined by the procedure found in 40 CFR 136 (revised as of May 14, 1999)

⁸ Table 4 Toxic Equivalency Factors (TEFs) for 2, 3, 7, 8- TCDD Equivalents, pg. 27, Policy for Implementation of Toxics, Standard for Inland Surface Waters, Enclosed Bays and Estuaries of California, Adopted March 2, 2000

⁹ mg/kg – milligrams-per-kilogram

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Zinc	mg/kg	Grab	Annually
Fecal Coliform	MPN/gram	Grab	Annually

EFFLUENT TOXICITY TESTING

The discharger shall conduct toxicity testing on the effluent as follows:

<u>Test</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Test</u>
Chronic Toxicity	tu _c	Composite	Quarterly
Acute Toxicity	% survival	Composite	Quarterly

Both test species given below shall be used to measure acute and chronic toxicity:

<u>Species</u>	<u>Effect</u>	<u>Test Duration (Days)</u>	<u>Reference</u>
Fathead Minnow (Pimephales promelas)	Larval Survival	7	EPA/600/4-91/002 (chronic) EPA/600/4-90/027F (acute)
Water Flea (Ceriodaphnia dubia)	Survival; Number of Young	7	EPA/600/4-91/002 (chronic) EPA/600/4-90/027F (acute)

Toxicity Test Reference: Methods for measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fourth Edition, EPA-600-4-90-027F, August 1993. Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water for Freshwater Organisms, EPA-600-4-91-002, July 1994.

Dilution and control waters may be obtained from an unaffected area of receiving waters. Standard dilution is an option and may be used if the above source is suspected to have toxicity greater than 1.0 tu_c. The sensitivity of the test organism to a reference toxicant shall be determined concurrently with each bioassay and reported with the test results.

Chronic toxicity shall be expressed and reported as toxic units (tu_c) where:

$$tu_c = 100/NOEC$$

and the No Observed Effect Concentration (NOEC) is expressed as the maximum percent effluent of test water that causes no observed effect on a test organism, as determined in a critical life stage toxicity test indicated above.

Acute toxicity may be calculated from the results of the chronic toxicity test described above and shall be reported along with the results of each chronic test. Acute toxicity shall be expressed as percent survival of test organism over a ninety-six hour period in 100% effluent.

REPORTING

1. The discharger shall report the results of acute and chronic toxicity testing as determined through standard toxicity protocols using 100% effluent.
2. The discharger shall arrange the data in tabular form so that the specified information is readily discernible. The data should be summarized in such a manner as to clearly illustrate whether the facility is operating in compliance with waste discharge requirements.
3. The discharger shall report with each sample result the applicable Minimum Level (as described in the California Toxics Policy) and the laboratory current Method Detection Limit, as determined by the procedure in 40 CFR 136 (revised as of May 14, 1999).
4. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurement(s);
 - b. The individual(s) who performed the sampling or measurement(s);
 - c. The date(s) analyses were performed;
 - d. The individual(s) who performed the analyses;
 - e. The analytical techniques or method use; and
 - f. The results of such analyses.
5. The results of any analysis of samples taken more frequently than required at the locations specified in this Monitoring and Reporting Program shall be reported to the Regional Board.
6. Monitoring reports shall be certified under penalty of perjury to be true and correct, and shall contain the required information at the frequency designated in this monitoring report.
7. Each report shall contain the following statement:

“I declare under the penalty of law that I personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment for knowing violations.”
8. A duly authorized representative of the discharger may sign the documents if:
 - a. The authorization is made in writing by the person described above;
 - b. The authorization specified an individual or person having the responsibility for the overall operation of the regulated disposal system; and
 - c. The written authorization is submitted to the Regional Board's Executive Officer.
9. Reporting of any failure in the waste disposal system shall be as described as in Provision No. 29 to the Regional Board office and to the Office of Emergency Services.

10. Daily, weekly, and monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month. Quarterly monitoring reports shall be submitted by January 15, April 15, July 15, and October 15 of each year. Annual reports shall be submitted by January 15 of each year.

11. Submit reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-720 Fred Waring Drive, Suite 100
Palm Desert, CA 92260

A copy of the monitoring report shall also be sent to:

Regional Administrator
U.S. Environmental Protection Agency
Region 9, Attn: 65MR, W-3
75 Hawthorne Street
San Francisco, CA 94105

Ordered by: original signed by/
Executive Officer

September 13, 2000
Date