

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 COLORADO RIVER BASIN REGION
 MONITORING AND REPORTING PROGRAM FOR:
 Date Gardens Mobile Home Park**

WDID NO.: 7A131067011
 ORDER NO.: 97-113
 NPDES NO.: CA0104841

MONTH: June
 2003

REPORTING FREQUENCY.: MONTHLY

EFFLUENT

Constituents	FLOW	BOD	SUS.SOLIDS	SETT.MATT.	Ph	TDS
Sample						
Frequency	Daily	Monthly	Monthly	Monthly	Monthly	Monthly
Description		24 Hr.Comp	24 Hr.Comp	Grab	Grab	
Units	MGD	mg/L	mg/L	m/L	Ph Units	
Requirements						
30 Day Mean		30	30	0.3		2000
7 Day Mean		45	45	0.5		2500
Maximum					6.0 - 9.0	
Date of Sample						
1	0.019450					
2	0.021690					
3	0.016209					
4	0.019128					
5	0.016119					
6	0.016407					
7	0.016094					
8	0.014015					
9	0.015861					
10	0.015268					
11	0.015668					
12	0.016717					
13	0.011738					
14	0.016787					
15	0.015298					
16	0.016301					
17	0.016022	10.0	9.0			
18	0.009397			0.10	7.27	1084
19	0.001076					
20	0.008712					
21	0.009852					
22	0.012401					
23	0.008873					
24	0.008620					
25	0.009552					
26	0.011643					
27	0.011121					
28	0.008484					
29	0.008466					
30	0.010174					
31	0.020991					
MONTHLY MEAN	0.013488	10.0	9.0	0.10	7.27	1084

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Grab at peak flow

RECEIVED
 JUL 15 2003
 REGION 7

SIGNATURE:

[Handwritten Signature]
 IN ROCKY VANDOLGNIFF ABSORBER

**COLORADO RIVER BASIN REGION
MONITORING AND REPORTING PROGRAM FOR:
DATE GARDENS MOBILE HOME PARK**

WDID NO.: 7A131067011
ORDER NO.: 97-113
NPDES NO.: CA0104841

MONTH: June
YEAR: 2003

QUARTER:


REPORTING FREQUENCY.: MONTHLY/QUARTERLY

INFLUENT/RECEIVING WATER

Constituents	BOD	Sus.Solids	DO. Oxygen	PH	DO. Oxygen	PH
Sample	Influent	Influent	Rec. water	Rec. water	Rec. water	Rec. water
Frequency	Quarterly	Quarterly	Monthly	Monthly	Monthly	Monthly
Description	24Hr.Comp	24Hr.Comp	Upstream	Upstream	Downstream	Downstream
Units	mg/L	mg/L	mg/L	PH Units	mg/L	PH Units
Requirements						
30 Day Mean					Min. 5.0	6.0 - 9.0
7 Day Mean						
Maximum						
Date of Sample						
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17	189	184				
18			8.05	7.98	8.01	7.95
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
MONTHLY MEAN	189	184	8.05	7.98	8.01	7.95

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

RECEIVED
JUL 15 2003
REGION 7

SIGNATURE: 
ROCKY DANIEL GRUFF ABSORCO