CALIFO A REGIONAL WATER QUALITY CONTROL ARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
MONTH September
YEAR 2005

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD_5	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.012778						
2	0.012322						
3	0.011921						
4	0.012028						
5	0.01249						
6	0.011542				< 20		
7	0.011806						
8	0.010728						
9	0.013245						
10	0.012955						
11	0.011659						
12	0.012075						
13	0.011845						
14	0.011206	2	1	7.4	< 20		1064
15	0.010739						
16	0.01142						
17	0.012118						
18	0.011555						
19	0.012191						
20	0.011461						
21	0.011532						
22	0.010765						
23	0.011914						
24	0.011765						
25	0.012484						
26	0.011511				< 20		
27	0.009785						
28	0.011758						
29	0.01196				< 20		
30	0.012055						
31							
30-DAY MEAN	0.011787						
7-DAY MEAN	0.082514						
MAXIMUM	0.012955						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Vanderwolf

MONTHLY REPORT

OCT 14 2005

QM

CALIFO A REGIONAL WATER QUALITY CONTROL ARD
COLORADO RIVER BASIN

WDID NO.: **7A1310570011**
ORDER NO.: **R7-2003-0054**
NPDES NO.: **CA0104841**
REPORTING FREQUENCY: **QUARTERLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER September
YEAR 2005

TYPE OF SAMPLE:	INFLUENT		RECEIVING WATER - R1 (UPSTREAM)				
CONSTITUENTS	20°C BOD_5	Sus. Solids	DO	Hydrogen Ion	Chlorine	E. Coli	
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly	
DESCRIPTION	24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab	
UNITS	mg/L	mg/L	mg/L	pH Units	mg/L	MPN/100mL	
REQUIREMENTS							
30-DAY MEAN							
7-DAY MEAN							
MAXIMUM							
DATE OF SAMPLE							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14	158	87	8.6	7.81			
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
QUARTER MEAN							
MAXIMUM							

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Vanderpool

WDID NO.: **7A1310570011**
ORDER NO.: **R7-2003-0054**
NPDES NO.: **CA0104841**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER September
QUARTERLY REPORT

OCT 14 2005

CALIFC 'A REGIONAL WATER QUALITY CONTROI)ARD
COLORADO RIVER BASIN

REPORTING FREQUENCY: **QUARTERLY** YEAR 3 2005

TYPE OF SAMPLE:	RECEIVING WATER - R2 (DOWNSTREAM)					EFFLUENT	
CONSTITUENTS	DO	Hydrogen Ion	Chlorine	E. Coli		20°C BOD_5	Sus. Solids
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly			
DESCRIPTION	Grab	Grab	Grab	Grab		% Removal	% Removal
UNITS	mg/L	pH Units	mg/L	MPN/100mL			
REQUIREMENTS							
30-DAY MEAN						85%	85%
MINIMUM	5.0	6.0					
MAXIMUM		9.0	0.02	400			
DATE OF SAMPLE							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14	7.9	7.56					
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
QUARTER MEAN							
MAXIMUM							

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Vanderhoff

WDID NO.: **7A1310570011**
ORDER NO.: **R7-2003-0054**
NPDES NO.: **CA0104841**
REPORTING FREQUENCY: **QUARTERLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER _____
YEAR _____

QUARTERLY REPORT

OCT 14 2005

CALIFO A REGIONAL WATER QUALITY CONTROL ARD
COLORADO RIVER BASIN

1. Is there receiving water at Station R-1? Yes No
If the answer is no proceed to Station R-2 Section, otherwise continue with the following questions.
PLEASE CIRCLE THE APPROPRIATE ANSWER

Station R-1 Section (The following questions refer to Station R-1)

1. Is there the presence of floating or suspended matter present?	Yes	No
2. Is there discoloration present?	Yes	No
3. Is there aquatic life present?	Yes	No
4. Is there visible film, sheen or coating present?	Yes	No
5. Is there fungi, slime or objectable growths present?	Yes	No
6. Is there potential nuisance conditions present?	Yes	No

Station R-2 Section (The following questions refer to Station R-2)

Is there the presence of floating or suspended matter present?	Yes	No
Is there discoloration present?	Yes	No
Is there aquatic life present?	Yes	No
Is there visible film, sheen or coating present?	Yes	No
Is there fungi, slime or objectable growths present?	Yes	No
Is there potential nuisance conditions present?	Yes	No

Any additional comments.

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Vandergrift

OCT 14 2005

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M8985

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-6-05 1110AM ANALYSIS:

SAMPLED FROM CLIENT:

DATE GARDENS MOBILE PARK

DISTRICT

SAMPLED BY: ROD

DATE/TIME: 9-6-05

TYPE OF SAMPLE: RAW

CHLORINE: UV

SITE CODE: 21-2

SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM ABSENCE

FECAL COLIFORM = ABSENCE

E COLI = ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

DATE START: 9-6-05 TIME START: 1130AM

DATE COMPLETED: 9-8-05 TIME COMPLETED: 800AM

DATE REPORTED: 9-9-05 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

OCT 14 2005

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M9024-1

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-14-05 800AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS MOBILE PARK

SAMPLED BY: JASON

DATE/TIME: 9-14-05

TYPE OF SAMPLE: RAW

CHLORINE: UV

SITE CODE: 21-2

SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM PRESENCE

FECAL COLIFORM = PRESENCE

E COLI = ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=80/FECAL=20/ECOLI=<20/100ML

DATE START: 9-14-05 TIME START: 830AM

DATE COMPLETED: 9-16-05 TIME COMPLETED: 700AM

DATE REPORTED: 9-16-06 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER PHONE 760-344-2532

OCT 14 2005

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M9092
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-26-05 945AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS MOBILE PARK

SAMPLED BY: JASON
DATE/TIME: 9-26-05
TYPE OF SAMPLE: RAW
CHLORINE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE 21-2

TOTAL COLIFORM = ABSENCE
FECAL COLIFORM = ABSENCE
E COLI= ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

ANALYST: LLW/MO
DATE START: 9-26-05 TIME START: 1000AM
DATE COMPLETED: 9-28-05 TIME COMPLETED: 730AM
DATE REPORTED: 9-28-05 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

OCT 14 2005

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M8932

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 8-29-05 720AM ANALYSIS:

SAMPLED FROM CLIENT:

DATE GARDENS MOBILE PARK

DISTRICT

SAMPLED BY: RV

DATE/TIME: 8-29-05 700AM

TYPE OF SAMPLE: RAW

SITE CODE: 21-2

CHLORINE: UV

SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM ABSENCE

FECAL COLIFORM – ABSENCE

E COLI – ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

DATE START: 8-29-05

TIME START: 900AM

DATE COMPLETED: 8-31-05

TIME COMPLETED: 730AM

DATE REPORTED: 8-31-05

METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

OCT 14 2005

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M8999
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 9-12-05 910AM ANALYSIS:
SAMPLED FROM CLIENT:
DATE GARDENS MOBILE PARK

DISTRICT
SAMPLED BY: RV
DATE/TIME: 9-12-05
TYPE OF SAMPLE: RAW
CHLORINE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE: 21-2

TOTAL COLIFORM PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE
DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=9000/ECOLI=3000/100ML
DATE START: 9-12-05 TIME START: 930AM
DATE COMPLETED: 9-14-05 TIME COMPLETED: 630AM
DATE REPORTED: 9-14-05 METHOD: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER . PHONE 760-344-2573

OCT 14 2005