

## Date Gardens Waste Water Plant

1020 West Evan Hewes SP . 41

Office- (760) 353-0268 / Fax- (760) 353-0268

September 7, 2006

Jose Cortez  
C.R.W.Q.C.B.  
73-720 Fred Waring Drive, Suite 100  
Palm Desert, CA. 92260

Re: August Monthly Self-Monitoring Report.

Mr, Jose Cortez.

Plant operating normally and all effluent limitations were met during the month of August 2006. If you have any further questions don't hesitate to call, please feel free to contact me at your earliest convenience at (760) 427-4235  
Sincerely,



Rocky Vandergriff.  
Chief Operator  
Date Gardens Waste Water Plant

RECEIVED

SEP 07 2006

REGION 7

M 8

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
ORDER NO.: R7-2003-0054  
NPDES NO.: CA0104841  
REPORTING FREQUENCY: MONTHLY

**MONITORING AND REPORTING PROGRAM  
FOR DATE GARDENS MOBILE HOME PARK**  
MONTH August  
YEAR 2006

| TYPE OF SAMPLE: | EFFLUENT |              |                       |          |               |          |         |
|-----------------|----------|--------------|-----------------------|----------|---------------|----------|---------|
| CONSTITUENTS    | Flow     | Sus. Solids  | 20°C BOD <sub>5</sub> | pH       | E. Coli       | Chlorine | TDS     |
| FREQUENCY       | Daily    | Monthly      | Monthly               | Monthly  | 5 Samples/Mo. | Daily    | Monthly |
| DESCRIPTION     |          | 24-Hr. Comp. | 24-Hr. Comp.          | Grab     | Grab          | Grab     | Grab    |
| UNITS           | mgd      | mg/L         | mg/L                  | pH UNITS | MPN/100mL     | mg/L     | mg/L    |
| REQUIREMENTS    |          |              |                       |          |               |          |         |
| 30-DAY MEAN     | 0.021    | 30           | 30                    | 6.0-9.0  | 126           | 0.01     | 2000    |
| 7-DAY MEAN      |          | 45           | 45                    | 6.0-9.0  |               |          | 2500    |
| MAXIMUM         |          |              |                       |          | 400           | 0.02     |         |
| DATE OF SAMPLE  |          |              |                       |          |               |          |         |
| 1               | 0.0096   |              |                       |          |               |          |         |
| 2               | 0.0047   |              |                       |          |               |          |         |
| 3               | 0.0085   |              |                       |          |               |          |         |
| 4               | 0.0087   |              |                       |          |               |          |         |
| 5               | 0.0077   |              |                       |          |               |          |         |
| 6               | 0.0079   |              |                       |          |               |          |         |
| 7               | 0.0078   |              |                       |          |               |          |         |
| 8               | 0.0079   | 6.9          | 28.8                  | 8.4      | 2             | 0        | 414.0   |
| 9               | 0.0090   |              |                       |          | 2             |          |         |
| 10              | 0.0094   |              |                       |          |               |          |         |
| 11              | 0.0093   |              |                       |          |               |          |         |
| 12              | 0.0096   |              |                       |          |               |          |         |
| 13              | 0.0090   |              |                       |          |               |          |         |
| 14              | 0.0094   |              |                       |          |               |          |         |
| 15              | 0.0095   |              |                       |          | 2             |          |         |
| 16              | 0.0097   |              |                       |          | 2             |          |         |
| 17              | 0.0097   |              |                       |          |               |          |         |
| 18              | 0.0089   |              |                       |          |               |          |         |
| 19              | 0.0087   |              |                       |          |               |          |         |
| 20              | 0.0088   |              |                       |          |               |          |         |
| 21              | 0.0094   |              |                       |          |               |          |         |
| 22              | 0.0087   |              |                       |          |               |          |         |
| 23              | 0.0089   |              |                       |          |               |          |         |
| 24              | 0.0095   |              |                       |          |               |          |         |
| 25              | 0.0097   |              |                       |          |               |          |         |
| 26              | 0.0086   |              |                       |          |               |          |         |
| 27              | 0.0089   |              |                       |          |               |          |         |
| 28              | 0.0089   |              |                       |          |               |          |         |
| 29              | 0.0090   |              |                       |          |               |          |         |
| 30              | 0.0093   |              |                       |          | 2             |          |         |
| 31              | 0.0097   |              |                       |          |               |          |         |
| 30-DAY MEAN     | 0.0089   | 6.9          | 28.8                  | 8.4      | 2             | 0        | 414.0   |
| 7-DAY MEAN      |          | 6.9          | 28.8                  | 8.4      | 2             | 0        | 414.0   |
| MAXIMUM         | 0.0097   | 6.9          | 28.2                  | 8.4      | 2             | 0        | 414.0   |


I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Vandenberg

RECEIVED

SEP 07 2006

REGION 7



### Imperial Valley Environmental Laboratory

331 West 2<sup>nd</sup> Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1197  
 Sample ID: M1197  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 08-08-06, 10:35am  
 Temperature: 28° Celcius

Received by: Patty Hardin  
 Date Received: 08-08-06  
 Time Received: 11:50am  
 Test Start Time: 12:00pm  
 Chlorine Residual: 0  
 Date Test Ended: 08-10-06  
 Test End Time: 11:30am

### Analytical Results

| Date     | Final Result      | Test Name  | Count | Volume Tested     |
|----------|-------------------|------------|-------|-------------------|
| 08-10-06 | Total Coliform -- | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-10-06 | Fecal Coliform -  | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-10-06 | E. Coli -         | MPN by MTF | <2    | MPN- 100mL. Water |

Miguel E. Ortega, Laboratory Director

RECEIVED  
 SEP 07 2006  
 REGION 7



### Imperial Valley Environmental Laboratory

331 West 2<sup>nd</sup> Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1201  
 Sample ID: M1201  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 08-09-06, 10:30am  
 Temperature: 29° Celcius

Received by: Patty Hardin  
 Date Received: 08-09-06  
 Time Received: 1:55pm  
 Test Start Time: 2:05pm  
 Chlorine Residual: 0  
 Date Test Ended: 08-11-06  
 Test End Time: 1:30pm

### Analytical Results

| Date     | Final Result      | Test Name  | Count | Volume Tested     |
|----------|-------------------|------------|-------|-------------------|
| 08-11-06 | Total Coliform -- | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-11-06 | Fecal Coliform -  | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-11-06 | E. Coli -         | MPN by MTF | <2    | MPN- 100mL. Water |

Miguel E. Ortega, Laboratory Director

RECEIVED  
 SEP 07 2006  
 REGION 7


**Imperial Valley Environmental Laboratory**

331 West 2<sup>nd</sup> Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1204

Sample ID: M1204

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 08-14-06, 1:00pm

Temperature: 35° Celcius

Received by: Patty Hardin

Date Received: 08-14-06

Time Received: 3:40pm

Test Start Time: 3:50pm

Chlorine Residual: 0

Date Test Ended: 08-16-06

Test End Time: 1:30pm

### Analytical Results

| Date     | Final Result     | Test Name  | Count | Volume Tested     |
|----------|------------------|------------|-------|-------------------|
| 08-16-06 | Total Coliform - | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-16-06 | Fecal Coliform - | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-16-06 | E. Coli -        | MPN by MTF | <2    | MPN- 100mL. Water |

Miguel E. Ortega, Laboratory Director

RECEIVED

SEP 07 2006

REGION 7



### Imperial Valley Environmental Laboratory

331 West 2<sup>nd</sup> Street

Calexico CA, 92231

(Tel) 760-357-8764

(Fax) 760-357-8765

ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1206

Sample ID: M1206

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 08-15-06, 11:30am

Temperature: 24° Celcius

Received by: Patty Hardin

Date Received: 08-15-06

Time Received: 1:30pm

Test Start Time: 1:40pm

Chlorine Residual: 0

Date Test Ended: 08-18-06

Test End Time: 1:00pm

### Analytical Results

| Date     | Final Result     | Test Name  | Count | Volume Tested   |
|----------|------------------|------------|-------|-----------------|
| 08-18-06 | Total Coliform - | MPN by MTF | 4     | MPN-100mL Water |
| 08-18-06 | Fecal Coliform - | MPN by MTF | <2    | MPN-100mL Water |
| 08-18-06 | E. Coli -        | MPN by MTF | <2    | MPN-100mL Water |

Miguel E. Ortega, Laboratory Director

RECEIVED

SEP 07 2006

REGION 7



### Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1221  
 Sample ID: M1221  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 08-29-06, 12:00pm  
 Temperature: 33° Celcius

Received by: Patty Hardin  
 Date Received: 08-29-06  
 Time Received: 2:45pm  
 Test Start Time: 2:55pm  
 Chlorine Residual: 0  
 Date Test Ended: 08-31-06  
 Test End Time: 12:00pm

### Analytical Results

| Date     | Final Result      | Test Name  | Count | Volume Tested     |
|----------|-------------------|------------|-------|-------------------|
| 08-31-06 | Total Coliform -- | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-31-06 | Fecal Coliform -  | MPN by MTF | <2    | MPN- 100mL. Water |
| 08-31-06 | E. Coli -         | MPN by MTF | <2    | MPN- 100mL. Water |

Miguel E. Ortega, Laboratory Director

RECEIVED

SEP 07 2006

REGION 7