

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN

WDID NO.: 7A1310570011  
ORDER NO.: R7-2003-0054  
NPDES NO.: CA0104841  
REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM  
FOR DATE GARDENS MOBILE HOME PARK  
MONTH January  
YEAR 2007

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD <sub>5</sub>	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0097						
2	0.0096						
3	0.0078						
4	0.0096						
5	0.0090						
6	0.0093						
7	0.0098						
8	0.0079						
9	0.0077						
10	0.0078				11		
11	0.0090						
12	0.0093						
13	0.0088						
14	0.0086						
15	0.0087						
16	0.0087						
17	0.0088						
18	0.0094						
19	0.0090						
20	0.0091						
21	0.0098						
22	0.0096				2		
23	0.0090				7		
24	0.0091	8.7	7.4	7.3	4	0	914.0
25	0.0090						
26	0.0088						
27	0.0089						
28	0.0087						
29	0.0085						
30	0.0089				2		
31	0.0090						
30-DAY MEAN	0.0089	8.7	7.4	7.3	4	0	914.0
7-DAY MEAN		8.7	7.4	7.3		0	914.0
MAXIMUM	0.0098	8.7	7.4	7.3	11	0	914.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Winters

RECEIVED

FEB 06 2007

REGION 7

**Imperial Valley Environmental Laboratory**

501 E. Third Street  
Calexico CA, 92231  
(Tel) 760-357-8764  
(Fax) 760-357-8765  
ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Contact : Rocky V.

Log Number: 1330

Sample ID: Effluent (1330)

Date Reported: 01-31-07

Date Sampled: 01-24-07

Date Received: 01-24-07

Sample Type: Water

**Analytical Results**

<u>Analysis</u>	<u>Effluent</u>	<u>Units</u>	<u>Method</u>	<u>DLR</u>	<u>Analysis Date</u>
BOD	7.35	mg/L	SM 5210B	1	01-29-07
Tot. Suspended Solids	8.7	mg/L	SM 2540D	1	01-26-07
Total Dissolved Solids	914.0	mg/L	SM 2540C	1	01-24-07
pH	7.31	units	SM 4500HB	1	01-24-07

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 06 2007

REGION 7



## Imperial Valley Environmental Laboratory

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1439

Sample ID: M1439

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 01-10-07, 12:30pm

Temperature: 6° Celcius

Received by: Patty Hardin

Date Received: 01-10-07

Time Received: 3:10pm

Test Start Time: 3:20pm

Chlorine Residual: 0

Date Test Ended: 01-12-07

Test End Time: 2:31pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-12-07	Total Coliform --	MPN by MTF	130	MPN- 100mL. Water
01-12-07	Fecal Coliform --	MPN by MTF	11	MPN- 100mL. Water
01-12-07	E. Coli --	MPN by MTF	11	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 06 2007

REGION 7


**Imperial Valley Environmental Laboratory**

501 E. Third Street  
 Calexico CA, 92231  
 (Tel) 760-357-8764  
 (Fax) 760-357-8765  
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1454  
 Sample ID: M1454  
 Sample Site: Effluent  
 Collected by: Hector O  
 Date Sampled and Time: 01-22-07, 2:00pm  
 Temperature: 20° Celcius

Received by: Patty Hardin  
 Date Received: 01-22-07  
 Time Received: 2:55pm  
 Test Start Time: 3:05pm  
 Chlorine Residual: 0  
 Date Test Ended: 01-25-07  
 Test End Time: 2:35pm

### Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-25-07	Total Coliform --	MPN by MTF	11	MPN- 100mL. Water
01-25-07	Fecal Coliform -	MPN by MTF	2	MPN- 100mL. Water
01-25-07	E. Coli -	MPN by MTF	2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 06 2007

REGION 7