

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011
 ORDER NO.: R7-2003-0054
 NPDES NO.: CA0104841
 REPORTING FREQUENCY: MONTHLY


MONITORING AND REPORTING PROGRAM
 FOR DATE GARDENS MOBILE HOME PARK
 MONTH November
 YEAR 2007

TYPE OF SAMPLE: EFFLUENT							
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0097						
2	0.0085				2		
3	0.0087						
4	0.0088						
5	0.0079						
6	0.0074						
7	0.0071						
8	0.0070						
9	0.0076				2		
10	0.0072						
11	0.0080						
12	0.0085						
13	0.0084						
14	0.0096						
15	0.0088						
16	0.0083				8		
17	0.0084						
18	0.0086						
19	0.0082				8		
20	0.0087						
21	0.0081						
22	0.0080						
23	0.0075						
24	0.0081						
25	0.0083						
26	0.0084						
27	0.0082						
28	0.0087	1.00	4.4	7.0	11	0	952.0
29	0.0081						
30	0.0079						
30-DAY MEAN	0.0082	1.0	4.4	7.0	5	0	952.0
7-DAY MEAN		1.0	4.4	7.0		0	952.0
MAXIMUM	0.0097	1.0	4.4	7.0	8	0	952.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Nordberg

RECEIVED



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2006
 Sample ID: M2006R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 11-01-07, 12:00pm
 Temperature: 3° Celcius

Received by: Patty Hardin
 Date Received: 11-01-07
 Time Received: 1:45pm
 Test Start Time: 1:55pm
 Chlorine Residual: 0
 Date Test Ended: 11-05-07
 Test End Time: 1:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
11-05-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
11-05-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
11-05-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
 DEC 10 2007
 REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2020
 Sample ID: M2020R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 11-08-07, 9:00am
 Temperature: 1° Celcius


Received by: Patty Hardin
 Date Received: 11-08-07
 Time Received: 11:45am
 Test Start Time: 12:15pm
 Chlorine Residual: 0
 Date Test Ended: 11-10-07
 Test End Time: 11:30am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
11-10-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
11-10-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
11-10-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
 DEC 10 2007
 REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.


Log Number: M2032
Sample ID: M2032R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 11-15-07, 12:00pm
Temperature: 2° Celcius

Received by: Patty Hardin
Date Received: 11-15-07
Time Received: 1:42pm
Test Start Time: 1:20pm
Chlorine Residual: 0
Date Test Ended: 11-17-07
Test End Time: 1:30pm

Analytical Results

<u>Date</u>	<u>Final Result</u>	<u>Test Name</u>	<u>Count</u>	<u>Volume Tested</u>
11-17-07	Total Coliform -	MPN by MTF	8	MPN- 100mL. Water
11-17-07	Fecal Coliform -	MPN by MTF	8	MPN- 100mL. Water
11-17-07	E. Coli -	MPN by MTF	8	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2039
Sample ID: M2039R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 11-19-07, 10:40am
Temperature: 6° Celcius

Received by: Patty Hardin
Date Received: 11-19-07
Time Received: 12:53pm
Test Start Time: 1:20pm
Chlorine Residual: 0
Date Test Ended: 11-21-07
Test End Time: 12:45pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
11-21-07	Total Coliform -	MPN by MTF	80	MPN- 100mL. Water
11-21-07	Fecal Coliform -	MPN by MTF	80	MPN- 100mL. Water
11-21-07	E. Coli -	MPN by MTF	80	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director