



# California Regional Water Quality Control Board

## Colorado River Basin Region



Linda S. Adams  
Secretary for  
Environmental Protection

73-720 Fred Waring Drive, Suite 100, Palm Desert, California 92260  
(760) 346-7491 • Fax (760) 341-6820  
<http://www.waterboards.ca.gov/coloradriver>

Arnold Schwarzenegger  
Governor

September 25, 2008

Rocky Vandergriff  
1020 West Evan Hewes SP 41  
P.O. Box 815  
Seeley, CA 92273

**RE: DATE GARDENS MOBILE HOME PARK, VIOLATION OF BOARD ORDER NO. R7-2008-0010.**

The Date Gardens Mobile Home Park is in violation of the Effluent Limitations and Discharge Specifications of Board Order No. R7-2008-0010 for failing to comply with the bacterial density in the wastewater effluent for Escherichia coli (E. coli), Enterococci, and Fecal Coliform during the month of August 2008.

Effluent Limitations and Discharge Specifications stipulated on Board Order No. 2008-0010 state that : Based on a minimum of not less than 5 samples equally spaced over a 30-day period, the bacterial density in the wastewater effluent shall not exceed: the geometric mean bacterial density of the Most Probable Number /100 ml of water (MPN) of 126, and 33 nor shall any sample exceed the maximum allowable bacterial density of 400 and 100 MPN, for E. coli and Enterococci, respectively. In addition, the geometric mean bacterial density for Fecal Coliform shall not exceed a MPN of 200, nor shall more than 10% of the total samples during any 30-day period exceed 400 MPN.

A review of the August 2008 Monthly Monitoring Report, reveals that the water sample collected on August 13<sup>th</sup> and 15<sup>th</sup> reported an E. coli concentration > 1600 MPN. Also, the water sample collected on August 19<sup>th</sup> reported an Enterococci concentration = 200 MPN. These values constitute a violation of the maximum allowable bacterial density of the 400 and 100 MPN for E. coli and Enterococci, respectively. In addition, more than 10% of the total samples collected during the month exceeded the 400 MPN for Fecal Coliform as stipulated on the Effluent Limitation of Board Order No. 2008-0010.

In future monitoring reports, as required in the monitoring program, the cover letter shall clearly identify violations of the Waste Discharge Requirements and their corrective actions.

*California Environmental Protection Agency*


Recycled Paper



25.002

Finally, a review of our files indicates that, the Date Gardens MHP failed to submit a self monitoring report for the month of July 2008. In order to avoid the issuance of a non compliance letter, please submit the July 2008 report as soon as possible.

Failure to comply with the requirements of Board Order No. R7-2008-0010 is a violation of State law and may result in further enforcement actions including the imposition of administrative civil liability claims. If you have any questions concerning this matter, please contact me at (760) 776-8967.



Jose Figueroa-Acevedo  
Water Resources Control Engineer

Cc Doug Wylie, RWQCB

File: WDID No. 7A131057 001, Date Gardens MHP, Board Order No. R7-2008-0010



# California Regional Water Quality Control Board

## Colorado River Basin Region



Linda S. Adams  
Secretary for  
Environmental Protection

73-720 Fred Waring Drive, Suite 100, Palm Desert, California 92260  
(760) 346-7491 • Fax (760) 341-6820  
<http://www.waterboards.ca.gov/coloradriver>

Arnold Schwarzenegger  
Governor

December 11, 2008

Rocky Vandergriff  
1020 West Evan Hewes SP 41  
P.O. Box 815  
Seeley, CA 92273

**RE: DATE GARDENS MOBILE HOME PARK, VIOLATION OF BOARD ORDER NO. R7-2008-0010.**

The Date Gardens Mobile Home Park is in violation of the Effluent Limitations and Discharge Specifications of Board Order No. R7-2008-0010 for failing to comply with the monthly geometric mean and the maximum sample effluent concentration for Enterococci during the month of November 2008.

Board Order No. 2008-0010 states", for Enterococci, the geometric mean bacterial density (based on a minimum of not less than 5 samples equally spaced over a 30-day period) shall not exceed a Most Probable Number /100 ml of water (MPN) of 33 nor shall any sample exceed the maximum allowable bacterial density of 100 MPN."

A review of the November 2008 Monthly Monitoring Report, reveals that the sample collected on November 19<sup>th</sup> reported an Enterococci concentration of 461.1 MPN and the monthly average was reported as 72 MPN, respectively. These values constitute violations of the 100 and the 33 MPN required for compliance with the instantaneous maximum and the geometric mean monthly effluent requirements stipulated on the Board Order No. 2008-0010.

In future monitoring reports, as required in the monitoring program, the cover letter shall clearly identify violations of the Waste Discharge Requirements and their corrective actions.

Failure to comply with the requirements of Board Order No. R7-2008-0010 is a violation of State law and may result in further enforcement actions including the imposition of administrative civil liability claims. If you have any questions concerning this matter, please contact me at (760) 776-8967.

Jose Figueroa-Acevedo  
Water Resources Control Engineer

Cc Doug Wylie, RWQCB  
File: WDID No. 7A131057 001, Date Gardens MHP, Board Order No. R7-2008-0010



2591024



# California Regional Water Quality Control Board

## Colorado River Basin Region



Linda S. Adams  
Secretary for  
Environmental Protection

73-720 Fred Waring Drive, Suite 100, Palm Desert, California 92260  
(760) 346-7491 • Fax (760) 341-6820  
<http://www.waterboards.ca.gov/coloradoriver>

Arnold Schwarzenegger  
Governor

March 26, 2009

Rocky Vandergriff  
1020 West Evan Hewes SP 41  
P.O. Box 815  
Seeley, CA 92273

**RE: DATE GARDENS MHP, VIOLATION OF BOARD ORDER NO. R7-2008-0010.**

The Date Gardens MHP is in violation of the Effluent Limitations and Discharge Specifications of Board Order No. R7-2008-0010 for failing to comply the daily maximum effluent limitation for Enterococci, during the month of December 2008.

Compliance with the Enterococci bacterial effluent limitations requires that the daily maximum allowable not exceed a Most Probable Number (MPN) of 100 MPN per 100 ml. A review of the December 2008 Monthly Monitoring Report (MMR), reveals that the water sample collected on December 11<sup>th</sup> had an Enterococci concentration of 2420 MPN per 100 ml. This value constitute a violation of the 100 MPN per 100 ml required to comply with the daily maximum effluent stipulated on the Board Order No. 2008-0010.

Finally, in all of your future MMR please, include as part of the cover letter, a summary identifying all of the violations of waste discharge requirements.

Failure to comply with the requirements of Board Order No. R7-2008-0010 is a violation of State law and may result in further enforcement actions including the imposition of administrative civil liability claims. If you have any questions concerning this matter, please contact me at (760) 776-8967.

Jose Figueroa  
Water Resources Control Engineer

Cc Doug Wylie, RWQCB

File: WDID No. 7A131057 011, Date Gardens MHP, Board Order No. R7-2008-0010





# California Regional Water Quality Control Board

## Colorado River Basin Region



Linda S. Adams  
Secretary for  
Environmental Protection

73-720 Fred Waring Drive, Suite 100, Palm Desert, California 92260  
(760) 346-7491 • Fax (760) 341-6820  
<http://www.waterboards.ca.gov/coloradoriver>

Arnold Schwarzenegger  
Governor

April 22, 2008

Rocky Vandergriff  
1020 West Evan Hewes SP 41  
P.O. Box 815  
Seeley, CA 92273

**RE: DATE GARDENS MHP, VIOLATION OF BOARD ORDER NO. R7-2003-0054.**

The Date Gardens MHP is in violation of the Effluent Limitations and Discharge Specifications of Board Order No. R7-2003-0054 for failing to comply the daily maximum effluent limitation for Escherichia coli (E. coli) during the month of March 2008.

Effluent Limitations and Discharge Specifications, state that: Wastewater effluent discharged shall not have an E. coli concentration in excess of a log mean of Most Probable Number (MPN) of 126 MPN per 100 milliliters of water (based on a minimum of not less than five samples for any calendar month with a minimum of one sample per week) nor shall any sample exceed 400 MPN per 100 milliliters of water, respectively.

A review of the March 2008 Monthly Monitoring Report (MMR), reveals that the water sample collected on March 25<sup>th</sup> had an E. coli concentration of >1600 MPN per 100 milliliters of water. This value constitute a violation of the 400 MPN per 100 milliliters of water daily maximum effluent for the E. coli concentration stipulated on the Effluent Limitation for E. coli concentration of Board Order No. 2003-0054.

Finally, in all of your future MMR please, include as part of the cover letter, a summary identifying all of the violations of waste discharge requirements.

Failure to comply with the requirements of Board Order No. R7-2003-0054 is a violation of State law and may result in further enforcement actions including the imposition of administrative civil liability claims. If you have any questions concerning this matter, please contact me at (760) 776-8967.

  
Jose Figueroa-Acevedo  
Water Resources Control Engineer

Cc: Doug Wylie, RWQCB  
File: WDID No. 7A131057 001, Date Gardens MHP, Board Order No. R7-2003-0054

011 35  
**California Environmental Protection Agency**

Recycled Paper



246523



# California Regional Water Quality Control Board

## Colorado River Basin Region



**Linda S. Adams**  
Secretary for  
Environmental Protection

73-720 Fred Waring Drive, Suite 100, Palm Desert, California 92260  
(760) 346-7491 • Fax (760) 341-6820  
<http://www.waterboards.ca.gov/coloradriver>

**Arnold Schwarzenegger**  
Governor

May 6, 2009

Rocky Vandergriff  
1020 West Evan Hewes SP 41  
P.O. Box 815  
Seeley, CA 92273

**RE: DATE GARDENS MHP, VIOLATION OF BOARD ORDER NO. R7-2008-0010.**

The Date Gardens MHP is in violation of the Effluent Limitations and Discharge Specifications of Board Order No. R7-2008-0010 for failing to achieve the average percentage efficiency required for the removal of Total Suspended Solids (TSS), during the month of March 2009.

Effluent Limitations stipulated on the Board Order No. R7-2008-0010 states that the monthly average removal efficiency for TSS shall be 85%. Your monthly average removal efficiency for TSS for the month of March 2009 was reported as 75%.

Failure to comply with the requirements of Board Order No. R7-2008-0010 is a violation of State law and may result in further enforcement actions including the imposition of administrative civil liability claims. If you have any questions concerning this matter, please contact me at (760) 776-8967.

Jose Figueroa-Acevedo  
Water Resources Control Engineer

Cc: Doug Wylie, RWQCB  
File: WDID No. 7A131057 011, Date Gardens MHP, Board Order No. R7-2008-0010

