

California Regional Water Quality Control Board, Colorado River Basin
Prosecution Team Evidence
on the matter of
Administrative Civil Liability Complaint R7-2014-0041
Exhibit 13



CITY OF BRAWLEY

PUBLIC WORK / CITY ENGINEER
180 SOUTH WESTERN AVENUE
BRAWLEY, CALIFORNIA
92227
PHONE (760) 344-5800
FAX (760) 344-5612

April 14, 2003

Mr. Kirk Larkin
California Regional Water Quality Control Board
Colorado River Basin Region
73-270 Fred Waring Drive, Ste. 100
Palm Desert, CA 92268

Subject: Monthly Status of Activities as part of the TRE.

Dear Mr. Larkin:

The City has discovered the following areas of concerns in its Collection System.

- The lift station located at Citrus View Subdivision has elevated levels of Ammonia >30 ppm.
- A Fertilizer Spreading Business located on the central collector has been discharging high levels of Ammonia >50 ppm.
- The Beef Plant has continued its elevated Ammonia Discharge. However the City has notified and put them on notice.
- The West Collector has a level of 10-15 ppm of Ammonia.
- The East Collector has a level of 15-20 ppm of Ammonia.
- The City will begin conducting operation survey of the suspected businesses that are impacting our Facility.

Pioneers Memorial Hospital has been surveyed and no elevated Ammonia Discharge have been noted at their point of connection.

Currently the Public Works Department is procuring a software program for industrial waste dischargers, in addition the City is working with Berryman and Henigar a Consulting group from San Diego to establish Industrial user Discharge Rates.

If you have any questions, please contact me at (760) 344-5800 Ext. 11.

Sincerely,

Ruben Mireles
Superintendent of Operations

RECEIVED
APR 15 2003
REGION 7