

Item No. 8

September 13, 2013

ERRATA SHEET

CHANGES TO TENTATIVE ORDER NO. R8-2013-0017

NPDES No. CA8000027

Renewal of Waste Discharge and Producer/User Reclamation Requirements
for Elsinore Valley Municipal Water District, Regional Water Reclamation Facility,
Riverside County

(Language deleted is ~~strike through~~)

(Language added is **bold and underlined**)

Monitoring and Reporting Program Page E-8:

Table 3. Influent Monitoring Requirements

Constituent	Units	Type of Sample	Minimum Frequency of Sampling & Analysis (See I.13., above)	Required Analytical Test Method
Flow	MGD	Recorder/Totalizer	Continuous	
Specific Conductance	µmhos/cm	Recorder	"	See Section I.2., above
pH	pH units	"	"	"
BOD ₅	mg/L	Composite	Daily	"
Total Suspended Solids	"	"	"	"
Total Inorganic Nitrogen (TIN)	mg/L	Composite	Monthly	
Ammonia-Nitrogen	"	Grab	"	"
Total Nitrogen	"	Composite	"	"
Total Phosphorous	"	Composite	"	"
Total Dissolved Solids	"	Composite	"	"
Volatile organic portion of EPA Priority Pollutants ¹ (See Attachment G)	µg/L	Grab	Monthly <u>Annually</u>	"
Remaining EPA Priority Pollutants ² (See Attachment G)	"	Composite	"	"

¹ EPA priority pollutants are those remaining volatile organic pollutants listed in Attachment G which are not specifically listed in this monitoring program table.

² Remaining EPA priority pollutants are those pollutants listed in Attachment G which are not volatile organics and pollutants not specifically listed in this monitoring program table.