California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Linda S. Adams
Secretary for Environmental Protection

Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
http:// www.waterboards.ca.gov/sandiego

October 29, 2008

In Reply Refer to:
CIWQS ID: 354062

Mr. Ogden Watson
General Manager
Pauma Valley Community Services District
33129 Cole Grade Road
P.O. Box 434
Pauma Valley, CA 92061

Dear Mr. Watson:

SUBJECT: REVIEW OF MONITORING REPORTS FOR ORDER NO. R9-2006-0049 PAUMA VALLEY WASTEWATER TREATMENT PLANT

The California Regional Water Quality Control Board, San Diego Region (Regional Board) has reviewed the January - March 2008 and April - June 2008 quarterly monitoring reports submitted by the Pauma Valley Community Services District (District) for Monitoring and Reporting Program No. R9-2006-0049.

The Regional Board has identified the following violations of Order No. R9-2006-0049:

1. The effluent total suspended solids (TSS) concentrations were reported as 47 mg/L, 56 mg/L, and 54 mg/L on February 5 and12, 2008, and on May 27, 2008 respectively. Discharge Specification B2 of Order No.R9-2006-0049 states that the daily effluent TSS concentration shall not exceed 45 mg/L.

2. The 30-day average effluent TSS concentrations were reported as 49 mg/L and 36.75 mg/L for February 2008 and May 2008 respectively. Discharge Specification B2 of Order No. R9-2006-0049 states that the monthly average effluent TSS concentration shall not exceed 45 mg/L.

Please take adequate measures to prevent further violations of Order No.R9-2006-0049. The cited violations are not a priority for further enforcement action unless similar violations in the future demonstrate that the District is having chronic problems complying with Order No. R9-2006-0049.

The heading portion of this letter includes a Regional Board code number noted after "In reply refer to". In order to assist us in the processing of your correspondence please include this code number in the heading or subject line portion of all correspondence and reports to the Regional Board pertaining to this matter.

If you have any questions regarding the above, please contact Mr. Fisayo Osibodu at (858) 637-5594 or via e-mail at Oosibodu@waterboards.ca.gov.

Sincerely,

Julie Chan

Julie Chan, P.G
Supervising Engineering Geologist
Ground Water Basins Branch

JC: rwm: oo

Violations: 791170, 791172, 791174, 791176, 791178

Enforcement: (SEL), 354062