

Rancho Santa Fe Fire District, 16936 El Fuego, Rancho Santa Fe, California

Staff Contact: Sean McClain

The San Diego Water Board intends to issue a no further action letter for an unauthorized release of petroleum fuel wastes from a leaking underground storage tank (UST) system at the Rancho Santa Fe Fire Department (RSFFD), Rancho Santa Fe, California. This public notice fulfills the San Diego Water Board's obligation to inform the public of the unauthorized release of petroleum fuel, completed corrective actions, and a completed human health risk assessment as required by California Code of Regulations (CCR), Title 23, Division 3, Chapter 16, Article 11, section 2728. Since 1992, several phases of remedial activities were completed at the Site, including excavation and disposal of soil and recovery and treatment of groundwater, and soil vapor extraction using a high vacuum dual-phase extraction system. Ninyo & Moore (RSFFD consultant) concluded that the extent the residual concentrations in groundwater are naturally attenuating, and current groundwater conditions do not pose a threat to human health, safety, or the environment, and the unauthorized release case can be closed.

The case files are available for public review by submitting a file review request to the San Diego Water Board office, or on-line from the [GeoTracker database](#). Provided no significant issues arise during the public notification period, the San Diego Water Board will issue a no further action letter after February 29, 2012.