

California Regional Water Quality Control Board, San Diego Region

June 13, 2014

In reply refer to:
263145:icanada

Ms. Jayne E. Joy, P.E.
Director of Environmental and Regulatory Compliance
Eastern Municipal Water District
P.O. Box 8300
Perris, CA. 92572-8300

Subject: Review of Monitoring Reports for Temecula Valley Regional Water Reclamation Facility, Order No. 2000-165

Ms. Joy:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following monitoring reports submitted by the Eastern Municipal Water District in accordance with the Monitoring and Reporting Program of Order No. 2000-165: March 2012-April 2014 monthly monitoring reports; January-June 2012, January-June 2013, and July-December 2013 semi-annual monitoring reports; and the 2011, 2012, and 2013 annual pretreatment reports.

The report lists violations of Section B.3 in Order No. 2000-165 for the daily maximum effluent limitation for manganese, established at 0.06 (mg/L). A tabulated list of violation dates and concentrations is provided below:

Date	mg/L
October 10, 2012	0.074
January 7, 2013	0.070
August 14, 2013	0.068
September 4, 2013	0.270
November 13, 2013	0.160
November 20, 2013	0.160
March 26, 2014	0.120
March 27, 2014	0.160

Please take steps to implement follow-up actions necessary to ensure that the violation noted above does not occur in the future. These violations subject the District to possible further enforcement action by the San Diego Water Board including administrative enforcement orders requiring the District to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil

liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.


The San Diego Water Board has the following comments regarding the reports referenced in paragraph one above:

1. Effluent values for manganese, iron, and boron were reported in units of micrograms/liter (ug/L). Please ensure effluent values for these chemical constituents are reported in units of milligrams per liter (mg/L) as specified by Section B.2 in Monitoring and Reporting Program No. 2001-165.
2. Please include the addresses of all Significant Industrial Users (SIUs) which violated any discharge or reporting requirements in the semi-annual SIU compliance status report, as required by Section E.5.a in Order No. 2000-165.
3. Please ensure that future Recycled Water Users Summary Reports include the number of the hydrologic subarea underlying the recycled water use site as required by Section E.1.d in Monitoring and Reporting Program No. 2000-165.
4. The annual monitoring report (which must include analysis results for constituents specified by Section B.2 in Order No. 2000-165) and the annual recycled water compliance report are both due by January 30 each year as required by Sections F and E.2 of Monitoring and Reporting Program No. 2000-165. The annual pretreatment report is due March 30 of each year as required by Section E.4 of Order No. 2000-165. Please submit the annual pretreatment report under separate cover from the annual monitoring report and the annual recycled water compliance report.

The next monitoring report required to be submitted is the May 2014 monthly monitoring report, due by June 30, 2014.

In the subject line of any response, please include reference 263145: lcanada. Please contact Ms. Leah Canada at 619-521-8050, or at Leah.Canada@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G., Senior Engineering Geologist
Land Discharge Unit

JRO: oo: lc

¹ Under authority of California Water Code section 13350.

Tech Staff Info & Use	
Place ID	263145
Reg. Measure ID	396707
Violation ID	970133, 970134
	970136, 970138
	970139, 970141
	970142, 970143