

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

ORDER NO. 86-61  
NPDES NO. CA 0028649

WASTE DISCHARGE REQUIREMENTS FOR:

INTEL CORPORATION  
FAB 1 FACILITY AND FIRE POND  
SANTA CLARA, SANTA CLARA COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region, (hereinafter called the Board) finds that:

1. Intel Corporation, hereinafter called the discharger, by application dated June 9, 1986, has applied for renewal of waste discharge requirements and a permit to discharge waste under the National Pollutant Discharge Elimination System (NPDES).
2. The discharger is manufacturing integrated circuits using semiconductor manufacturing processes.
3. The report of waste discharge describes the existing discharges as follows:
  - a. Waste No. 001 consists of reverse osmosis reject water. In the manufacturing process, de-ionized water (DI) is required. A reverse osmosis membrane system is used to produce DI water from tap water. The discharger proposes to discharge up to approximately 25,920 gallons per day of reverse osmosis reject water to a storm drain tributary to San Tomas Aquino Creek tributary to Guadalupe Slough tributary to South San Francisco Bay.
  - b. Waste No. 002 consists of filter backwash water. The waste is produced from the backwashing of the filters used for the pond located at the discharger's facility. The purpose of the pond is for the storage of water for the suppression of possible fires occurring at the facility. Santa Clara city water is used to fill the fire pond. Filtering is accomplished by the use of jacuzzi filters (swimming pool filters) to purify the city waters. Filter backwashing, using city water, occurs approximately twice a week. The discharger proposes to discharge up to approximately 230 gallons per day (575 gallons per backwashing) of filter backwash water to a storm drain tributary to San Tomas Aquino Creek tributary to Guadalupe Slough tributary to South San Francisco Bay.
4. The Regional Board adopted a Water Quality Control Plan for the San Francisco Bay Region (Basin Plan) on July 21, 1982.

The Basin Plan contains water quality objectives for San Tomas Aquino Creek, Guadalupe Slough, and South San Francisco Bay and its tributaries.

5. The beneficial uses of San Tomas Aquino Creek, Guadalupe Slough and South San Francisco Bay are:
  - a. Water contact recreation
  - b. Non-contact water recreation
  - c. Fish migration and habitat
  - d. Wildlife habitat
  - d. Esthetic enjoyment
  - e. Industrial service supply
  - f. Navigation
  - g. Commercial and sport fishing
  - h. Marine habitat
  - i. Shellfish harvesting
6. The Basin Plan prohibits discharge of any wastewater which has particular characteristics of concern to beneficial uses at any point at which the wastewater does not receive a minimum initial dilution of 10:1 and also prohibits discharge of wastewater south of the Dumbarton Bridge. The Board finds that the proposed discharge does not have particular characteristics of concern, provided the discharge limitations contained in this Order are met.
7. Effluent limitations and toxic effluent standards established pursuant to Sections 301, 304, and 307 of the Federal Water Pollution Control Act, and amendments thereto are applicable to the discharge of Wastes 001 and 002.
8. Effluent limitation guidelines requiring the application of best available technology economically achievable (BAT) for this point source discharge have not been promulgated by the U.S. Environmental Protection Agency. Effluent limitations of this Order are based on the Basin Plan, State plans and policies, current plant performance, and best professional judgement. The limitations are considered to be those attainable utilizing BAT, in the judgement of the Board.
9. The issuance of waste discharge requirements for this discharge (001 and 002) is exempt from the provisions of Chapter 3 (commencing with Section 21000 of Division 13) of the Public Resources Code (CEQA) pursuant to Section 13389 of the California Water Code.
10. The Board has notified the discharger and interested agencies and persons of its intent to reissue waste discharge requirements for the discharge (001 and 002) and has provided them with an opportunity for a public hearing and an opportunity to submit their written views and recommendations.

11. The Board, in a public meeting, heard and considered all comments pertaining to the discharge of 001 and 002.

IT IS HEREBY ORDERED that, Intel Corporation, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, and the provisions of the Federal Water Pollution Control Act and regulations and guidelines adopted thereunder, shall comply with the following.

A. Effluent Limitations

1. The discharge of an effluent for 001 in excess of the following is prohibited:

	<u>Units</u>	<u>Daily Maximum</u>
a. Total Dissolved Solids	mg/l	2000
b. Chlorine*	mg/l	0.0

2. The discharge of an effluent for 002 in excess of the following is prohibited:

	<u>Units</u>	<u>Daily Maximum</u>	<u>Monthly Average</u>
a. Total Suspended Solids	mg/l	30	15
b. Settleable Matter	ml/l-hr	0.2	0.1
c. Chlorine*	mg/l	0.0	0.0
d. Total Dissolved Solids	mg/l	2000	

3. The effluent for 001 and 002 shall not have a pH of less than 6.5 nor greater than 8.5.

4. In any representative set of samples, the waste as discharged shall meet the following limit of quality:

TOXICITY:

The survival of Rainbow Trout test fishes in 96 hour bioassays of the effluent shall achieve a median of 90% survival for three consecutive samples and a 90 percentile value of not less than 70% survival for 10 consecutive samples.

5. The discharge (001 and 002) shall be limited to wastewater of the quantity and type described in Finding No. 3 of this Order.

B. Receiving Water Limitations

1. The discharge of waste from 001 and 002 shall not cause the following conditions to exist in waters of the State at any place:

- a. Floating, suspended, or deposited macroscopic

\* Compliance with this limitation may be demonstrated in the storm drain prior to discharge into San Tomas Aquino Creek.

particulate matter or foam;

- b. Bottom deposits or aquatic growths;
  - c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
  - d. Visible, floating, suspended or deposited oil or other products of petroleum origin;
  - e. Toxic or other deleterious substances to be present in concentrations or quantities which will cause deleterious effects on aquatic biota, wildlife or waterfowl, or which render any of these unfit for human consumption either at levels created in the receiving waters or as a result of biological concentration.
2. The discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Board or the State Water Resources Control Board as required by the Federal Water Pollution Control Act and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Federal Water Pollution Control Act, or amendments thereto, the Board will revise and modify this Order in accordance with such more stringent standards.


#### C. Provisions

1. The discharger shall comply with all effluent and receiving water limitations and provisions of this Order immediately upon adoption.
2. Where concentration limitations in mg/l are contained in this permit, the following mass emission limitations shall also apply as follows:  
  
$$\text{Mass Emission Limit in kg/d} = \text{Concentration Limit in mg/l} \times 3.79 \times \text{Actual Flow in mgd averaged over the time interval to which the limit applies.}$$
3. The discharger shall file with the Board technical reports on self-monitoring work performed according to the detailed specifications contained in the Self-Monitoring and Reporting Program adopted by the Board and as may be amended by the Executive Officer.
4. The discharger shall review and update annually its contingency plan as required by Board Resolution No. 74-10. The discharge of pollutants in violation of this Order where the discharger has failed to develop and/or implement a contingency plan will be basis for

considering such discharge a willful and negligent violation of this Order pursuant to Section 13387 of the California Water Code.

5. All applications, reports, or information submitted to the Regional Board shall be signed and certified pursuant to Environmental Protection Agency regulations (40 CFR 122.41K).
6. The discharger shall comply with all the items of the attached "Standard Provisions" dated April 1977 except Provisions and Requirements A.5, A.7, A.12, and B.5.
7. Pursuant to Environmental Protection Agency regulations (40 CFR 122.42(a)) the discharger must notify the Regional Board as soon as it knows or has reason to believe that a discharge of a pollutant not limited by this permit has or will occur.
8. This order shall serve as a National Pollutant Discharge Elimination System permit pursuant to Section 402 of the Federal Water Pollution Control Act, or amendments thereto, and shall take effect at the end of ten days from date of hearing provided the Regional Administrator of the U.S. Environmental Protection Agency has no objections. If the Regional Administrator objects to its issuance, the permit shall not become effective until such objection is withdrawn.
9. The requirements prescribed by this Order supercede the requirements prescribed by Order No. 81-33 adopted on June 17, 1981. Order No. 81-33 is hereby rescinded.
10. This Order expires on August 20, 1991. The discharger must file a Report of Waste Discharge in accordance with Title 23, Chapter 3, Subchapter 9, of the California Administrative Code not later than 180 days in advance of such expiration date as application for issuance of new waste discharge requirements.

I, Roger B. James, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on August 20, 1986.



ROGER B. JAMES  
Executive Officer

Attachments:

Standard Provisions & Reporting  
Requirements dated April 1977  
Self-Monitoring Program



CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

SELF-MONITORING PROGRAM  
FOR

INTEL CORPORATION

3601 JULIETTE LANE

SANTA CLARA, SANTA CLARA COUNTY

NPDES NO. CA 0028649

ORDER NO. 86-61

CONSISTS OF

PART A

AND

PART B

PART B

I. DESCRIPTION OF SAMPLING STATIONS

A. Effluent

<u>Station</u>	<u>Description</u>
E-001	At any point in the outfall between the point of discharge of 001 and the point at which all waste tributary to that outfall is present.
E-002	At any point in the outfall between the point of discharge of 002 and the point at which all waste tributary to that outfall is present.

II. SCHEDULE OF SAMPLING AND ANALYSIS

- A. The schedule of sampling and analysis for Station E-001 and E-002 shall be that given in Table I.
- B. Reports shall be submitted on January 15, April 15, July 15 and October 15.

I, Roger B. James, Executive Officer, hereby certify that the foregoing Self-Monitoring Program:

1. Has been developed in accordance with the procedure set forth in this Regional Board's Resolution No. 73-16 in order to obtain data and document compliance with waste discharge requirements established in Regional Board Order No. 86-61.
2. Does not include the following paragraphs of Part A:  
D.1, D.2a, D.3, D.4, E.2.b, E.4, F.3.f and F.3.g.
3. Is effective on the date shown below.
4. May be reviewed at any time subsequent to the effective date upon written notice from the Executive Officer or request from the discharger, and revisions will be ordered by the Executive Officer.

  
ROGER B. JAMES  
Executive Officer

Attachment:  
Table I (2 pages)

Effective Date August 28, 1986



TABLE 1 (continued)

SCHEDULE FOR SAMPLING, MEASUREMENTS, AND ANALYSIS

Sampling Station	E-001	E-002											
TYPE OF SAMPLE	G	G											
Mercury (mg/l & kg/day)													
Nickel (mg/l & kg/day)													
Zinc (mg/l & kg/day)													
Phenolic Compounds (mg/l & kg/day)													
All Applicable Standard Observations													
Bottom Sediment Analyses and Observations													
Tot. Ident. Chlori. Hydro- carbons (mg/l & kg/day)													
Total Dissolved Solids (mg/l & kg/day)	W	M											

LEGEND FOR TABLE

TYPES OF SAMPLES

- G = grab sample
- C-24 = composite sample - 24-hour
- C-X = composite sample - X hours  
(used when discharge does not  
continue for 24-hour period)
- Cont = continuous sampling
- DI = depth-integrated sample
- BS = bottom sediment sample
- O = observation

TYPES OF STATIONS

- I = intake and/or water supply stations
- A = treatment facility influent stations
- E = waste effluent stations
- C = receiving water stations
- P = treatment facilities perimeter stations
- L = basin and/or pond levee stations
- B = bottom sediment stations
- G = groundwater stations

FREQUENCY OF SAMPLING

- E = each occurrence
- H = once each hour
- D = once each day
- W = once each week
- M = once each month
- Y = once each year
- 2/H = twice per hour
- 2/W = 2 days per week
- 5/W = 5 days per week
- 2/M = 2 days per month
- 2/Y = once in March and  
once in September
- Q = quarterly, once in  
March, June, Sept.  
and December
- 2H = every 2 hours
- 2D = every 2 days
- 2W = every 2 weeks
- 3M = every 3 months
- Cont = continuous