

**ORDER NO. R2-2014-1006**  
**ACCEPTANCE OF CONDITIONAL RESOLUTION**  
**AND WAIVER OF RIGHT TO HEARING**

By signing below and returning this Acceptance of Conditional Resolution and Waiver of Right to Hearing (Acceptance and Waiver) to the Regional Water Quality Control Board (Regional Water Board), San Francisco Public Utilities Commission (SFPUC) hereby accepts the "Offer to Participate in Expedited Payment Program" and waives the right to a hearing before the Regional Water Board to dispute the allegations of violations described in the Notice of Violation which is attached hereto as Exhibit A and incorporated herein by reference.

SFPUC agrees that the attached Exhibit A shall serve as a complaint pursuant to Article 2.5 of the California Water Code (CWC) and that no separate complaint is required for the Regional Water Board to assert jurisdiction over the alleged violations through its Assistant Executive Officer. SFPUC agrees to pay the penalties authorized by CWC section 13385, which shall be deemed payment in full of any civil liability pursuant to the CWC sections 13385 and 13385.1 that otherwise might be assessed for the violations described in the attached Exhibit A.

SFPUC understands that this Acceptance and Waiver does not address or resolve liability for any violation that is not specifically identified in the attached Exhibit A.

Upon execution by SFPUC, the Acceptance and Waiver shall be returned to:

Expedited Payment Program  
California Regional Water Quality Control Board  
San Francisco Bay Region  
NPDES Enforcement Section, Regulatory Measure ID No. 389684  
Attention: Farhad Azimzadeh  
1515 Clay Street, Suite 1400  
Oakland, California 94612

SFPUC understands that federal regulations set forth at title 40, Code of Federal Regulations, section 123.27(d)(2)(iii) require the Regional Water Board to publish notice of and provide at least 30 days for public comment on any proposed resolution of an enforcement action. Accordingly, this Acceptance and Waiver, prior to execution by the Executive Officer of the Regional Water Board, will be published as required by law for public comment.

If no comments are received within the notice period which causes the Executive Officer of the Regional Water Board to reconsider the Expedited Payment Amount, the Executive Officer will execute the Acceptance and Waiver. Resolution of these violations by the Regional Water Board will preclude State Water Board action for these same violations.

SFPUC understands that if significant comments are received in opposition to the Expedited Payment Amount, the offer on behalf of the Regional Water Board to resolve the violations set forth in the attached Exhibit A may be withdrawn. In that circumstance, SFPUC will be advised of the withdrawal and an administrative civil liability complaint may be issued and the matter may be set for a hearing before the Regional Water Board or the State Water Board. For such a liability hearing SFPUC understands that this Acceptance and Waiver executed by SFPUC will be treated as a settlement communication and will not be used as evidence in that hearing.

SFPUC understands that once the Acceptance and Waiver is executed by the Executive Officer of the Regional Water Board, payment of the amount in full no later than 30 days after the date of the Executive Officer's signature is a condition of this Acceptance and Waiver. SFPUC must submit its payment in full by check made out to "California Regional Water Quality Control Board" and sent to the address indicated above, together with a copy of this Acceptance and Waiver after execution by the Executive Officer.

I hereby affirm that I am duly authorized to act on behalf of and to bind SFPUC in the making and giving of this Acceptance and Waiver.

\_\_\_\_\_  
San Francisco Public Utilities Commission (SFPUC)

By: Harlan Kelly Jr.  
(Signed Name)  
HARLAN KELLY JR.  
GENERAL MANAGER  
\_\_\_\_\_  
(Printed or typed name)

12/4/13  
\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Title)

IT IS SO ORDERED PURSUANT TO CALIFORNIA WATER CODE SECTION 13385

By: \_\_\_\_\_

Bruce H. Wolfe  
Executive Officer  
Regional Water Quality Control Board

**Note to SFPUC: Please return the signed waiver with Exhibit A, together.**

**EXHIBIT A**  
**Notice of Violation**

San Francisco Public Utilities Commission  
Drinking Water Transmission System located at Multiple Addresses (Linear System) in  
Alameda, Santa Clara, and San Mateo Counties

Mandatory Minimum Penalties without Regional Water Quality Control Board Hearing

The following table lists this facility's alleged permit exceedance of California Water Code (CWC) Sections 13385(h) and 13385(i) for which the Water Board has not assessed a mandatory minimum penalty. Final calculation of MMP amounts owed, and descriptions of the abbreviations that appear in the table are also listed in the table below.

No	CIWQS Violation ID No.	Date of Occurrence	Effluent Limitation Description (Unit)	Effluent Limit	Reported Value	Percent a Group I or Group II Pollutant is over Effluent Limitation	Type of Exceedance	CWC Section 13385(h) and/or (i) or 13385.1 Required MMP
1	940179	01/10/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.12	> 20% (See Note 1)	C1, S	\$3,000
2	946670	02/01/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	C2, S	\$3,000
3	946671	09/09/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	C1, S	\$3,000
4	940185	09/21/2010	pH (SU)	6.5 (SU)	6.4		C2	
5	946672	10/12/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	C3, S	\$3,000
6	946673	10/13/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
7	940186	10/18/2010	pH (SU)	8.5 (SU)	8.7		> C3	\$3,000

No	CIWQS Violation ID No.	Date of Occurrence	Effluent Limitation Description (Unit)	Effluent Limit	Reported Value	Percent a Group I or Group II Pollutant is over Effluent Limitation	Type of Exceedance	CWC Section 13385(h) and/or (i) or 13385.1 Required MMP
8	940187	10/25/2010	pH (SU)	8.5 (SU)	8.7		> C3	\$3,000
9	946674	11/02/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
10	940188	11/04/2010	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.07	> 20% (See Note 1)	> C3, S	\$3,000
11	940189	12/20/2010	pH (SU)	8.5 (SU)	8.6		> C3	\$3,000
12	946675	01/14/2011	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
13	946676	01/26/2011	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
14	946677	02/09/2011	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
15	940080	02/14/2011	pH (SU)	6.5	6.1		> C3	\$3,000
16	946678	04/07/2011	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
17	938601	01/12/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.15	> 20% (See Note 1)	C1, S	\$3,000
18	946680	02/01/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	C2, S	\$3,000

No	CIWQS Violation ID No.	Date of Occurrence	Effluent Limitation Description (Unit)	Effluent Limit	Reported Value	Percent a Group I or Group II Pollutant is over Effluent Limitation	Type of Exceedance	CWC Section 13385(h) and/or (i) or 13385.1 Required MMP
19	946681	02/06/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	C3, S	\$3,000
20	938609	03/07/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.09	> 20% (See Note 1)	> C3, S	\$3,000
21	946682	03/20/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
22	938620	04/26/2012	pH (SU)	8.5 (SU)	10.8		> C3	\$3,000
23	938622	05/15/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.6	> 20% (See Note 1)	> C3, S	\$3,000
24	946683	05/29/2012	Total Chlorine Residual Instantaneous Maximum (mg/L)	0.0	0.05	> 20% (See Note 1)	> C3, S	\$3,000
<b>Total</b>								<b>\$69,000</b>

**Legend for Table:**

CIWQS = California Integrated Water Quality System database used by the Water Boards to manage violation and enforcement activities.

Violation ID = Identification number assigned to a permit exceedance in CIWQS.

CWC = California Water Code.

C = Count – The number that follows represents the number of exceedances the Discharger has had in the past 180 days, including this violation. A count greater than three (> C3) means that a penalty under CWC Section 13385(i) applies.

S = Serious, which means that a penalty under CWC Section 13385(h) applies when an effluent limitation is exceeded 40% or more for a Group I pollutant or 20% or more for a Group II pollutant.

Note 1: Chlorine is a Group II pollutant and the percent that chlorine residue is more than the limit of 0.0 is more than 20 but not quantifiable.

Regulatory Measure ID: 389684

Place ID: 730408

WDID: 2 386065001