

ORDER NO. R2-2014-1025
ACCEPTANCE OF CONDITIONAL RESOLUTION
AND WAIVER OF RIGHT TO HEARING

By signing below and returning this Acceptance of Conditional Resolution and Waiver of Right to Hearing (Acceptance and Waiver) to the Regional Water Quality Control Board (Regional Water Board), Martinez Shell Refining Company (Shell) hereby accepts the "Offer to Participate in Expedited Payment Program" and waives the right to a hearing before the Regional Water Board to dispute the allegations of violations described in the Notice of Violation which is attached hereto as Exhibit A and incorporated herein by reference.

Shell agrees that the attached Exhibit A shall serve as a complaint pursuant to Article 2.5 of the California Water Code (CWC) and that no separate complaint is required for the Regional Water Board to assert jurisdiction over the alleged violations through its Assistant Executive Officer. Shell agrees to pay the penalties authorized by CWC section 13385, which shall be deemed payment in full of any civil liability pursuant to the CWC sections 13385 and 13385.1 that otherwise might be assessed for the violations described in the attached Exhibit A. Shell understands that this Acceptance and Waiver waives its right to contest the allegations in the Notice of Violation and Exhibit A and the amount of civil liability for such violations.

Shell understands that this Acceptance and Waiver does not address or resolve liability for any violation that is not specifically identified in the attached Exhibit A.

Upon execution by Shell, the Acceptance and Waiver shall be returned to:

Expedited Payment Program
California Regional Water Quality Control Board, San Francisco Bay Region
NPDES Enforcement Section, Regulatory Measure ID No. 394227
Attention: Farhad Azimzadeh
1515 Clay Street, Suite 1400
Oakland, California 94612

Shell understands that federal regulations set forth at title 40, Code of Federal Regulations, section 123.27(d)(2)(iii) require the Regional Water Board to publish notice of and provide at least 30 days for public comment on any proposed resolution of an enforcement action. Accordingly, this Acceptance and Waiver, prior to execution by the Executive Officer of the Regional Water Board, will be published as required by law for public comment.

If no comments are received within the notice period which causes the Executive Officer of the Regional Water Board to reconsider the Expedited Payment Amount, the Executive Officer will execute the Acceptance and Waiver. Resolution of these violations by the Regional Water Board will preclude State Water Board action for these same violations.

Shell understands that if significant comments are received in opposition to the Expedited Payment Amount, the offer on behalf of the Regional Water Board to resolve the violations set forth in the attached Exhibit A may be withdrawn. In that circumstance, Shell will be advised of the withdrawal and an administrative civil liability complaint may be issued and the matter may be set for a hearing before the Regional Water Board or the State Water Board. For such a liability hearing, Shell understands that this Acceptance and Waiver executed by Shell will be treated as a settlement communication and will not be used as evidence in that hearing.

Shell understands that once the Acceptance and Waiver is executed by the Executive Officer of the Regional Water Board, payment of the amount in full no later than 30 days after the date of the Executive Officer's signature is a condition of this Acceptance and Waiver. In accordance with California Water Code section 13385(n)(1) and California Water Code section 13385.1(c)(1), funds collected for violations of effluent limitations and reporting requirements pursuant to section 13385 and 13385.1 shall be deposited in the State Water Pollution Cleanup and Abatement Account. Accordingly, the liability shall be paid by a cashiers or certified check for \$6,000 made out to the "State Water Pollution Cleanup and Abatement Account" referencing the number of this Order and Regulatory Measure ID Number shown at the bottom of this page. The payment must be submitted to the State Water Resources Control Board, Division of Administrative Services, Accounting Branch 1001 I Street, 18th Floor, Sacramento, California, 95814.

I hereby affirm that I am duly authorized to act on behalf of and to bind Shell in the making and giving of this Acceptance and Waiver.

Martinez Shell Refining Company

By: PA Gabbard
(Signed Name)

23 June 2014
(Date)

Paul Gabbard
(Printed or typed name)

General Manager
(Title)

IT IS SO ORDERED PURSUANT TO CALIFORNIA WATER CODE SECTION 13385

By: _____

Bruce H. Wolfe
Executive Officer
Regional Water Quality Control Board

Note to Shell: Please return the signed waiver with Exhibit A, together.

**EXHIBIT A
Notice of Violation**

Martinez Shell Refining Company

Martinez Shell Refining Company Wastewater Treatment Plant located at
3485 Pacheco Blvd, Martinez, Contra Costa County

Mandatory Minimum Penalties without Regional Water Quality Control Board Hearing

The following table lists this facility's alleged permit exceedance of California Water Code (CWC) Sections 13385(h) and 13385(i) for which the Water Board has not assessed a mandatory minimum penalty. Final calculation of MMP amounts owed, and descriptions of the abbreviations that appear in the table are also listed in the table below.

No	CIWQS Violation ID No.	Date of Occurrence	Effluent Limitation Description (Unit)	Effluent Limit	Reported Value	Percent a Group I or Group II Pollutant is over Effluent Limitation	Type of Exceedance	CWC Section 13385(h) and/or (i) Required MMP
1	941169	11/30/2012	Mercury, Total Monthly Average	0.079	0.14	77%	C1, S	\$3,000*
2	942692	12/02/2012	Mercury, Total Daily Maximum (ug/L)	0.12	0.34	183%	C2, S	\$3,000*
3	950182	5/28/2013	Total Organic Carbon (TOC) Daily Maximum (mg/L)	110	1152	947%	C3, S	\$3,000
4	964265	1/9/2014	Mercury, Total Daily Maximum limit (ug/L)	0.12	0.155	29%	C1, S	\$3,000
5	964266	1/15/2014	Selenium, Total Daily Maximum limit (ug/L)	50	53	6%	C2	
Total								\$6,000

Legend for Table:

CIWQS = California Integrated Water Quality System database used by the Water Boards to manage violation and enforcement activities.

Violation ID = Identification number assigned to a permit exceedance in CIWQS.

CWC = California Water Code.

C = Count – The number that follows represents the number of exceedances Shell has had in the past 180 days, including this violation.

A count greater than three (> C3) means that a penalty under CWC Section 13385(i) applies.

S = Serious, which means that a penalty under CWC Section 13385(h) applies when an effluent limitation is exceeded 40% or more for a Group I pollutant or 20% or more for a Group II pollutant.

* Paid under Order No. R2-2013-1021

Regulatory Measure ID: 394227

Place ID: 256695

WDID No.: 2 071042001