

California Regional Water Quality Control Board
Santa Ana Region

Order No. R8-2013-0020

Amending Order No. R8-2002-0033

General Waste Discharge Requirements for the Re-injection/Percolation of Extracted and Treated Groundwater Resulting from the Cleanup of Groundwater Polluted by Petroleum Hydrocarbons, Solvents and/or Petroleum Hydrocarbons Mixed with Lead and/or Solvents within the Santa Ana Region

The California Regional Water Quality Control Board, Santa Ana Region (hereinafter Regional Board), finds that:

1. On May 31, 2002, the Regional Board adopted Order No. R8-2002-0033, for the reinjection/percolation of extracted and treated groundwater resulting from the cleanup of groundwater polluted by petroleum hydrocarbons, solvents and/or petroleum hydrocarbons mixed with lead and/or solvents.
2. On October 3, 2003, Order No. R8-2002-0033 was amended by Order No. R8-2003-0085 to add a new compliance determination for the tert butyl alcohol (TBA) average monthly limit and to add average monthly limits for cis 1,2-dichloroethylene; trans 1,2-dichloroethylene; 1,4-dioxane; and perchlorate.
3. It is appropriate to amend Order No. R8-2002-0033 again to revise the average monthly limits for 1,4-dioxane and perchlorate.
4. The amendment of waste discharge requirements for the cleanup of defined groundwater contamination plume(s) is for the protection of the environment and, as such, is exempt from the California Environmental Quality Act (Public Resources Code, Section 21100 et. seq.) in accordance with Section 15308, Chapter 3, Title 14, California Code of Regulations.
5. The Regional Board has notified all dischargers currently enrolled under Order No. R8-2002-0033 and other interested agencies and persons of its intent to amend the Order and has provided them with an opportunity to submit their written views and recommendations.
6. The Regional Board, in a public meeting, heard and considered all comments pertaining to the discharge.


IT IS HEREBY ORDERED that Order No. R8-2002-0033 be amended as follows:

1. A portion of the Discharge Specification A.1. of Order No. R8-2002-0033 be revised with the following limits:

Constituent	Average Monthly Concentration Limit
1,4-Dioxane	1 µg/l
Perchlorate	6 µg/l

2. This amendment shall become effective upon the adoption of this Order.
3. All other conditions and requirements of Order No. R8-2002-0033, as amended by Order No. R8-2003-0085, including attachments, shall remain unchanged.

I, Kurt V. Berchtold, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, Santa Ana Region, on June 7, 2013.



Kurt V. Berchtold
Executive Officer