SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/29/2004	7/28/2004	40063	Private Property Owner	1742 Clementine St., Anaheim, Orange County	SSO	1,360	An estimated 1,360 gallons of sewage overflowed from the private property owner's manhole due to unknown reason. 1,100 gallons of the spill were contained, recovered, and returned to the opertational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Anaheim staff.
8/1/2004	8/1/2004	40084	City of Ontario	1217 E. Sixth St., Ontario, San Bernardino County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to a grease blockage. All 900 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the City of Ontario staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/1/2004	8/1/2004	40146	City of Ontario	6th St., @ Grove, Ontario, San Bernardino County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to grease blockage. 200 gallons of the spill were contained, recovered, and returned to the opertational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Ontario staff.
8/3/2004	8/3/2004	40064	Costa Mesa Sanitation District	2063 National Ave., Costa Mesa, Orange County	SSO	900	An estimated 900 gallons of sewage leaked from a pressure releave valve failure of the force main. 800 gallons of the spill were contained, recovered, and returned to the operational sewer system and while the rest of the spill discharged into the local storm drain. The pressure releave valve was repaired, the affected area was cleaned up and disinfected by CMSD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/10/2004	8/10/2004	40144	City of Fontana	7251 Arcadia Place., Fontana, San Bernardino County	SSO	960	An estimated 960 gallons of sewage overflowed from a manhole due to tree roots blockage. City of Fontana staff was unable to contain the spill and it discharged into a local storm drain and flowed to the Santa Ana River. The tree roots was removed, the affected area was cleaned up and disinfected by the City of Fontana staff.
8/14/2004	8/14/2004	39903	City of Anaheim	6700 Walnut Canyon Road, Anaheim, Orange County	SSO	7,020	An estimated 7,020 gallons of sewage overflowed from a manhole due to tree root blockage. 5000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Anaheim staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/18/2004	8/18/2004	40065	City of Redlands	Intersection of Pennsylvania & Arelne, Redlands, San Bernardino County	SSO	800	An estimated 800 gallons of sewage overflowed from a manhole due to an excessive discharge of treated well water to the city sewer line from the City's Texas Street G.A.C. Facility during a perchlorate removal study. All 800 gallons of the spill discharged to a dry storm drain, where it percolated. The affected area was cleaned up by the City of Redlands staff.
8/23/2004	8/23/2004	40105	City of Orange	2740 Villa Real Dr., Orange, Orange County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to tree roots blockage. 700 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Orange staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/2/2004	9/2/2004	39863	Private Property Owner	3091 W. Chapman, Orange, Orange County	SSO	54,000	An estimated 54,000 gallons of sewage leaked from a broken sewer line during contractor's excavation in the area. The private contractor build a dirt berm to contain the spill and they used a sump pump to pump all 54,000 gallons of the spill into the operational sewer system. The line was repaired, the affected area was cleaned up and disinfected by the private contractor with assistance of the City of Orange staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/4/2004	9/4/2004	39803	Orange County Sanitation District	OCSD, Plant #2, Orange, Orange County	SSO	1.6M	An estimated 1.6 million gallons of primary and secondary effluent overflowed from OCSD's Treatment Plant #2. The cause of the spill was a power surge from the Edison power system that affected both of the treatment plants. The surge took the form of short circuit and shut off many of Plant #2 loads. All 1.6 million gallons of the spill discharged to the Santa Ana River and flowed to the Pacific Ocean. OCHCA closed portions of the Pacific Ocean (up and down coast of the Santa Ana River mouth). In response to the spill, OCSD created a new team to respond to this kind of problem and to avoid sewage spills in the future. An ACLC will be issued for this discharge.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/7/2004	9/7/2004	40085	Private Property Owner	3091 W. Chapman Ave., Orange, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a broken sewer line due to contactors excavation in the area. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and flowed to the Santa Ana River. The broken line was repaired, the affected area was cleaned up and disinfected by a private contractor with assistance of the City of Orange staff.
9/11/2004	9/11/2004	39743	City of Beaumont	Trinette Dr. & Cedar View, Beaumont, Riverside County	SSO	12,250	An estimated 12,250 gallons of sewage overflowed from a manhole due to debris and wooden stakes dropped into a manhole by vandals. All 12,250 gallons of the spill discharged to a dry storm drain where it percolated. The blockage was removed, the affected area was cleaned up and disinfected by the City of Beaumont staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/11/2004	9/11/2004	39884	Private Property Owner	7931 Stark Ave. Huntington Beach, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a lateral of a private apartment building due to a grease blockage. All 1,000 gallons of the spill discharged to the flood control channel. The blockage was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of the Huntington Beach staff.
9/14/2004	9/14/2004	40104	City of Corona	Butterfield & Clearwater Rd., Corona, Riverside County	STE	10M	An estimated 10,000,000 gallons of secondary treated effluent was released from a hole on a 24" effluent line. This line transmits non-disinfected secondary effluent from Wasetwater Treatment Plant #A1 to the percolation ponds at Lincoln Avenue and Cota Street. All 10M gallons of the spill discharged to the Butterfield Drain which merges with Temescal Creek and then leads to Prado Dam and then to the Santa Ana River. The pipe was repaired, the affected area was cleaned up by the City of Corona staff. This incident is under investigation by Board staff and an ACLC may be issued to the City of Corona.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/16/2004	9/16/2004	40003	City of Anaheim	131 Cerro Vista Way, Anaheim, Orange County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to tree roots. 150 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Anaheim.
9/18/2004	9/18/2004	40164	Eastern Municipal Water District	29541 Murrieta Rd., Sun City, Riverside County	Brine Water	27,000	An estimated 27,000 gallons of brine water released from Menifee Desalter pump station due to pump failure. All 27,000 gallons of the spill discharged to the Salt Creek where it percolated. The alarm system of the pump is repaired, the affected area was cleaned up by EMWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/23/2004	9/23/2004	39986	Private Property Owner	1317 S. Standard Ave., Santa Ana, Orange County	SSO	720	An estimated 720 gallons of sewage overflowed from a private property's clean out due to a grease blockage. 670 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of the City of Santa Ana staff.
9/24/2004	9/23/2004	39985	City of Colton	1300 block Meridian, Colton, San Bernardino County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to debris blockage. All 3,000 gallons of the spill discharged to a local storm drain. The debris was removed, the affected area was cleaned up and disinfected by the City of Colton staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/27/2004	9/24/2004	39843	Private Property Owner	584 West Hamilton. Costa Mesa, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a private manhole due to a grease blockage. 1,600 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the Costa Mesa Water District staff.
9/27/2004	9/27/2004	40124	Cucamonga Valley Water District	13500 Victoria St., Rancho Cucamonga, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to a bag of asphalt poured into the manhole by vandals. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The bag of asphalt was removed from the manhole, the affected area was cleaned up and disinfected by CVWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/27/2004	9/27/2004	40364	Cucamonga Valley Water District	10440 Ashford St., Rancho Cucamonga, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to debris dumped into manhole by vandals. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The debris was removed, the affected area was cleaned up and disinfected by CVWD staff.
9/30/2004	9/30/2004	39944	Private Property Owner	201 Yale St., Hemet, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private property's clean out due to debris blockage. All 1,000 gallons of the spill discharged to a dry local storm drain where it percolated. The debris was removed, the affected area was cleaned up and disinfected by a private contractor.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/30/2004	9/30/2004	40106	City of Colton	1300 Blk of Meridian, Colton, San Bernardino County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to a grease and rocks blockage. 2,800 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a dry local storm drain where it percolated. The blockage was removed, the affected area was cleaned up and disinfected by the City of Colton staff.
10/4/2004	10/4/2004	40403	City of Placentia	Essex Cir., Placentia, Orange County	SSO	2,175	An estimated 2,175 gallons of sewage overflowed from a manhole due to a grease blockage. 1,500 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Placentia staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/4/2004	10/4/2004	40365	City of Lake Elsinore	Mission Trail Ave, Lake Elsinore, Riverside County	SSO	3,750	An estimated 3,750 gallons of sewage overflowed from a lift station due to accumulation of rags and debris in the wet well which caused a pump failure. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The rags and debris were removed from the wet well, pumps restored to normal operation, and the affected area was cleaned up by the City of Lake Elsinore staff.
10/9/2004	10/9/2004	40245	Cucamonga Valley Water District	Carnelion at Vivero, Rancho Cucamonga, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to unknown blockage. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by CVWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/11/2004	10/11/2004	40363	Jurupa Community Services District	30th St. & Donner Way, Jurupa, Riverside County	SSO	500	An estimated 500 gallons of sewage was released from an 8" broken sewer line during contractors excavation of the line. All 500 gallons of the spill which contained in the excavated area, recovered, and returned to the operational sewer system. The broken line was repaired, the affected area was cleaned up and disinfected by the JCSD staff.
10/17/2004	10/17/2004	40383	City of Huntington Beach	Intersection of Warner & Graham, Huntington Beach, Orange County	SSO	4,500	An estimated 4,500 gallons of sewage overflowed from a manhole due to a grease blockage. 4,000 gallons of sewage were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Huntigton Beach staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/20/2004	10/20/2004	40303	City of Riverside	4481 Brockton Ave. Riverside, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to unknown blockage. All 500 gallons of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Riverside staff.
10/20/2004	10/20/2004	40408	City of Riverside	4800 Magnolia Ave., Riverside, Riverside County	SSO	37,400	An estimated 37,400 gallons of sewage overflowed from a manhole due to insufficient capacity of the sewer line. The City of Riverside is aware of the problem and this sewer line put on the priority list for capital improvements. All 37,400 gallons of the spill commingled with storm water and discharged into a local storm drain. Debris were removed, the affected area was cleaned up by the City of Riverside staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/20/2004	10/20/2004	40405	San Bernardino County Special Districts	Lytle Creek Road, Lytle Creek, San Bernardino County	SSO	80,800	An estimated 80,800 gallons of sewage was released from an 8" PVC sewer line. This sewer line was washed away along with the roadway during a rain storm. 800 gallons of the spill were contained, recovered, and returned to the operational sewer system. The remaining 80,000 gallons of the spill discharged to Lytle Creek and commingled with storm water. New sewer line was installed and the roadway was repaired by the County and Special Distrcts staff.
10/21/2004	10/20/2004	40343	City of Riverside	2521 Arroyo Dr., Riverside, Riverside County	SSO	66,995	An estimated 66,995 gallons of sewage released from an 8" sewer line which was washed out during a rain storm. This sewer line runs through Victoria Country Club. All the spill was contained in the irrigation ponds of the Club. The 8" sewer line was replaced and repaired, the affected area was cleaned up and the wastewater flow in the line was restored to a normal process by the City of Riverside.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/22/2004	10/21/2004	40304	Private Property Owner	2307 S. Bristol, Santa Ana, Orange County	SSO	1,380	An estimated 1,380 gallons of sewage overflowed from a private manhole due to a grease blockage. 690 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and to Upper Newport Bay. The blockage was removed, the affected area was cleaned up and disinfected by a private property owner.
10/23/2004	10/23/2004	40344	City of Orange	2700 E. Villa Real, Orange, Orange County	SSO	950	An estimated 950 gallons of sewage overflowed from a manhole due to a grease blockage. 800 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Orange.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/23/2004	10/23/2004	40345	Private Property Owner	240 N. Parker, Orange, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private manhole due to a grease blockage. 250 gallons of spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local catch basin. The blockage was removed, the affected area was cleaned up and disinfected by the private contractor with assistance of the City of Orange staff.
11/3/2004	11/3/2004	40406	San Bernardino International Airport Authority	105 S. Leland Norton Way, San Bernardino, San Bernardino County	SSO	5,800	An estimated 5,800 gallons of sewage was released to a local storm drain. A sub-contractor of the Airport's master developer mistakenly plumbed the portable restroom trailer's sewage line into a storm drain line during the installation of the restroom. Upon the discovery of the problem, the restroom was shut down and the plumbing to the sewer line was restored. The storm drain was cleaned up and disinfected by the San Bernardino Airport Authority staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/5/2004	11/4/2004	40323	Private Property Owner	1001 W. MacArthur Blvd., Santa Ana, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a private property owner's manhole due to tree roots. All 600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The tree roots were removed, the affected area was cleaned up and disinfected by a private contractor.
11/10/2004	11/10/2004	40223	City of Ontario	Rear of 2200 E. Holt Blvd, Ontario, San Bernardino County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to a grease blockage. All 500 gallons of sewage were contained, recovered, and returned to the operational sewer system. The grease blockage was removed, the affected area was cleaned up and disinfected by the City of Ontario.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/14/2004	11/13/2004	40263	Cucamonga Valley Water District	10440 Ashford Street, Rancho Cucamonga, San Bernardino County	SSO	24,000	An estimated 24,000 gallons of sewage overflowed from a manhole due to a boulder lodged in a sewer line. 6,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spll discharged to the flood control channel. The sewer line was bypassed and the area was excavated to clear the blockage. The affected area was cleaned up and disinfected by CVWD staff.
11/14/2004	11/14/2004	40409	City of Newport Beach	21244 Newport Coast Drive, Newport Beach, Orange County	SSO	4,700	An estimated 4,700 gallons of sewage was released from a 14-year old ductile iron force main which was corroded on the outside to the point where it failed and began to leak. All 4,700 gallons of the spill discharged into a local storm drain and flowed to the headwaters of Buck Gully. The line was repaired, the affected area was cleaned up and disinfected by IRWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/14/2004	11/14/2004	40410	Eastern Municipal Water District	Acacia St., Hemet, Riverside County	SSO	1M	An estimated 1,000,000 gallons of sewage was released from a broken 12" PVC force main. 4,000 Gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged to an open field where it percolated. The line was repaired, debris was cleaned up and the affected area was disinfected by EMWD staff.
11/16/2004	11/16/2004	40247	City of Beaumont	Cedar Brook at Evergreen, Beaumont, Riverside County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to construction debris. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a local storm drain and to a dry Noble Creek. Debris was removed, the affected area was cleaned up and disinfected by the City of Beaumont staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/17/2004	11/17/2004	40411	City of La Habra	710 Lambert Drive, La Habra, Orange County	SSO	750	An estimated 750 gallons of sewage overflowed from a manhole due to a consturction debris. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill dischaged into a local storm drain. The debris was removed, the affected area was cleaned up and disinfected by the City of La Habra staff.
11/19/2004	11/19/2004	40246	City of Huntington Beach	Edwards Ave. at Armada, Huntington Beach, Orange County	SSO	800	An estimated 800 gallons of sewage was released from City's force main when a contractor hit the line during the excavation. All 800 gallons of the spill were contained, recovered, and returned to the operational sewer system. The sewer line was repaired, the affected area was cleaned up and disinfected by the City of Huntington Beach staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/20/2004	11/20/2004	40412	City of Orange	858 N. Olive, Orange, Orange County	SSO	700	An estimated 700 gallons of sewage overflowed from a manhole due to a grease blockage. 300 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Orange staff.
11/24/2004	10/20/2004	40407	City of Colton	224 W. Congress, Colton, San Bernardino County	SSO	10,000	An estimated 10,000 gallons of sewage overflowed from a manhole due to infltration and vandalism. Vandals removed a manhole lid the day before a rain storm. All 10,000 gallons of the spill commingled with storm water and discharged into a local storm drain. The manhole lid was put back on the manhole and secured, the affected area was cleaned up by the City of Colton staff.

Row(s) 1 - 50