

**Table 3: Test Methods and Minimum Levels [REVISED]**

(If the minimum levels specified in the table below are higher than the effluent limits, the permittee will be deemed to be in compliance with the effluent limits if that constituent is not detected (ND) above the minimum level. If the data set includes a number of “NDs” and numerical values above ND, then the median value for the data set shall be considered. If the data set includes an even number of values and the median includes a “ND” and a numeric value, then the median shall be considered as ND.)

Constituent	Units	Test Method	Minimum Level
pH	pH units	EPA 9040/SM <sup>35</sup> 4500H or field test with a calibrated portable instrument	±0.1
Turbidity	NTUs	EPA 180.1/SM 2130B or field test with a calibrated portable instrument	0.5
Oil and Grease	mg/L	EPA 1664A	5.0
Specific Conductance	µmhos/cm	EPA 120.1/ SM 2510-B or field test with portable instrument	1.0
Total Petroleum Hydrocarbons	mg/l	EPA 1664A or EPA 8015B	5.0
Zinc (total recoverable)	µg/l	EPA 200.8	5.0
Nickel (total recoverable)	µg/l	EPA 200.8	1.0
Silver (total recoverable)	µg/l	EPA 200.8	1.0
Lead (total recoverable)	µg/l	EPA 200.8	1.0
Aluminum (total recoverable)	µg/l	EPA 200.8	1.0
Copper (total recoverable)	µg/l	EPA 200.8	1.0
Iron (total recoverable)	µg/l	EPA 200.8 or EPA 200.7	1.0
Cadmium (total recoverable)	µg/l	EPA 200.8	1.0
Arsenic (total recoverable)	µg/l	EPA 200.8	1.0
Chemical Oxygen Demand (COD)	mg/l	SM 5220C or SM 5220D	10.0
PCBs	µg/l	EPA Method 608	0.5

**C. Sampling and Analysis Reduction:** If a Permittee is in full compliance with the sampling and analysis requirements specified above (collected the required number of samples within the specified time period and has analyzed for all the listed parameters), the visual inspections have not identified any violations, and the analytical results have not exceeded any of the triggers specified in this Permit for NELs and NALs for at least two consecutive years, the Permittee may request for a reduction in the sampling and analysis frequencies. Once the reduction request is approved by the Executive Officer, it can be implemented by the discharger. Approved reductions can be revoked by the

<sup>35</sup> SM= Standard Methods for the Examination of Water and Wastewater, 18<sup>th</sup> Edition