

# Lubrizol Ultrazol

Manufacturer's Affirmative Statement of Compatibility  
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years of Manufacture	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
Bravo	F-Series	Entry fitting	MH29867	2006-Present	All	olive-grey	1-100	Yes
Bravo	F-Series Retrofit-S	Retrofit entry fitting	MH29867	2010-Present	All	olive-grey	1-100	Yes
Bravo	F-Series Retrofit D-BLR-S	Retrofit entry fitting	3rd Party	2009-Present	All	olive-grey	1-100	Yes
Bravo	F-Series Retrofit D-INR-S	Retrofit entry fitting	3rd Party	2012-Present	All	olive-grey	1-100	Yes
Bravo	FR-Series Reducer	Test reducer	MH29867	2010-Present	All	olive-grey	1-100	Yes
Bravo	B-500 Series	Cont. sump	MH29867	2003-Present	All	olive-grey	1-100	Yes

For tanks and piping please list only double wall products

(Insert a company logo below if available)

Manufacturer: Bravo (S. Bravo Systems, Inc.)  
Corporate  
Headquarters 2929 Vail Ave, Commerce, CA  
Address:  
Phone: 323-888-4133  
Email: [compatibility@sbravo.com](mailto:compatibility@sbravo.com)



I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

Jonathan E. Smith

Print Name

Director

Title

Manufacturer's Authorized Signature

10-21-14

Date



Tuesday - August 30 - 2011

R2 1.18.12

## RE: Bravo Fiberglass Fittings and Alternative fuels

This letter is to certify the compatibility of S. Bravo Systems, Inc. Single and Double Wall Fiberglass Sump Entry Fittings with Alternative Fuels such as Biodiesel and Ethanol blended fuels. It also addresses compatibility with DEF Diesel Exhaust Fluid.

Bravo Systems Fiberglass Fittings are engineered with the same UL Listed materials used in the manufacture and certification of Fiberglass Tanks, matching the UL Standard 1316. Since our Fiberglass Fittings are Built like a Tank, they can withstand continuous fuel exposure to, or submersion in Biodiesel, Ethanol and Alcohol blends without failure.

All Fiberglass Fittings designed for DoubleWall Sumps are engineered to be fully compliant with the California State Water Resource Control Board Assembly Bill AB-2481 for DoubleWall Sumps and Continuous Monitoring Systems.

The following Single and Double Wall Fiberglass Fittings manufactured by Bravo Systems in Commerce, California are compatible with Biodiesel and Ethanol fuel blends up to B100 and E100, respectively.

- > **F-Series** "Full Body" Fiberglass Fittings.
- > **FF-Series** "Flange" Fiberglass Fittings.
- > **FPE-Series** Fiberglass Fittings for Polyethylene pipe.
- > **FR-Series** Fiberglass Split Test Reducers.
- > **F-Series Retrofit-S** Fiberglass Split Retrofit Fittings.
- > **FPE-Retrofit-Si** Fiberglass Split Retrofit Fittings for Polyethylene pipe.
- > **F-Series BLR** "Full Body" Fiberglass Retrofit Fittings.
- > **F-Series D-BLR-S** Fiberglass Split Retrofit Fittings.
- > **TBF-Series** Fiberglass Tank Bung Fittings.

Bravo Systems also certifies that these fittings are compatible with and approved for use in secondarily containing DEF Diesel Exhaust Fluid.

This letter also addresses any fittings above sold under an OEM agreement.

Each respective Series may be UL Listed in addition to being manufactured of UL recognized materials approved for use in the manufacture of Fiberglass UST tanks. Please visit [www.sbravo.com/thirdparty](http://www.sbravo.com/thirdparty) to find associated information.

Please feel free to contact us with any questions you may have at:

S. Bravo Systems, Inc.  
2929 Vail Avenue  
Commerce, CA 90040  
323-888-4133  
[compatibility@sbravo.com](mailto:compatibility@sbravo.com)

Additionally, you may find further information at [www.sbravo.com](http://www.sbravo.com).

Sincerely,

Jonathan E. Smith  
Director of Brand Management  
S. Bravo Systems, Inc.

### S. Bravo Systems, Inc.

2929 Vail Avenue  
Commerce,  
CA 90040

1-800-AT-BRAVO

FAX: 323-888-4123

Email:  
[info@sbravo.com](mailto:info@sbravo.com)

Website:  
[www.sbravo.com](http://www.sbravo.com)



Wednesday - August 25 - 2010

R2 5.16.12

## RE: Bravo Fiberglass Sumps and Alternative fuels

This letter is to certify the compatibility of S. Bravo Systems, Inc. Single and Double Wall Fiberglass Containment Sumps with Alternative Fuels such as Biodiesel and Ethanol blended fuels. It also addresses compatibility with DEF Diesel Exhaust Fluid.

Bravo Systems Fiberglass products are engineered with the same UL Listed materials used in the manufacture and certification of Fiberglass Tanks, matching the UL Standard 1316. Since our Fiberglass containment sumps are Built like a Tank, they can withstand continuous fuel exposure to Biodiesel, Ethanol and Alcohol blends without failure.

All DoubleWall Containment Sumps are engineered to be fully compliant with the California State Water Resource Control Board Assembly Bill AB-2481 for DoubleWall Sumps and Continuous Monitoring Systems.

The following Single and Double Wall Containment Sumps manufactured by Bravo Systems in Commerce, California are compatible with Biodiesel and Ethanol fuel blends up to B100 and E100, respectively.

- > B3XX Series Spill Buckets
- > B4XX Series Tank Sumps & Covers
- > B5XX Series Planter Transition Sumps
- > B6XX Series Walkover Transition Sumps
- > B7XX Series H-20 Rated Transition Sumps
- > B8XX Series Transition Sumps
- > B7XXX Series Under Dispenser Containment Sumps
- > B8XXX Series Under Dispenser Containment Sumps
- > B9XXX Series Under Dispenser Containment Sumps

Bravo Systems also certifies that these fittings are compatible with and approved for use in secondarily containing DEF Diesel Exhaust Fluid.

Each respective Series may be UL Listed in addition to being manufactured of UL recognized materials approved for use in the manufacture of Fiberglass UST tanks. Please visit [www.sbravo.com/thirdparty](http://www.sbravo.com/thirdparty) to find associated information.

Please feel free to contact us with any questions you may have at:

S. Bravo Systems, Inc.  
2929 Vail Avenue  
Commerce, CA 90040  
323-888-4133  
[compatibility@sbravo.com](mailto:compatibility@sbravo.com)

Additionally, you may find further information at [www.sbravo.com](http://www.sbravo.com).

Sincerely,

Jonathan E. Smith  
Director of Brand Management  
S. Bravo Systems, Inc.

### S. Bravo Systems, Inc.

2929 Vail Avenue  
Commerce,  
CA 90040

1-800-AT-BRAVO

FAX: 323-888-4123

Email:  
[info@sbravo.com](mailto:info@sbravo.com)

Website:  
[www.sbravo.com](http://www.sbravo.com)

# Certificate of Compliance

Certificate Number **20101221 – MH29867E**  
Report Reference **MH29867, 2009 February 03**  
Issue Date **2010 December 21**

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **S BRAVO SYSTEMS INC**

**2929 VAIL AVE  
COMMERCE, CA 90040 USA**

*This is to certify that  
representative samples of*

## **Flammable and Combustible Liquid Tank Accessories**

**Model Descriptions: Models F-10-RR, F-10-SS, F-17-RR, F-17-SS, F-20-LL, F-22-LS, F-22-LS-T, F-30-LL, F-30-SS, F-32-TS, F-32-TS-T, F-33-LS, F-33-LS-T, F-40-SS, F-43-TS and F-43-TS-T fiberglass reinforced plastic sump penetration fittings.**

*Have been investigated by Underwriters Laboratories Inc.® in accordance  
with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*

**The basic standard used to investigate products in this category is  
UL Subject 2258, "Outline of Investigation for Nonmetallic Tanks for Oil Burner  
Fuel."**

*Additional Information:*

**See UL On-line Certification Directory at [www.ul.com](http://www.ul.com) for additional information.**

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

**William R. Carney**

**Director, North American Certification Programs**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

# Certificate of Compliance

Certificate Number 20101221 - MH29867E  
Report Reference MH29867, 2009 February 03  
Issue Date 2010 December 21

Page 1 of 1



**Issued to:** S BRAVO SYSTEMS INC  
2929 VAIL AVE  
COMMERCE, CA 90040 USA

*This is to certify that representative samples of*

**Flammable and Combustible Liquid Tank Accessories**

**Model Descriptions:** Models F-10-RR, F-10-SS, F-17-RR, F-17-SS, F-20-LL, F-22-LS, F-22-LS-T, F-30-LL, F-30-SS, F-32-TS, F-32-TS-T, F-33-LS, F-33-LS-T, F-40-SS, F-43-TS and F-43-TS-T fiberglass reinforced plastic sump penetration fittings.

*Have been investigated by Underwriters Laboratories of Canada in accordance with the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety:** The basic standard used to investigate products in this category is ULC-S631-1984, "Isolating Bushings for Steel Underground Tanks Protected with External Corrosion Protection Systems."

**Additional Information:** See UL On-line Certification Directory at [www.ul.com](http://www.ul.com) for additional information.

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the current status, validate the above information via the on-line directory.

**Look for the ULC Listing Mark on the product**

Issued by:

James Larin, Customer Service Professional  
Underwriters Laboratories of Canada

Reviewed by:

William R. Carney, Director, North American  
Underwriters Laboratories of Canada

# Certificate of Compliance

Certificate Number 20101221 – MH29867C  
Report Reference MH29867, 2005 March 17  
Issue Date 2010 December 21

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **S BRAVO SYSTEMS INC**

**2929 VAIL AVE  
COMMERCE, CA 90040 USA**

*This is to certify that  
representative samples of*

## **Flammable and Combustible Liquid Tank Accessories**

**Model Descriptions: Models B-4000, B-5000, B8000, B8000-B and B-9000 single wall fiberglass reinforced plastic dispenser sumps with emergency valve mounting systems.**

**Models B-4000-D-AB, B-5000-D-AB, B-8000-BD-AB and B-9000-D-AB double wall, monitorable fiberglass reinforced plastic dispenser sumps with emergency valve mounting systems.**

**Model B-500-JP and B-600-JP single wall fiberglass reinforced plastic transition sump.**

**Models B-500-D-AB JP and B-600-D-AB double wall, monitorable fiberglass reinforced plastic transition sumps.**

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*

**The basic standard used to investigate products in this category is UL Subject 2258, "Outline of Investigation for Nonmetallic Tanks for Oil Burner Fuel."**

*Additional Information:*

**See UL On-line Certification Directory at [www.ul.com](http://www.ul.com) for additional information.**

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

**William R. Carney**

**Director, North American Certification Programs**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

# Certificate of Compliance

Certificate Number **20101221 – MH29867D**  
Report Reference **MH29867, 2008 November 19**  
Issue Date **2010 December 21**

Page 1 of 1



*Issued to:* **S BRAVO SYSTEMS INC**

**2929 VAIL AVE  
COMMERCE, CA 90040 USA**

*This is to certify that  
representative samples of*

## **Flammable and Combustible Liquid Tank Accessories**

**Model Descriptions: Models B-7000, B-7000-EO, B8000 and B-9000 single wall fiberglass reinforced plastic dispenser sumps with mounting frames.**

**Model B-500-JP and B-600-JP single wall fiberglass reinforced plastic transition sump.**

*Standard(s) for Safety:*

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

**The basic standard used to investigate products in this category is UL Subject 2258, "Outline of Investigation for Nonmetallic Tanks for Oil Burner Fuel."**

*Additional Information:*

**See UL On-line Certification Directory at [www.ul.com](http://www.ul.com) for additional information.**

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

**William R. Carney**

**Director, North American Certification Programs**

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

# Certificate of Compliance

Certificate Number 20101221 - MH29867D  
Report Reference MH29867, 2008 November 19  
Issue Date 2010 December 21

Page 1 of 1



**Issued to:** S BRAVO SYSTEMS INC  
2929 VAIL AVE  
COMMERCE, CA 90040 USA

*This is to certify that representative samples of*

**Flammable and Combustible Liquid Tank Accessories**  
**Model Descriptions:** Models B-7000, B-7000-EO, B8000 and B-9000 single wall fiberglass reinforced plastic dispenser sumps with mounting frames.  
Model B-500-JP and B-600-JP single wall fiberglass reinforced plastic transition sump.

*Have been investigated by Underwriters Laboratories of Canada in accordance with the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety:** The basic standard used to investigate products in this category is ULC-S631-1984, "Isolating Bushings for Steel Underground Tanks Protected with External Corrosion Protection Systems."

**Additional Information:** See UL On-line Certification Directory at [www.ul.com](http://www.ul.com) for additional information.

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the current status, validate the above information via the on-line directory.

**Look for the ULC Listing Mark on the product**

Issued by:

James Larin, Customer Service Professional  
Underwriters Laboratories of Canada

Reviewed by:

William R. Carney, Director, North American  
Underwriters Laboratories of Canada