

Biodiesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
Containment Solutions (previously Fluid Containment)	Double-Wall fiberglass tank	tank	UL file # MH7991	1995 - 2012 (present)	550 - 50,000 gallons	UL unique number label	0-5% and all blends between	No
Containment Solutions (previously Fluid Containment)	Double-wall transition sump	transition sump	UL file # MH29555	2004 - 2012 (present)	42" dia. 48" dia.	UL mark	0-5% and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump	tank top sump	UL file # MH29555	2004 - 2012 (present)	42" dia. 48" dia.	UL mark	0-5% and all blends between	
Containment Solutions (previously Fluid Containment)	HydroGuard® System	tank and tank top sump	UL file # MH7991	2004 - 2012 (present)	550 - 50,000 gallons	UL unique number label	0-5% and all blends between	
Containment Solutions (previously Fluid Containment)	Triple-Wall fiberglass tank	tank	UL file # MH7991	1997 - 2012 (present)	550 - 50,000 gallons	UL unique number label	0-5% and all blends between	
Containment Solutions (previously Fluid Containment)	ReTank®	in situ tank upgrade	UL file # MH25159	1996 - 2012 (present)	8' dia. tanks 4,000 - 15,000 gallons	proprietary panel design	0-5% and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall fiberglass tank	tank		1995 - 2012 (present)	550 - 50,000 gallons	UL unique number label	6-100% as defined by ASTM and all blends between	
Containment Solutions	Double-wall transition sump	transition sump		2004 - 2012 (present)	42" dia. 48" dia.	UL mark	6-100% as defined by	

Please complete and submit form to Cory Hootman of the SWRCB at chootman@waterboards.ca.gov.

Biodiesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

(previously Fluid Containment)								ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump	tank top sump		2004 - 2012 (present)	42" dia. 48" dia.	UL mark		6-100% as defined by ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	HydroGuard® System	tank and tank top sump		2004 - 2012 (present)	550 - 50,000 gallons	UL unique number label		6-100% as defined by ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	Triple-Wall fiberglass tank	tank		1997 - 2012 (present)	550 - 50,000 gallons	UL unique number label		6-100% as defined by ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	ReTank®	in situ tank upgrade		1996 - 2012 (present)	8' dia. tanks 4,000 - 15,000 gallons	proprietary panel design		6-100% as defined by ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall transition sump	transition sump		June 2012	54" dia.			0-100% as defined by ASTM and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump	tank top sump		June 2012	54" dia.			0-100% as defined by ASTM and all blends between	
Containment Solutions	Double-Wall tank sump upgrade	transition & tank top		June 2012	42" dia. 48" dia.			0-100% as defined by	

❖ Please complete and submit form to Cory Hootman of the SWRCB at chootman@waterboards.ca.gov.

Biodiesel

Manufacturer's Affirmative Statement of Compatibility
 (As required by California Code of Regulations section 2631(k))

(Previously Fluid Containment)	sumps					ASTM and all blends between	
(Insert a company logo below if available)							

For tanks and piping please list only double wall products

Manufacturer: Containment Solutions, Inc.

Corporate **5150 Jefferson Chemical Rd**

Headquarters **Conroe, TX 77301**

Address:

Phone: 877-CSI-TANK

Email: sales@csiproducts.com



I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

David Heiman

Print Name

Director of Marketing

Title

5/1/2012

Date

Manufacturer's Authorized Signature